

MAASTRICHT AACHEN AP, Netherlands

WMO: 063800

Lat: 50.9053N

Lon: 5.7619E

Elev: 114

StdP: 99.96

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.6	-4.6	-10.2	1.6	-4.9	-7.8	2.0	-3.3	14.0	8.8	12.6	8.8	3.6	50	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	30.2	20.2	27.8	19.4	25.8	18.5	21.1	27.7	20.2	26.2	19.3	24.4	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.9	23.5	18.1	13.2	22.6	17.2	12.5	21.7	61.5	27.5	58.2	26.3	55.3	24.5	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.7	8.5	-9.2	34.0	3.2	1.9	-11.5	35.4	-13.4	36.5	-15.2	37.5	-17.6	38.9		
(5)			-9.6	23.0	3.2	1.2	-11.9	23.9	-13.8	24.6	-15.6	25.3	-17.9	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	3.1	3.9	6.6	10.1	13.8	16.8	18.9	18.5	15.2	11.4	7.0	3.9	(6)
(7)		DBStd	6.68	4.28	4.11	3.66	3.78	3.64	3.35	3.43	3.07	3.00	3.57	3.62	4.15	(7)
(8)		HDD10.0	876	214	173	114	46	8	0	0	0	1	27	103	191	(8)
(9)		HDD18.3	2882	471	404	363	249	147	69	34	35	104	216	341	447	(9)
(10)		CDD10.0	1166	1	2	10	47	126	203	276	262	155	69	12	3	(10)
(11)		CDD18.3	131	0	0	0	1	6	23	52	39	9	1	0	0	(11)
(12)		CDH23.3	1101	0	0	0	10	62	201	436	330	60	3	0	0	(12)
(13)		CDH26.7	320	0	0	0	1	11	53	138	108	11	0	0	0	(13)
(14)	Wind	WSAvg	4.0	4.8	4.7	4.4	3.9	3.7	3.6	3.4	3.3	3.5	4.0	4.2	4.7	(14)
(15)	Precipitation	PrecAvg	773	60	54	58	52	62	72	72	62	63	71	73	(15)	
(16)		PrecMax	1127	110	139	124	121	170	152	182	187	147	148	113	158	(16)
(17)		PrecMin	563	4	6	7	5	16	8	13	13	11	8	20	14	(17)
(18)		PrecStd	134	27	32	28	26	31	36	39	38	35	35	25	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	14.8	19.3	24.8	28.1	31.5	33.6	32.7	28.1	23.1	17.2	13.6	(19)
(20)			MCWB	10.9	9.5	12.3	15.2	18.4	20.6	21.0	21.1	19.0	17.4	13.7	11.1	(20)
(21)		2%	DB	11.5	12.2	16.2	21.7	24.9	28.0	30.3	29.6	25.0	20.0	14.8	12.2	(21)
(22)			MCWB	9.9	9.1	10.8	13.9	16.7	19.6	20.4	20.1	18.2	15.8	12.3	10.6	(22)
(23)		5%	DB	10.0	10.7	14.0	19.1	22.8	25.6	27.7	27.1	22.5	18.1	13.4	11.1	(23)
(24)			MCWB	8.5	8.6	10.0	12.8	15.7	18.3	19.4	19.5	17.0	14.9	11.5	9.6	(24)
(25)		10%	DB	8.8	9.5	12.1	16.6	20.6	23.3	25.6	24.5	20.2	16.5	12.1	9.7	(25)
(26)			MCWB	7.4	7.9	9.1	11.6	14.9	17.4	18.6	18.1	15.9	14.0	10.4	8.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	10.7	13.1	16.2	19.9	22.1	22.5	22.4	20.2	17.7	14.1	12.0	(27)
(28)			MCDWB	12.4	12.9	17.5	22.5	25.9	28.8	30.3	29.7	26.3	21.7	16.1	13.0	(28)
(29)		2%	WB	10.0	9.7	11.7	14.6	18.0	20.2	21.1	20.9	18.7	16.3	12.7	10.7	(29)
(30)			MCDWB	11.2	11.4	15.0	20.1	23.2	26.3	27.9	27.6	23.3	19.3	14.5	12.0	(30)
(31)		5%	WB	8.7	8.9	10.5	13.3	16.6	19.1	20.2	19.8	17.6	15.2	11.7	9.8	(31)
(32)			MCDWB	10.0	10.4	13.2	17.9	21.2	24.2	26.2	25.5	21.5	17.6	13.3	11.0	(32)
(33)		10%	WB	7.5	7.9	9.5	12.1	15.3	17.9	19.2	18.8	16.5	14.2	10.6	8.5	(33)
(34)			MCDWB	8.7	9.5	11.8	16.1	19.6	22.4	24.2	23.5	19.7	16.2	11.9	9.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	7.2	8.9	9.0	9.2	9.1	9.0	8.1	6.9	5.1	4.3	(35)
(36)			MCDBR	5.3	7.1	10.5	12.5	12.4	12.9	12.9	13.2	11.2	8.8	6.2	5.0	(36)
(37)			MCWBR	4.6	5.0	6.3	6.8	6.3	6.3	5.4	5.7	5.7	5.5	4.6	4.2	(37)
(38)		5% WB	MCDWB	5.2	6.1	8.7	11.1	10.9	11.4	11.3	11.4	9.8	8.2	5.7	4.7	(38)
(39)			MCWBR	4.7	4.7	5.7	6.4	6.0	6.1	5.2	5.5	5.4	4.6	4.6	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.343	0.375	0.407	0.415	0.415	0.419	0.410	0.382	0.359	0.334	0.317	(40)	
(41)		taud	2.418	2.376	2.296	2.230	2.249	2.264	2.252	2.300	2.368	2.427	2.418	2.387	(41)	
(42)		Ebn at Noon	705	782	818	831	842	843	832	819	804	753	677	642	(42)	
(43)		Edh at Noon	61	82	106	127	130	129	129	117	98	77	61	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.76	1.44	2.59	4.13	4.92	5.35	5.07	4.32	3.23	1.90	0.90	0.59	(44)	
(45)		RadStd	0.11	0.28	0.38	0.47	0.46	0.47	0.61	0.43	0.34	0.16	0.10	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (83 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page