

OOSTENDE-BRUGES INTL, Belgium

WMO: 064070

Lat: 51.2003N

Lon: 2.8872E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	26.1	16.8	12.8	24.7	20.6	15.5	27.6	36.7	47.2	33.1	47.2	7.7	60	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.9	79.1	66.4	75.0	65.3	72.0	63.9	68.4	76.5	66.6	73.3	64.9	70.7	9.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.4	94.0	72.5	63.8	88.5	70.6	62.2	83.8	68.8	32.7	76.8	31.2	73.4	29.9	70.9	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.8	25.2	22.4	18.0	89.3	5.3	3.4	14.2	91.8	11.1	93.7	8.2	95.6	4.4	98.1		
			17.1	72.7	5.1	1.7	13.4	73.9	10.4	74.9	7.5	75.9	3.7	77.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.9	39.5	40.1	43.7	48.3	54.1	59.2	62.9	63.2	59.2	53.1	46.1	40.7
	DBStd	10.13	6.83	6.20	5.34	5.44	5.29	4.68	4.40	4.16	4.16	5.43	5.50	6.66
	HDD50	1384	329	278	202	95	17	0	0	0	0	31	140	292
	HDD65	5223	792	696	659	500	339	186	95	85	181	369	568	753
	CDD50	1715	2	2	8	44	145	276	400	410	275	128	21	4
	CDD65	82	0	0	0	0	3	12	30	31	6	0	0	0
	CDH74	479	0	0	0	2	27	84	164	167	33	2	0	0
	CDH80	114	0	0	0	0	3	22	38	45	6	0	0	0
Wind	WSAvg	10.8	12.5	12.0	11.8	10.5	10.6	10.1	9.6	9.4	9.9	10.5	11.1	12.0
Precipitation	PrecAvg	30.6	2.4	2.2	1.8	1.7	2.2	2.6	2.8	2.9	2.6	3.0	3.4	3.0
	PrecMax	37.9	4.7	3.8	3.7	3.1	5.6	5.8	6.3	6.2	6.6	5.9	6.9	7.2
	PrecMin	22.4	0.1	0.6	0.4	0.2	0.5	0.9	0.6	0.3	0.2	0.7	0.4	0.6
	PrecStd	4.2	1.1	1.0	0.9	0.8	1.1	1.2	1.3	1.8	1.7	1.3	1.4	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	56.0	62.8	71.7	77.7	83.6	84.9	86.0	78.5	71.1	61.0	56.1
		MCWB	51.6	49.9	52.8	57.5	62.3	67.3	68.6	69.8	66.1	62.7	57.3	53.1
	2%	DB	52.5	52.8	57.0	65.3	70.8	75.0	78.3	78.3	72.2	65.6	57.9	54.0
		MCWB	49.9	48.9	50.9	55.1	59.6	65.0	67.1	66.5	63.5	60.2	55.1	51.5
	5%	DB	50.3	50.7	53.8	60.5	66.0	70.3	74.0	73.8	69.1	62.9	56.0	52.1
		MCWB	47.8	47.5	49.1	53.1	58.1	62.5	65.4	65.8	62.3	58.7	53.2	49.7
	10%	DB	48.3	48.8	51.5	56.6	62.6	67.0	70.9	71.0	66.5	60.8	54.0	49.8
		MCWB	46.0	45.9	47.8	51.4	56.5	60.6	63.9	64.1	60.7	57.1	51.1	47.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	51.5	54.6	58.6	65.4	69.2	70.9	71.4	67.4	63.6	57.9	53.8
		MCDB	54.1	54.7	60.3	68.0	73.6	80.1	80.7	81.4	75.1	69.1	59.9	55.7
	2%	WB	50.2	49.6	51.8	56.0	61.0	65.7	68.2	68.6	65.2	61.1	55.5	51.9
		MCDB	52.3	52.2	56.0	63.5	68.3	73.6	76.5	75.7	70.8	64.8	57.8	53.9
	5%	WB	48.1	47.9	49.9	53.8	58.8	63.2	66.2	66.7	63.2	59.3	53.6	50.0
		MCDB	49.9	50.4	53.2	59.3	65.0	69.1	72.6	72.8	67.8	62.4	55.7	52.0
	10%	WB	46.2	46.2	48.2	51.8	57.0	61.3	64.6	64.8	61.6	57.7	51.5	47.7
		MCDB	48.1	48.6	51.1	56.2	62.2	66.5	70.3	70.0	65.9	60.6	53.6	49.6
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.6	10.9	13.0	12.7	12.9	13.1	13.9	13.2	11.6	9.2	8.2
		MCDBR	9.0	11.6	15.4	19.6	19.5	19.7	19.5	19.7	18.2	13.6	10.0	8.5
		MCWBR	8.2	9.1	10.6	11.9	11.2	11.7	10.6	10.9	10.8	9.6	8.5	8.0
	5% WB	MCDBR	8.7	10.1	13.6	17.0	17.2	17.9	16.8	17.1	15.5	12.6	9.7	8.6
		MCWBR	8.3	8.5	9.9	10.8	10.5	11.2	10.1	10.2	9.9	9.6	8.7	8.2
Clear-Sky Solar Irradiance	taub	0.334	0.353	0.391	0.414	0.424	0.421	0.422	0.414	0.392	0.371	0.346	0.329	
	taud	2.368	2.352	2.251	2.220	2.245	2.274	2.279	2.320	2.368	2.402	2.379	2.346	
	Ebn at Noon	214	242	253	261	264	266	263	259	251	233	207	194	
	Edh at Noon	20	27	35	41	41	41	40	36	31	25	20	18	
All-Sky Solar Radiation	RadAvg	245	467	856	1395	1632	1768	1672	1427	1055	604	285	187	
	RadStd	21	85	108	128	122	141	169	120	71	52	29	23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (70 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page