

BEITEM, Belgium

WMO: 064140

Lat: 50.9039N

Lon: 3.1217E

Elev: 25

StdP: 101.03

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-2.7	-7.7	2.0	-3.0	-5.7	2.3	-1.3	12.4	9.4	11.3	9.3	2.8	60	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	28.9	19.4	26.6	18.3	24.9	17.3	20.6	27.0	19.5	24.9	18.5	23.0	3.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	22.9	17.5	12.6	21.8	16.6	11.9	20.8	59.4	27.2	55.7	24.9	52.4	23.0	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.9	8.5	7.5	-7.1	34.0	2.9	2.8	-9.2	36.0	-10.9	37.7	-12.5	39.2	-14.6	41.3		
			-7.3	23.0	2.8	1.8	-9.3	24.2	-10.9	25.3	-12.4	26.3	-14.4	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	3.8	4.4	7.0	10.3	13.5	16.5	18.4	17.9	15.2	11.9	7.8	4.9	(6)
		DBStd	6.05	3.62	3.29	3.17	3.38	3.45	2.90	2.82	2.45	2.58	3.22	3.33	3.85	
		HDD10.0	755	194	158	101	36	6	0	0	0	18	81	162		
		HDD18.3	2765	451	390	351	243	155	72	33	37	100	200	316	417	
		CDD10.0	1118	1	1	8	44	115	194	262	245	155	76	15	3	
		CDD18.3	86	0	0	0	0	5	16	36	24	5	1	0	0	
		CDH23.3	782	0	0	0	10	54	133	317	213	49	5	0	0	
		CDH26.7	202	0	0	0	0	4	31	94	63	9	0	0	0	
(14)	Wind	WSAvg	3.7	4.2	4.2	4.2	3.6	3.7	3.6	3.3	3.1	3.1	3.3	3.8	4.2	(14)
(15)	Precipitation	PrecAvg	812	68	55	48	53	53	72	68	66	77	75	88	88	(15)
		PrecMax	974	138	131	108	112	92	146	132	141	179	138	152	195	
		PrecMin	646	5	16	7	4	17	27	17	5	7	21	31	29	
		PrecStd	115	35	30	26	26	25	34	35	40	45	30	36	45	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	12.7	14.3	18.6	24.7	27.0	30.4	33.3	31.6	27.9	23.3	16.9	13.6		(19)
		0.4% MCWB	11.1	10.0	12.8	14.7	19.0	21.4	21.4	19.6	17.4	17.4	14.5	11.8		
		2% DB	11.3	11.5	16.0	22.1	24.9	26.6	28.9	28.2	24.4	20.1	15.2	12.5		
		2% MCWB	9.8	9.6	12.8	14.4	16.0	18.8	19.5	18.9	16.9	16.6	13.2	11.1		
		5% DB	10.1	10.5	13.7	18.8	22.4	24.5	26.7	25.5	21.8	17.9	14.0	11.5		
		5% MCWB	8.6	9.0	10.6	13.2	15.3	17.9	18.5	17.7	16.2	15.2	12.2	10.2		
		10% DB	8.9	9.4	11.9	16.2	19.8	22.2	24.5	23.3	19.9	16.5	12.6	10.2		
		10% MCWB	7.6	8.0	9.4	11.9	14.6	16.6	17.5	16.8	15.2	14.1	11.0	9.0		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	11.5	11.5	16.0	16.9	20.7	22.1	21.9	21.7	20.1	18.2	15.3	12.4		(27)
		0.4% MCDB	12.5	13.0	16.0	22.3	25.2	29.2	30.1	28.3	25.3	22.0	16.6	13.1		
		2% WB	10.0	10.2	12.4	14.7	18.2	19.8	20.6	19.9	18.3	16.8	13.5	11.3		
		2% MCDB	11.2	11.2	14.9	20.0	21.6	25.3	27.6	25.9	21.7	19.9	14.9	12.3		
		5% WB	8.8	9.2	11.1	13.4	16.2	18.4	19.4	18.8	17.2	15.5	12.4	10.4		
		5% MCDB	9.9	10.4	13.3	18.3	20.4	23.2	25.1	23.6	20.4	17.7	13.9	11.5		
		10% WB	7.6	8.0	9.8	12.2	15.0	17.2	18.4	17.8	16.2	14.5	11.1	9.1		
		10% MCDB	8.8	9.4	11.8	15.9	19.5	21.6	22.9	21.8	19.0	16.2	12.5	10.2		
(35)	Mean Daily Temperature Range	MDBR	4.6	5.5	7.2	9.1	9.0	8.7	9.4	9.7	8.9	6.8	5.0	4.5		(35)
		5% DB MCDBR	5.1	6.9	11.0	13.3	12.7	12.5	13.4	14.3	11.9	8.6	5.7	4.8		
		5% WB MCWBR	4.9	5.5	7.8	7.3	6.2	6.2	6.0	6.5	6.6	5.8	4.9	4.4		
		5% WB MCDBR	5.2	6.7	9.8	11.9	10.6	11.1	11.8	11.5	10.1	8.4	5.7	4.8		
(40)	Clear-Sky Solar Irradiance	taub	0.333	0.354	0.392	0.418	0.428	0.425	0.426	0.417	0.393	0.370	0.345	0.328		(40)
		taud	2.359	2.332	2.223	2.177	2.196	2.227	2.231	2.276	2.331	2.381	2.367	2.336		
		Ebn at Noon	680	765	797	819	828	833	825	813	791	736	656	617		
		Edh at Noon	65	86	114	133	137	134	131	120	102	81	64	58		
(44)	All-Sky Solar Radiation	RadAvg	0.79	1.49	2.70	4.35	5.07	5.53	5.24	4.46	3.34	1.94	0.93	0.62		(44)
		RadStd	0.07	0.28	0.35	0.43	0.41	0.47	0.53	0.40	0.24	0.17	0.10	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (69 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page