

GENT INDUSTRIE-ZONE, Belgium

WMO: 064310

Lat: 51.1806N

Lon: 3.8042E

Elev: 8

StdP: 101.23

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.1	-3.1	-8.7	1.8	-3.3	-6.4	2.2	-1.6	12.3	9.3	10.8	9.1	2.6	50	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	29.3	20.3	27.2	19.2	25.3	18.6	21.3	27.4	20.2	25.3	19.3	23.9	2.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.0	23.8	18.3	13.2	22.8	17.5	12.6	21.7	61.9	27.5	58.1	25.2	55.0	23.8	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.8	6.8	-7.0	33.2	3.2	1.4	-9.3	34.2	-11.1	35.1	-12.9	35.9	-15.3	36.9		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-7.4	23.4	3.1	1.1	-9.7	24.2	-11.5	24.9	-13.2	25.5	-15.5	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	4.4	5.1	7.6	10.8	14.3	16.9	19.1	18.9	16.1	12.4	8.4	5.3
	DBStd	6.23	3.95	3.81	3.39	3.59	3.62	3.09	2.97	2.64	2.66	3.27	3.54	3.97
	HDD10.0	673	176	141	88	31	4	0	0	0	0	14	69	150
	HDD18.3	2574	432	371	333	226	135	64	25	23	78	185	298	403
	CDD10.0	1274	2	3	13	56	137	207	283	276	183	89	21	5
	CDD18.3	134	0	0	0	1	10	21	50	41	11	2	0	0
	CDH23.3	892	0	0	0	9	84	159	322	259	54	4	0	0
	CDH26.7	227	0	0	0	1	14	43	88	73	9	0	0	0
Wind	WSAvg	3.3	3.8	3.8	3.6	3.2	3.0	3.0	2.9	2.8	2.7	3.0	3.5	3.7
Precipitation	PrecAvg	816	68	61	48	42	58	68	79	89	69	71	81	81
	PrecMax	968	139	124	127	90	104	126	160	261	205	140	146	180
	PrecMin	611	4	14	3	0	20	21	19	26	13	22	4	18
	PrecStd	95	34	27	27	25	24	30	38	57	44	26	33	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.0	19.0	24.7	28.4	31.0	32.3	31.6	27.7	23.4	17.6	14.2
		MCWB	11.2	10.0	12.5	15.2	19.0	20.6	21.0	22.0	19.6	18.1	14.6	12.2
	2%	DB	12.0	12.4	16.1	21.7	25.7	27.3	29.4	28.7	24.5	20.3	15.6	13.0
		MCWB	10.4	9.6	11.2	14.1	17.1	19.0	20.2	20.7	18.5	16.5	13.5	11.4
	5%	DB	10.8	11.2	14.1	18.9	23.0	24.8	27.1	26.2	22.2	18.2	14.3	11.9
		MCWB	9.2	9.1	10.2	12.7	16.1	18.2	19.4	19.5	17.5	15.4	12.4	10.4
	10%	DB	9.7	10.2	12.5	16.5	20.5	22.5	24.9	24.0	20.4	16.9	13.1	10.6
		MCWB	8.2	8.5	9.6	11.6	14.9	17.0	18.8	18.4	16.4	14.6	11.5	9.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.2	13.3	16.4	20.5	21.8	22.6	23.1	20.8	18.5	15.5	12.7
		MCDB	12.6	13.0	17.3	23.2	26.3	29.1	30.0	29.7	26.4	22.5	16.9	13.7
	2%	WB	10.6	10.2	11.8	14.6	18.2	19.9	21.3	21.3	19.1	16.9	13.7	11.6
		MCDB	11.8	11.6	14.8	19.9	23.5	25.4	27.2	27.1	23.0	19.6	15.3	12.8
	5%	WB	9.4	9.5	10.8	13.3	16.8	18.6	20.2	20.1	18.1	15.8	12.7	10.5
		MCDB	10.7	10.9	13.3	17.7	21.4	23.5	25.4	24.6	21.4	17.9	14.1	11.8
	10%	WB	8.4	8.6	9.9	12.2	15.5	17.5	19.2	19.0	17.1	14.9	11.6	9.3
		MCDB	9.6	10.1	12.2	15.7	19.6	21.7	23.8	23.0	19.8	16.6	12.9	10.5
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.6	6.1	7.7	7.8	7.9	7.6	7.9	6.9	5.9	4.3	3.7
		MCDBR	4.5	5.3	8.8	11.7	12.3	12.2	11.6	12.0	9.9	7.7	5.1	4.2
		MCWBR	4.1	4.0	5.3	5.4	5.5	5.7	4.8	5.5	4.7	4.6	3.9	3.7
	5% WB	MCDBR	4.4	4.8	7.5	10.1	10.4	10.5	10.0	10.7	8.6	7.0	4.9	4.2
		MCWBR	4.2	4.1	5.0	5.2	5.4	5.5	4.9	5.6	4.6	4.5	4.0	4.0
Clear-Sky Solar Irradiance	taub	0.334	0.354	0.390	0.417	0.426	0.423	0.426	0.417	0.393	0.370	0.346	0.330	
	taud	2.370	2.342	2.243	2.201	2.220	2.250	2.247	2.292	2.348	2.398	2.378	2.340	
	Ebn at Noon	674	762	797	820	830	835	824	812	789	734	650	610	
	Edh at Noon	64	85	111	130	133	131	129	118	100	79	63	57	
All-Sky Solar Radiation	RadAvg	0.77	1.46	2.67	4.32	5.09	5.52	5.21	4.45	3.29	1.90	0.90	0.59	
	RadStd	0.08	0.27	0.35	0.42	0.40	0.45	0.56	0.39	0.25	0.16	0.09	0.07	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (77 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page