

UCCLE, Belgium

WMO: 064470

Lat: 50.7969N

Lon: 4.3581E

Elev: 331

StdP: 14.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	25.0	13.2	10.9	26.4	17.9	13.7	28.8	25.4	48.6	23.1	47.8	6.7	50	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	84.8	67.3	81.1	65.9	77.6	64.1	69.3	80.4	67.4	77.7	65.8	74.8	6.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	95.5	73.8	63.7	89.4	71.6	62.2	84.7	70.0	33.6	80.3	32.0	78.0	30.7	75.1	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.1	17.4	15.3	DB	17.5	91.3	5.1	3.0	13.8	93.5	10.8	95.2	7.9	96.9	4.1	99.0	
			WB	16.9	73.4	4.8	2.6	13.5	75.3	10.6	76.8	7.9	78.3	4.4	80.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.9	38.8	40.1	44.9	50.8	57.0	62.1	65.8	65.3	59.5	53.1	45.1	39.4
	DBStd	11.58	7.43	6.91	6.43	6.88	6.67	5.95	5.83	5.48	4.95	6.27	6.12	7.08
	HDD50	1432	351	280	180	71	12	0	0	0	1	39	166	332
	HDD65	5012	814	698	622	427	263	127	61	62	179	370	596	793
	CDD50	2117	2	2	23	95	228	362	489	473	284	135	20	4
	CDD65	224	0	0	0	2	14	39	85	69	13	2	0	0
	CDH74	1614	0	0	0	22	107	294	602	517	67	5	0	0
	CDH80	408	0	0	0	1	14	66	160	156	11	0	0	0
Wind	WSAvg	7.6	8.7	8.9	8.4	7.6	7.0	6.8	6.4	6.2	6.4	7.8	8.0	8.7
Precipitation	PrecAvg	32.6	2.8	2.3	2.6	2.0	2.6	3.0	3.1	3.0	2.4	2.8	3.1	3.3
	PrecMax	42.3	6.1	6.6	5.6	5.3	5.7	6.9	7.0	9.1	7.8	6.4	6.9	6.8
	PrecMin	21.3	0.1	0.4	0.2	0.0	0.6	0.5	0.7	0.4	0.3	0.2	0.4	0.6
	PrecStd	4.6	1.3	1.2	1.3	1.1	1.3	1.5	1.6	1.9	1.6	1.4	1.2	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	58.6	67.0	77.0	82.1	87.1	89.6	90.0	81.3	73.5	62.6	55.7
		MCWB	51.2	47.0	52.6	57.4	64.5	68.8	68.5	69.6	65.2	62.8	55.3	52.2
	2%	DB	52.9	53.6	61.7	71.4	76.8	81.2	84.6	84.3	74.9	68.1	58.2	53.7
		MCWB	50.0	47.9	51.0	55.7	61.0	65.7	67.0	68.0	62.9	60.4	53.9	51.2
	5%	DB	50.3	51.1	57.4	66.2	72.9	77.2	80.9	80.0	70.9	64.3	55.7	51.6
		MCWB	47.5	47.1	49.5	54.3	59.7	63.9	65.7	66.5	61.4	58.4	52.2	49.1
	10%	DB	48.3	49.2	54.2	61.7	68.7	73.2	77.1	75.5	67.7	61.6	53.3	49.3
		MCWB	45.7	45.8	48.2	51.9	57.9	62.1	64.4	64.4	59.8	57.0	50.4	47.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	50.9	54.8	60.0	66.9	71.2	71.7	72.8	66.9	63.6	56.6	53.6
		MCDB	54.2	53.7	62.0	73.2	77.9	83.3	84.5	85.4	76.2	71.3	60.1	54.7
	2%	WB	50.2	49.2	52.5	57.1	63.7	67.3	68.9	69.5	64.9	61.1	54.5	51.5
		MCDB	52.4	51.8	58.5	66.8	73.8	77.9	80.3	80.5	72.0	66.5	57.4	53.3
	5%	WB	47.9	47.7	50.8	54.9	61.2	65.2	67.2	67.4	63.0	59.3	52.8	49.3
		MCDB	50.0	50.6	55.8	64.0	69.5	74.6	77.6	77.2	68.8	63.5	55.5	51.2
	10%	WB	45.9	46.0	49.1	53.0	59.0	63.3	65.6	65.4	61.3	57.6	50.5	47.3
		MCDB	48.1	48.9	53.5	60.7	66.8	71.2	74.8	73.3	66.5	61.1	52.8	49.1
Mean Daily Temperature Range	5% DB	MDBR	7.4	9.0	11.8	14.4	14.8	14.7	14.3	14.7	13.2	11.1	8.1	7.1
		MCDBR	8.3	12.0	17.6	20.7	20.7	20.9	20.4	21.8	18.1	14.1	10.1	8.6
		MCWBR	7.4	8.3	9.6	9.9	9.3	9.6	8.2	9.8	8.9	8.0	7.4	7.6
	5% WB	MCDBR	8.1	10.0	13.6	17.9	17.7	18.4	17.3	18.6	15.5	12.8	9.1	7.9
	MCWBR	7.8	8.1	8.7	9.3	9.2	9.8	8.5	10.3	8.8	8.0	7.4	7.5	
Clear-Sky Solar Irradiance	taub	0.324	0.345	0.378	0.415	0.425	0.422	0.426	0.416	0.388	0.360	0.336	0.321	
	taud	2.405	2.374	2.280	2.189	2.205	2.234	2.227	2.274	2.340	2.421	2.409	2.375	
	Ebn at Noon	222	247	259	261	264	265	262	258	252	239	214	202	
	Edh at Noon	20	26	34	42	43	42	42	38	32	25	20	18	
All-Sky Solar Radiation	RadAvg	246	461	830	1321	1569	1708	1617	1378	1036	610	290	193	
	RadStd	33	90	116	148	148	150	189	138	102	51	33	28	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page