

BRUSSELS AP, Belgium

WMO: 064510

Lat: 50.8964N

Lon: 4.5272E

Elev: 56

StdP: 100.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-4.1	-9.5	1.7	-4.7	-7.2	2.1	-3.2	14.1	9.6	12.5	9.4	2.5	60	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	29.4	20.3	27.2	19.3	25.3	18.4	21.1	27.6	20.1	25.9	19.1	24.0	3.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.7	23.7	17.9	12.9	22.6	17.0	12.2	21.6	61.1	27.8	57.6	26.0	54.3	24.1	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.4	8.2	DB	-8.5	33.0	2.9	1.4	-10.6	34.1	-12.3	34.9	-13.9	35.7	-16.1	36.8	(4)
(5)			WB	-8.9	23.3	2.9	1.3	-11.0	24.3	-12.7	25.1	-14.3	25.8	-16.4	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	3.7	4.4	6.9	10.0	13.5	16.4	18.5	15.2	11.6	7.4	4.4	(6)	
(7)		DBStd	6.33	4.18	3.96	3.47	3.63	3.48	3.17	3.04	2.86	2.79	3.47	3.45	4.09	(7)
(8)		HDD10.0	803	196	159	106	44	7	0	0	0	23	91	178	(8)	
(9)		HDD18.3	2820	453	391	354	249	154	77	35	36	101	209	328	433	(9)
(10)		CDD10.0	1132	1	2	10	45	116	191	265	257	157	73	13	3	(10)
(11)		CDD18.3	107	0	0	0	1	5	17	42	34	7	1	0	0	(11)
(12)		CDH23.3	902	0	0	0	8	49	158	346	292	48	2	0	0	(12)
(13)		CDH26.7	239	0	0	0	0	7	36	97	90	8	0	0	0	(13)
(14)	Wind	WSAvg	3.7	4.6	4.4	4.2	3.6	3.4	3.3	3.2	3.1	3.2	3.6	3.9	4.5	(14)
(15)	Precipitation	PrecAvg	779	69	64	54	47	58	69	72	81	60	62	69	73	(15)
(16)		PrecMax	1017	132	139	118	104	105	140	138	206	181	139	139	177	(16)
(17)		PrecMin	616	3	13	3	0	17	25	25	12	9	15	32	17	(17)
(18)		PrecStd	115	35	31	30	23	24	28	31	53	43	27	25	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	14.8	18.7	24.5	27.4	30.7	32.1	32.1	27.8	22.7	17.1	13.7	(19)
(20)			MCWB	11.0	9.8	11.8	15.4	18.9	21.3	21.1	21.4	19.1	17.1	13.8	11.7	(20)
(21)		2%	DB	11.7	12.4	16.1	21.3	24.5	27.2	29.4	29.2	24.4	19.8	14.8	12.5	(21)
(22)			MCWB	10.0	9.4	10.9	13.9	16.9	19.4	20.2	20.3	17.9	15.8	12.4	10.8	(22)
(23)		5%	DB	10.4	11.0	13.8	18.7	22.4	25.0	27.1	26.7	22.0	17.9	13.5	11.3	(23)
(24)			MCWB	8.8	8.9	10.2	12.7	15.8	18.3	19.3	19.2	16.9	14.8	11.6	9.8	(24)
(25)		10%	DB	9.1	9.8	12.1	16.2	20.0	22.7	25.0	24.1	20.1	16.4	12.3	10.0	(25)
(26)			MCWB	7.7	8.0	9.2	11.5	14.6	17.1	18.5	18.2	15.8	13.9	10.6	8.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	11.0	12.9	16.1	19.9	22.3	22.3	22.5	20.0	17.6	14.3	12.1	(27)
(28)			MCD B	12.6	13.2	16.6	22.6	26.3	28.9	29.3	29.8	25.8	21.5	16.1	13.2	(28)
(29)		2%	WB	10.2	10.0	11.7	14.4	18.0	20.2	21.0	21.0	18.7	16.2	12.8	11.0	(29)
(30)			MCD B	11.5	11.7	14.9	19.7	22.9	25.9	27.8	27.5	23.2	19.1	14.5	12.3	(30)
(31)		5%	WB	8.9	9.1	10.6	13.1	16.5	18.8	20.0	19.8	17.5	15.2	11.8	9.9	(31)
(32)			MCD B	10.2	10.7	13.2	17.8	20.8	23.8	25.7	25.4	21.0	17.4	13.4	11.2	(32)
(33)		10%	WB	7.8	8.0	9.6	12.0	15.2	17.6	19.0	18.7	16.5	14.2	10.6	8.7	(33)
(34)			MCD B	9.1	9.6	11.9	15.9	19.3	21.9	23.7	23.1	19.5	16.2	12.1	9.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	6.9	8.6	8.9	9.2	9.1	8.1	6.7	4.9	4.2	(35)	
(36)			MCDBR	5.1	6.6	10.2	12.5	12.6	13.1	13.1	13.4	11.0	8.3	5.9	4.7	(36)
(37)			MCWBR	4.4	4.8	6.2	6.6	6.4	6.7	5.7	6.0	5.6	5.1	4.5	4.2	(37)
(38)		5% WB	MCD BR	5.0	5.4	8.3	10.9	11.0	11.6	11.4	11.9	9.7	7.5	5.5	4.6	(38)
(39)			MCWBR	4.6	4.3	5.5	6.1	6.1	6.4	5.5	5.8	5.3	4.9	4.5	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.350	0.383	0.419	0.428	0.425	0.429	0.420	0.392	0.364	0.340	0.325	(40)	
(41)		taud	2.392	2.358	2.264	2.184	2.202	2.231	2.223	2.270	2.336	2.408	2.396	2.360	(41)	
(42)		Ebn at Noon	692	772	808	819	828	833	822	810	792	745	666	627	(42)	
(43)		Edh at Noon	63	84	109	132	136	133	133	120	101	79	63	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.77	1.44	2.60	4.14	4.94	5.37	5.08	4.33	3.25	1.91	0.91	0.60	(44)	
(45)		RadStd	0.10	0.28	0.37	0.47	0.46	0.47	0.61	0.43	0.33	0.16	0.10	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (82 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page