

FLORENNES AB, Belgium

WMO: 064560

Lat: 50.2344N

Lon: 4.6531E

Elev: 935

StdP: 14.21

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	22.8	12.6	10.8	24.6	16.8	13.3	25.7	28.9	44.7	26.1	45.3	5.9	70	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	83.6	66.7	79.8	65.3	76.1	63.8	68.4	79.4	66.7	76.6	65.1	73.9	7.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	94.7	72.3	63.1	89.4	70.4	61.7	85.2	68.9	33.2	79.4	31.8	76.7	30.5	74.0	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.5	19.8	17.6	DB	14.2	90.2	5.2	3.1	10.5	92.4	7.4	94.2	4.5	95.9	0.7	98.2	(4)
(5)			WB	13.4	71.8	5.0	2.0	9.8	73.2	6.9	74.3	4.1	75.4	0.4	76.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	36.3	37.7	42.7	48.4	54.6	59.9	63.9	63.3	57.6	51.2	43.2	37.8
	DBStd	11.69	7.24	7.15	6.55	6.91	6.41	6.11	6.08	5.57	5.24	6.37	6.40	7.00
	HDD50	1811	424	347	239	111	26	1	0	0	2	63	218	380
	HDD65	5708	888	766	691	500	329	177	97	100	232	429	655	844
	CDD50	1732	1	1	13	62	167	299	432	414	229	99	13	2
	CDD65	154	0	0	0	1	6	25	64	49	9	0	0	0
	CDH74	1236	0	0	0	5	51	220	491	411	57	1	0	0
	CDH80	300	0	0	0	0	7	51	126	111	5	0	0	0
Wind	WSAvg	8.1	9.9	9.6	9.2	7.7	7.3	7.0	6.7	6.4	6.9	8.0	8.5	9.7
Precipitation	PrecAvg	35.6	3.0	2.5	3.0	2.6	3.0	3.3	3.0	2.8	2.6	3.0	3.5	3.3
	PrecMax	46.3	6.5	6.3	6.7	5.7	5.6	6.6	7.9	5.5	5.8	6.9	5.2	8.8
	PrecMin	23.3	1.0	0.4	0.5	0.9	0.3	0.4	0.8	0.6	0.5	0.2	0.9	0.7
	PrecStd	6.1	1.4	1.4	1.4	1.2	1.3	1.7	1.7	1.1	1.3	1.8	1.1	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	57.1	64.7	74.2	80.1	86.2	88.4	88.8	80.2	71.2	61.0	54.0
		MCWB	50.5	46.0	51.3	56.7	63.8	67.5	67.7	68.3	64.3	61.2	55.4	51.3
	2%	DB	50.5	52.2	60.2	69.2	74.3	79.9	83.5	83.2	74.6	66.4	56.7	52.0
		MCWB	48.4	46.4	49.7	54.9	60.0	65.5	67.0	66.8	63.1	59.2	52.9	49.7
	5%	DB	48.1	49.3	55.8	64.2	70.5	75.5	79.5	78.7	70.1	62.6	54.2	49.8
		MCWB	46.3	45.9	48.2	53.0	58.7	63.6	65.4	65.2	61.1	57.6	51.5	48.0
	10%	DB	45.9	47.2	52.3	59.8	66.3	71.5	75.6	74.3	66.3	59.9	52.0	47.5
		MCWB	44.2	44.7	47.2	50.9	57.1	61.7	64.0	63.6	59.2	56.1	49.8	45.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.6	49.8	53.6	59.1	66.3	70.3	71.0	71.0	66.6	62.8	56.4	52.4
		MCDB	52.4	52.6	60.1	70.8	75.8	81.1	83.3	83.9	75.3	68.7	58.9	53.6
	2%	WB	48.6	48.0	51.5	56.2	62.5	66.7	68.4	68.2	64.3	60.3	53.7	50.2
		MCDB	49.9	50.1	57.0	65.4	70.6	76.6	79.5	79.7	71.9	64.6	55.9	51.7
	5%	WB	46.4	46.5	49.6	53.9	59.9	64.7	66.7	66.4	62.2	58.4	51.8	48.2
		MCDB	47.8	48.8	54.5	62.1	67.8	73.4	76.8	75.9	68.4	61.9	54.0	49.7
	10%	WB	44.2	44.7	47.9	51.8	57.7	62.7	65.0	64.5	60.3	56.7	50.0	46.0
		MCDB	45.8	47.2	51.7	58.6	64.8	70.2	73.9	72.3	65.2	59.7	51.9	47.4
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.1	12.2	14.7	15.3	15.7	15.7	15.5	13.9	11.6	8.3	7.4
		MCDBR	9.0	12.3	18.4	21.0	21.9	22.1	21.8	22.8	19.9	14.9	10.4	8.0
		MCWBR	8.0	8.6	10.6	10.7	11.0	10.8	9.4	9.9	10.1	9.1	7.7	7.2
	5% WB	MCDBR	8.7	9.7	14.4	18.7	18.8	19.4	19.2	19.8	17.0	13.6	9.0	7.7
		MCWBR	8.2	7.9	9.4	10.3	10.4	10.4	9.0	9.9	9.1	8.8	7.3	7.2
Clear-Sky Solar Irradiance	taub	0.311	0.333	0.366	0.399	0.409	0.407	0.407	0.401	0.371	0.351	0.325	0.308	
	taud	2.430	2.391	2.307	2.231	2.239	2.264	2.262	2.306	2.373	2.429	2.430	2.400	
	Ebn at Noon	232	254	264	267	269	270	268	264	260	244	222	213	
	Edh at Noon	20	26	34	40	42	41	41	37	31	25	20	17	
All-Sky Solar Radiation	RadAvg	251	469	839	1321	1565	1716	1633	1391	1057	620	294	199	
	RadStd	38	90	118	157	164	158	185	152	112	53	35	33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page