

FLORENNES AB, Belgium

WMO: 064560

Lat: 50.2344N

Lon: 4.6531E

Elev: 285

StdP: 97.95

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-5.1	-10.8	1.5	-4.1	-8.4	1.9	-3.5	12.9	7.1	11.7	7.4	2.6	70	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	28.7	19.3	26.5	18.5	24.5	17.7	20.2	26.3	19.3	24.8	18.4	23.3	3.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.5	22.4	17.3	12.8	21.3	16.5	12.2	20.5	59.3	26.4	56.0	24.8	53.1	23.4	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.9	7.9	-9.9	32.3	2.9	1.7	-12.0	33.6	-13.7	34.6	-15.3	35.5	-17.4	36.8		
(5)			-10.3	22.1	2.8	1.1	-12.3	22.9	-14.0	23.5	-15.5	24.1	-17.6	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	2.4	3.1	5.9	9.1	12.5	15.5	17.7	17.4	14.2	10.6	6.2	3.2		
	DBStd	6.49	4.02	3.97	3.64	3.84	3.56	3.39	3.38	3.09	2.91	3.54	3.55	3.89		
	HDD10.0	1006	236	193	133	62	14	1	0	0	1	35	121	211		
	HDD18.3	3171	493	426	384	278	183	98	54	56	129	238	364	469		
	CDD10.0	962	1	1	7	34	93	166	240	230	127	55	7	1		
	CDD18.3	86	0	0	0	1	3	14	36	27	5	0	0	0		
	CDH23.3	687	0	0	0	3	28	122	273	228	32	1	0	0		
	CDH26.7	167	0	0	0	0	4	28	70	62	3	0	0	0		
(14) Wind	WSAvg	3.6	4.4	4.3	4.1	3.4	3.3	3.1	3.0	2.9	3.1	3.6	3.8	4.3		
(15) Precipitation	PrecAvg	904	77	63	77	65	77	83	75	71	66	76	90	84		
	PrecMax	1177	164	161	169	145	143	168	201	139	148	175	132	223		
	PrecMin	592	26	9	13	24	8	10	20	14	13	5	24	18		
	PrecStd	156	36	36	36	31	33	44	43	29	32	46	28	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	13.9	18.2	23.5	26.7	30.1	31.3	31.5	26.8	21.8	16.1	12.2		
		MCWB	10.3	7.8	10.7	13.7	17.6	19.7	19.8	20.2	17.9	16.2	13.0	10.7		
	2%	DB	10.3	11.2	15.7	20.7	23.5	26.6	28.6	28.4	23.7	19.1	13.7	11.1		
		MCWB	9.1	8.0	9.8	12.7	15.6	18.6	19.4	19.3	17.3	15.1	11.6	9.9		
	5%	DB	9.0	9.6	13.2	17.9	21.4	24.2	26.4	25.9	21.2	17.0	12.4	9.9		
		MCWB	7.9	7.7	9.0	11.7	14.9	17.5	18.6	18.5	16.2	14.2	10.8	8.9		
	10%	DB	7.7	8.5	11.3	15.4	19.0	21.9	24.2	23.5	19.1	15.5	11.1	8.6		
		MCWB	6.8	7.0	8.4	10.5	13.9	16.5	17.8	17.5	15.1	13.4	9.9	7.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	9.9	12.0	15.0	19.0	21.3	21.7	21.7	19.2	17.1	13.6	11.3		
		MCDB	11.3	11.5	15.6	21.5	24.3	27.3	28.5	28.8	24.1	20.4	15.0	12.0		
	2%	WB	9.2	8.9	10.8	13.5	16.9	19.3	20.2	20.1	17.9	15.7	12.1	10.1		
		MCDB	10.0	10.1	13.9	18.6	21.5	24.8	26.4	26.5	22.1	18.1	13.3	10.9		
	5%	WB	8.0	8.1	9.8	12.2	15.5	18.2	19.3	19.1	16.8	14.7	11.0	9.0		
		MCDB	8.8	9.4	12.5	16.7	19.9	23.0	24.9	24.4	20.2	16.6	12.2	9.8		
	10%	WB	6.8	7.1	8.8	11.0	14.3	17.1	18.3	18.1	15.7	13.7	10.0	7.8		
		MCDB	7.7	8.4	10.9	14.8	18.2	21.2	23.3	22.4	18.4	15.4	11.1	8.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	5.1	6.8	8.1	8.5	8.7	8.7	8.6	7.7	6.4	4.6	4.1		
		MCDBR	5.0	6.8	10.2	11.7	12.2	12.3	12.1	12.7	11.1	8.3	5.8	4.5		
	5% WB	MCWBR	4.5	4.8	5.9	5.9	6.1	6.0	5.2	5.5	5.6	5.1	4.3	4.0		
		MCWBR	4.8	5.4	8.0	10.4	10.4	10.8	10.7	11.0	9.5	7.6	5.0	4.3		
(40) Clear-Sky Solar Irradiance	taub		0.311	0.333	0.366	0.399	0.409	0.407	0.407	0.401	0.371	0.351	0.325	0.308		
		taud	2.430	2.391	2.307	2.231	2.239	2.264	2.262	2.306	2.373	2.429	2.430	2.400		
	Ebn at Noon		730	801	833	842	848	851	844	832	819	769	701	670		
		Edh at Noon	62	82	106	127	132	129	128	117	98	78	62	55		
(44) All-Sky Solar Radiation	RadAvg		0.79	1.48	2.64	4.17	4.93	5.41	5.15	4.39	3.33	1.95	0.93	0.63		
	RadStd		0.12	0.28	0.37	0.50	0.52	0.50	0.58	0.48	0.35	0.17	0.11	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page