

BEAUVECHAIN AB, Belgium

WMO: 064580

Lat: 50.7456N

Lon: 4.7633E

Elev: 113

StdP: 99.98

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.4	-4.3	-9.8	1.7	-4.9	-7.4	2.0	-3.1	14.1	9.2	12.6	8.8	3.0	60	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	29.4	19.7	27.2	19.0	25.4	18.1	20.8	27.1	19.7	25.4	18.9	24.1	3.1	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.7	23.1	17.7	12.9	22.0	16.9	12.2	21.2	60.3	27.2	56.8	25.6	53.9	24.2	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.5	8.3	DB	-8.7	33.2	3.1	1.6	-10.9	34.4	-12.8	35.3	-14.5	36.3	-16.8	37.5	(4)
(5)			WB	-9.1	23.1	3.1	1.6	-11.4	24.2	-13.2	25.1	-14.9	26.0	-17.2	27.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	3.4	4.1	6.9	10.2	13.7	16.5	18.6	18.3	15.2	11.6	7.2	4.1	(6)	
	DBStd	6.49	4.20	4.04	3.63	3.79	3.62	3.31	3.26	3.03	2.89	3.49	3.52	4.06	(7)	
	HDD10.0	834	206	166	108	43	8	0	0	0	0	23	97	184	(8)	
	HDD18.3	2851	463	397	355	246	152	76	38	37	103	208	335	441	(9)	
	CDD10.0	1144	1	2	11	48	121	194	266	258	156	73	12	3	(10)	
	CDD18.3	119	0	0	0	1	7	20	45	37	8	1	0	0	(11)	
	CDH23.3	915	0	0	0	9	49	164	344	298	48	2	0	0	(12)	
	CDH26.7	239	0	0	0	0	8	38	96	89	7	0	0	0	(13)	
(14) Wind	WSAvg	3.7	4.6	4.4	4.1	3.5	3.3	3.1	3.0	3.0	3.2	3.7	3.9	4.5	(14)	
(15) Precipitation	PrecAvg	774	68	59	54	48	60	70	74	82	56	61	65	76	(15)	
	PrecMax	1058	127	153	135	119	118	143	157	200	172	158	113	166	(16)	
	PrecMin	550	4	11	4	2	16	22	28	20	8	23	9	14	(17)	
	PrecStd	123	32	31	30	26	26	30	31	53	35	28	28	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.5	19.0	24.7	27.6	30.5	32.3	32.2	27.6	22.6	17.1	13.5	(19)	
		MCWB	10.8	9.3	11.5	14.9	18.2	20.3	20.6	20.4	18.6	16.8	13.7	11.3	(20)	
	2%	DB	11.4	12.1	16.2	21.4	24.5	27.3	29.3	29.1	24.5	19.8	14.6	12.2	(21)	
		MCWB	9.9	9.1	10.8	13.6	16.5	19.2	19.9	19.4	17.7	15.7	12.4	10.5	(22)	
	5%	DB	10.0	10.7	13.9	18.8	22.4	25.0	27.1	26.8	22.1	17.9	13.3	11.0	(23)	
		MCWB	8.5	8.6	10.0	12.5	15.7	18.0	19.0	18.9	16.7	14.6	11.5	9.6	(24)	
	10%	DB	8.8	9.5	12.1	16.4	20.0	22.8	25.0	24.2	20.0	16.4	12.0	9.6	(25)	
		MCWB	7.5	7.8	9.1	11.3	14.6	17.2	18.2	17.9	15.6	14.0	10.5	8.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	10.7	12.8	16.2	19.5	22.0	22.1	22.1	19.7	17.5	14.1	12.0	(27)	
		MCDB	12.3	12.6	16.8	22.8	25.2	28.3	29.2	29.5	25.3	21.4	16.1	13.0	(28)	
	2%	WB	10.0	9.7	11.5	14.3	17.7	20.0	20.7	20.5	18.6	16.2	12.8	10.8	(29)	
		MCDB	11.1	11.2	14.8	19.5	22.6	25.4	27.3	26.7	23.1	18.9	14.3	12.0	(30)	
	5%	WB	8.7	8.9	10.5	13.0	16.3	18.8	19.7	19.4	17.4	15.2	11.7	9.8	(31)	
		MCDB	9.9	10.4	13.3	17.8	20.8	23.8	25.5	25.0	21.0	17.5	13.2	10.9	(32)	
	10%	WB	7.6	7.8	9.5	11.8	15.1	17.6	18.8	18.4	16.3	14.2	10.6	8.5	(33)	
		MCDB	8.7	9.5	11.9	15.9	19.4	22.1	23.8	23.2	19.4	16.2	11.9	9.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	5.0	6.7	8.3	8.5	8.9	8.7	8.6	7.6	6.3	4.6	4.1	(35)	
		MCDBR	5.0	6.4	9.7	11.7	11.8	12.4	12.2	12.7	10.3	8.0	5.7	4.8	(36)	
	5% WB	MCWBR	4.4	4.6	5.8	6.1	6.0	6.3	5.2	5.3	5.0	4.8	4.3	4.1	(37)	
		MCWBR	5.0	5.3	8.1	10.3	10.4	10.9	10.8	10.9	8.9	7.2	5.3	4.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.322	0.344	0.377	0.412	0.422	0.419	0.423	0.414	0.385	0.360	0.335	0.320	(40)	
		taud	2.406	2.371	2.282	2.201	2.217	2.243	2.234	2.281	2.349	2.418	2.410	2.373	(41)	
	Ebn at Noon		704	782	816	826	835	839	829	816	800	753	677	639	(42)	
		Edh at Noon	62	83	108	130	134	132	131	119	100	78	62	56	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.77	1.45	2.60	4.14	4.92	5.36	5.08	4.33	3.26	1.92	0.91	0.61	(44)	
	RadStd		0.11	0.28	0.37	0.47	0.48	0.47	0.61	0.45	0.34	0.16	0.11	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (80 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page