

SCHAFFEN AB, Belgium

WMO: 064650

Lat: 50.9969N

Lon: 5.0619E

Elev: 54

StdP: 100.68

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.1	(c) -4.2	(d) -10.4	(e) 1.5	(f) -4.1	(g) -8.0	(h) 1.9	(i) -2.6	(j) 11.3	(k) 9.3	(l) 10.2	(m) 8.1	(n) 2.8	(o) 40	(p) 0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	30.1	19.6	27.9	18.8	26.0	17.9	20.7	27.6	19.7	25.9	18.9	24.1	2.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.5	22.9	17.6	12.7	21.7	16.9	12.1	21.1	59.9	27.7	56.6	26.1	53.8	23.9	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.6	(b) 7.5	(c) 6.7	(e) -8.6	(f) 34.0	(g) 3.0	(h) 2.1	(i) -10.7	(j) 35.4	(k) -12.5	(l) 36.7	(m) -14.1	(n) 37.8	(o) -16.3	(p) 39.3		
(a) 8.6	(b) 7.5	(c) 6.7	(e) -8.9	(f) 22.6	(g) 2.8	(h) 1.2	(i) -11.0	(j) 23.4	(k) -12.6	(l) 24.1	(m) -14.2	(n) 24.8	(o) -16.2	(p) 25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	3.6	4.2	7.0	10.6	13.9	16.9	19.0	18.3	15.4	12.0	7.4	4.3
	DBStd	6.49	4.20	3.95	3.72	3.85	3.56	3.17	3.28	2.74	2.91	3.44	3.42	4.08
	HDD10.0	801	199	164	106	37	6	0	0	0	0	19	91	178
	HDD18.3	2766	456	396	352	232	143	66	31	33	98	197	328	433
	CDD10.0	1201	2	2	12	57	127	206	279	257	161	82	13	3
	CDD18.3	123	0	0	0	1	6	22	52	32	9	1	0	0
	CDH23.3	1110	0	0	0	24	66	203	455	282	76	4	0	0
	CDH26.7	310	0	0	0	2	10	51	147	87	13	0	0	0
Wind	WSAvg	3.3	3.8	3.7	3.6	3.3	3.2	3.0	2.9	2.7	2.8	3.0	3.3	3.6
Precipitation	PrecAvg	784	66	59	57	49	61	74	76	81	59	64	65	73
	PrecMax	1030	124	142	135	116	140	168	228	217	174	174	110	154
	PrecMin	600	3	5	2	4	22	14	31	16	15	30	6	19
	PrecStd	116	30	31	28	25	29	34	41	50	38	28	25	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	15.1	19.6	26.3	28.3	31.6	34.1	32.3	28.7	23.6	17.5	13.9
		MCWB	10.7	9.4	11.6	15.1	18.4	20.3	20.6	19.9	19.2	17.1	13.9	11.7
	2%	DB	12.0	12.6	16.9	23.0	25.2	28.4	30.3	29.1	25.6	20.6	15.4	12.5
		MCWB	10.2	9.1	10.7	13.8	16.2	18.8	19.5	19.5	18.1	16.1	12.8	10.6
	5%	DB	10.4	11.0	14.4	20.1	23.3	25.9	27.9	26.4	23.0	18.5	13.8	11.2
		MCWB	8.7	8.7	10.0	12.7	15.4	17.8	18.9	18.7	17.1	14.9	11.6	9.6
	10%	DB	9.2	9.7	12.6	17.5	20.8	23.6	25.8	23.9	20.6	16.8	12.5	9.9
		MCWB	7.6	7.8	9.1	11.5	14.5	16.9	18.3	17.5	15.9	14.0	10.7	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	10.9	12.8	15.8	19.6	22.0	22.0	22.2	20.3	17.9	14.6	12.1
		MCDB	12.6	13.2	16.9	23.7	26.0	29.1	29.7	29.1	26.4	22.0	16.7	13.3
	2%	WB	10.2	9.9	11.6	14.5	17.7	20.0	20.7	20.4	19.0	16.4	13.0	10.9
		MCDB	11.7	11.7	15.3	21.1	22.7	25.8	28.0	27.0	23.8	19.9	14.9	12.2
	5%	WB	8.9	8.9	10.5	13.2	16.2	18.6	19.7	19.3	17.8	15.4	12.0	9.7
		MCDB	10.3	10.6	13.8	19.0	21.2	23.9	26.3	24.7	21.9	17.9	13.6	11.0
	10%	WB	7.7	7.8	9.5	12.0	15.0	17.5	18.9	18.3	16.7	14.4	10.8	8.7
		MCDB	9.1	9.6	12.2	16.7	19.8	22.5	24.2	22.8	19.9	16.5	12.4	9.9
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.6	7.5	9.4	9.3	9.7	9.6	9.3	8.8	7.3	5.4	4.6
		MCDBR	5.1	7.4	11.1	13.6	13.2	13.5	13.2	13.8	12.2	9.3	6.7	4.9
		MCWBR	4.4	5.1	6.3	6.3	6.0	5.7	5.0	5.7	5.7	5.4	4.9	4.1
	5% WB	MCDBR	5.1	6.1	9.3	12.2	10.9	11.1	11.6	11.7	10.9	8.5	6.1	4.6
MCWBR		4.6	4.7	5.8	5.9	5.8	5.7	4.8	5.6	5.5	5.2	4.8	4.1	
Clear-Sky Solar Irradiance	taub	0.328	0.352	0.385	0.417	0.426	0.423	0.429	0.420	0.391	0.366	0.341	0.326	
	taud	2.385	2.347	2.256	2.194	2.213	2.239	2.227	2.274	2.342	2.400	2.389	2.353	
	Ebn at Noon	688	768	805	820	830	835	822	810	792	742	662	622	
	Edh at Noon	63	85	110	131	134	132	132	120	101	79	63	57	
All-Sky Solar Radiation	RadAvg	0.77	1.44	2.60	4.15	4.95	5.38	5.08	4.33	3.24	1.91	0.90	0.60	
	RadStd	0.10	0.28	0.37	0.46	0.46	0.46	0.61	0.42	0.32	0.16	0.10	0.09	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (85 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page