

BUZENOL, Belgium

WMO: 064840

Lat: 49.6203N

Lon: 5.5875E

Elev: 1063

StdP: 14.14

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.1	20.7	8.0	8.6	20.0	14.1	11.7	23.9	18.9	44.6	17.2	44.0	5.1	70	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	85.5	67.7	80.8	66.0	77.0	63.5	69.6	80.2	67.8	77.3	66.0	74.4	6.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	102.9	72.0	65.0	96.0	70.1	63.1	89.9	68.2	34.3	80.0	32.7	77.1	31.3	74.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	14.3	12.8	8.8	93.3	5.9	3.1	4.6	95.6	1.1	97.4	-2.2	99.2	-6.4	101.4
			8.5	74.2	6.0	1.9	4.2	75.6	0.7	76.7	-2.7	77.8	-7.0	79.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	34.6	34.7	41.7	47.6	53.4	60.1	63.6	62.3	56.2	49.9	42.5	36.8	(6)
(7)		DBStd	12.06	7.10	7.60	6.47	6.60	6.38	5.93	5.96	5.77	5.15	6.63	6.35	7.54	(7)
(8)		HDD50	2070	479	428	265	122	36	0	0	0	6	84	239	411	(8)
(9)		HDD65	6080	943	848	723	521	364	172	99	122	269	468	676	875	(9)
(10)		CDD50	1588	0	0	6	51	140	303	421	382	191	81	12	1	(10)
(11)		CDD65	126	0	0	0	0	3	25	55	39	4	0	0	0	(11)
(12)		CDH74	1587	0	0	0	7	55	334	661	457	70	3	0	0	(12)
(13)		CDH80	478	0	0	0	0	8	92	220	146	12	0	0	0	(13)
(14)	Wind	WSAvg	6.1	6.5	6.8	7.0	6.6	6.1	6.0	5.4	5.2	5.4	5.6	6.4	6.5	(14)
(15)	Precipitation	PrecAvg	39.4	4.4	3.5	3.1	2.4	2.7	2.7	3.0	3.2	2.8	3.5	3.6	4.5	(15)
(16)		PrecMax	49.7	10.9	8.1	7.2	6.1	5.6	7.5	8.1	7.6	5.2	8.0	6.5	12.5	(16)
(17)		PrecMin	28.1	0.6	0.3	0.3	0.2	0.7	1.1	1.0	0.7	0.7	1.6	1.5	2.7	(17)
(18)		PrecStd	5.8	2.5	2.1	1.8	1.4	1.2	1.5	1.5	1.7	1.5	1.4	1.5	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	56.8	66.2	74.4	79.9	88.0	92.0	90.6	81.5	72.6	60.2	54.1	(19)
(20)			MCWB	50.0	45.2	51.0	57.8	65.0	67.9	68.6	67.5	65.8	60.1	57.4	51.5	(20)
(21)		2%	DB	49.9	50.2	62.6	70.5	74.5	82.7	85.9	84.2	74.9	67.7	56.9	51.4	(21)
(22)			MCWB	48.5	45.6	49.6	54.8	60.6	67.4	67.9	67.0	62.9	60.2	54.6	49.7	(22)
(23)		5%	DB	47.1	47.5	57.7	66.1	70.9	77.2	80.9	78.8	70.8	62.5	54.6	49.2	(23)
(24)			MCWB	46.1	45.2	47.1	53.2	58.9	64.1	65.7	65.0	61.8	58.0	52.5	47.8	(24)
(25)		10%	DB	44.5	45.0	53.0	61.3	66.7	73.2	76.6	74.3	66.3	59.1	51.7	47.1	(25)
(26)			MCWB	43.5	43.0	46.6	51.3	57.5	62.4	63.9	63.6	59.4	56.3	50.1	45.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	49.4	52.5	60.0	66.8	72.0	72.1	71.3	67.5	63.8	58.8	52.3	(27)
(28)			MCDWB	51.4	53.3	60.8	72.5	76.4	84.2	79.0	80.6	74.8	67.3	59.5	53.0	(28)
(29)		2%	WB	48.8	47.3	50.8	56.6	63.4	68.6	69.8	68.6	65.0	61.0	54.9	50.1	(29)
(30)			MCDWB	49.6	49.4	57.9	66.6	69.8	78.5	81.8	77.4	72.5	65.7	55.8	51.3	(30)
(31)		5%	WB	45.9	45.0	49.1	54.1	60.6	66.0	68.0	66.8	62.9	58.8	52.7	48.1	(31)
(32)			MCDWB	46.8	47.3	55.8	63.6	67.1	74.6	78.5	75.5	69.0	62.0	54.2	49.1	(32)
(33)		10%	WB	43.6	43.0	47.2	52.3	58.4	63.5	66.0	65.0	60.6	56.8	50.1	46.0	(33)
(34)			MCDWB	44.5	45.2	52.9	60.2	65.5	71.3	74.4	72.5	65.5	59.3	51.5	47.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	11.0	16.1	19.8	19.3	19.1	20.4	19.8	17.8	14.0	8.8	9.1	(35)
(36)			MCDBR	10.3	16.0	26.9	27.8	25.6	26.9	28.7	27.9	25.3	19.8	11.9	10.7	(36)
(37)			MCWBR	9.2	11.9	15.6	14.9	13.9	13.6	12.4	12.8	14.2	12.9	9.9	9.7	(37)
(38)		5% WB	MCDBR	9.7	14.1	21.4	24.4	21.4	23.5	24.4	22.8	20.8	16.7	11.3	10.4	(38)
(39)			MCWBR	8.9	11.2	14.0	13.9	12.9	12.9	12.1	12.5	12.8	12.2	10.0	9.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.329	0.359	0.389	0.399	0.401	0.398	0.393	0.365	0.350	0.323	0.302	(40)	
(41)		taud	2.437	2.395	2.325	2.261	2.268	2.288	2.289	2.330	2.388	2.429	2.446	2.422	(41)	
(42)		Ebn at Noon	238	258	268	271	272	272	271	267	263	246	227	220	(42)	
(43)		Edh at Noon	20	26	33	39	41	40	40	36	31	25	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	256	487	867	1350	1593	1769	1683	1439	1097	630	293	204	(44)	
(45)		RadStd	41	89	121	169	176	163	169	161	115	55	33	35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (58 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page