

LA CHAUX-DE-FONDS, Switzerland

WMO: 066120

Lat: 47.0831N

Lon: 6.7922E

Elev: 3340

StdP: 13.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.8	12.5	2.1	6.9	11.2	7.4	9.1	15.5	22.3	40.7	19.8	37.6	3.7	60	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	79.8	63.2	76.4	62.1	73.4	60.7	64.8	75.8	63.3	73.8	61.8	71.5	6.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.8	90.0	69.1	59.2	85.1	67.7	57.9	81.0	66.3	31.7	76.2	30.5	73.9	29.3	71.8	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.7	15.2	13.3	-1.2	84.5	6.2	3.2	-5.6	86.8	-9.2	88.6	-12.6	90.4	-17.1	92.7		
			-1.3	67.7	5.4	1.6	-5.2	68.9	-8.3	69.8	-11.3	70.7	-15.2	71.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	29.8	30.6	36.7	43.1	50.2	57.1	60.1	59.5	52.9	47.3	37.7	31.9
	DBStd	12.98	7.92	8.37	7.55	6.97	6.38	6.84	6.02	6.02	6.04	6.92	7.91	7.94
	HDD50	3008	625	544	414	224	78	14	3	3	39	130	373	561
	HDD65	7419	1090	964	878	658	460	249	174	189	363	548	820	1026
	CDD50	1120	0	0	1	16	84	228	316	298	127	48	2	0
	CDD65	55	0	0	0	0	0	13	22	19	1	0	0	0
	CDH74	579	0	0	0	0	8	144	214	208	5	0	0	0
	CDH80	93	0	0	0	0	0	23	34	36	0	0	0	0
Wind	WSAvg	4.7	5.1	5.4	5.5	5.0	4.8	4.4	4.3	3.7	4.2	4.3	4.9	5.3
Precipitation	PrecAvg	54.0	4.1	3.9	3.6	4.1	4.9	4.6	5.0	4.9	4.4	4.7	4.8	5.0
	PrecMax	70.0	10.8	9.4	11.9	7.2	8.3	9.4	11.2	10.2	8.8	8.4	12.0	10.9
	PrecMin	39.6	0.8	1.1	0.9	1.1	2.0	1.9	2.2	1.9	0.6	0.4	0.1	0.1
	PrecStd	7.9	2.5	2.1	2.6	2.1	1.9	1.9	1.9	2.2	2.0	2.0	2.6	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	53.8	60.5	68.3	74.5	83.4	84.2	84.5	74.4	70.0	60.8	52.1
		MCWB	41.1	41.1	46.1	52.3	59.0	63.7	63.5	62.9	60.0	55.0	49.0	43.2
	2%	DB	46.1	48.9	56.5	63.8	70.2	78.2	79.4	79.2	71.5	65.6	56.2	48.2
		MCWB	41.2	39.8	44.7	49.9	56.7	62.6	63.0	63.3	59.3	54.0	47.1	42.0
	5%	DB	43.2	45.1	52.8	59.8	66.7	74.2	75.8	75.7	67.9	62.2	52.5	45.5
		MCWB	39.1	38.9	43.1	48.8	54.8	61.0	62.2	61.9	57.6	52.8	45.9	41.5
	10%	DB	40.6	41.7	48.4	55.8	62.8	70.5	72.5	72.0	64.3	58.8	49.3	43.0
		MCWB	37.5	37.5	41.8	46.6	53.0	59.8	60.9	60.9	56.4	51.6	44.9	39.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.1	43.8	48.1	53.9	61.2	66.7	66.5	66.4	63.0	57.6	51.2	46.2
		MCDB	47.2	48.4	55.9	64.9	71.6	78.7	77.5	77.8	71.0	65.3	56.3	48.8
	2%	WB	42.0	41.4	46.2	51.3	58.2	64.1	64.5	64.5	60.6	55.7	48.8	43.8
		MCDB	44.6	46.5	52.9	61.2	67.7	74.8	75.9	75.6	68.4	62.2	53.4	46.6
	5%	WB	39.8	39.6	44.3	49.4	55.9	62.1	63.0	62.9	58.7	54.1	46.9	41.9
		MCDB	42.5	44.1	51.2	58.1	64.1	71.9	73.7	73.3	66.1	60.3	51.4	44.8
	10%	WB	37.7	37.8	42.3	47.4	53.8	60.3	61.6	61.3	56.8	52.4	44.9	39.9
		MCDB	40.1	41.6	47.9	54.8	61.4	69.2	71.1	70.4	63.1	57.8	49.1	42.8
Mean Daily Temperature Range	5% DB	MDBR	12.9	13.9	14.9	15.8	16.1	17.1	17.0	17.1	16.0	16.0	13.2	12.6
		MCDBR	15.0	19.7	22.5	23.9	23.9	23.8	23.6	24.3	22.8	22.3	19.7	16.9
		MCWBR	10.5	12.6	13.1	13.3	13.0	12.0	11.2	11.8	12.9	12.8	12.5	11.6
	5% WB	MCDBR	12.0	15.8	19.1	21.3	21.2	21.6	21.1	21.6	19.9	19.2	17.2	12.9
		MCWBR	9.4	11.0	11.9	12.5	12.2	11.6	10.8	11.2	11.7	11.7	11.9	9.9
Clear-Sky Solar Irradiance	taub	0.272	0.294	0.324	0.356	0.364	0.367	0.366	0.359	0.341	0.323	0.294	0.271	
	taud	2.480	2.434	2.411	2.344	2.359	2.380	2.373	2.404	2.441	2.485	2.514	2.488	
	Ebn at Noon	265	280	286	285	285	285	283	281	277	265	253	252	
	Edh at Noon	20	26	31	37	37	37	37	34	30	25	20	18	
All-Sky Solar Radiation	RadAvg	381	647	1024	1381	1593	1886	1824	1586	1220	775	421	309	
	RadStd	48	99	154	203	149	175	160	147	112	75	54	55	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	+1.35	+0.92	+0.52	N/A	N/A	+95	+25
	Regional (99 neighbors)	N/A	N/A	N/A	N/A	+0.70	+0.54	N/A	N/A	N/A	N/A

Nomenclature: See separate page