

FAHY-BONCOURT, Switzerland

WMO: 066160

Lat: 47.4239N

Lon: 6.9411E

Elev: 1959

StdP: 13.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.8	19.6	10.5	10.1	20.5	14.6	12.4	22.8	24.6	46.0	22.0	45.4	6.3	70	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	84.1	67.0	80.5	65.7	77.3	64.5	68.4	80.2	66.8	78.2	65.3	75.7	5.6	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	96.9	74.3	62.7	91.6	71.5	61.4	87.3	70.1	33.8	80.5	32.4	78.6	31.2	75.9	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.5	15.5	13.2	DB	10.6	89.0	5.2	4.2	6.9	92.0	3.9	94.5	1.0	96.9	-2.8	100.0
			WB	9.9	72.3	5.0	1.8	6.3	73.5	3.4	74.6	0.5	75.5	-3.1	76.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	34.0	35.9	41.8	48.0	55.1	61.7	65.1	64.6	57.2	50.8	41.3	36.1
	DBStd	13.11	8.10	8.17	7.58	7.23	6.61	6.84	6.22	6.48	6.12	7.09	7.44	7.90
	HDD50	2105	496	396	269	122	25	2	0	0	10	79	272	434
	HDD65	5926	960	815	721	511	314	144	78	89	245	442	710	897
	CDD50	1871	0	1	14	62	183	352	467	452	225	102	12	1
	CDD65	216	0	0	0	0	6	44	80	75	10	1	0	0
	CDH74	1532	0	0	0	2	41	305	598	538	45	3	0	0
	CDH80	365	0	0	0	0	2	59	153	149	2	0	0	0
Wind	WSAvg	5.6	6.7	6.7	6.8	5.7	5.2	4.8	4.8	4.5	4.8	5.1	5.7	6.7
Precipitation	PrecAvg	51.6	3.8	3.7	3.5	3.9	4.8	4.4	4.6	4.7	4.2	4.6	4.6	4.8
	PrecMax	69.0	8.8	8.5	11.7	7.5	8.9	8.7	10.6	9.3	8.2	8.7	11.7	9.5
	PrecMin	36.8	0.6	0.9	0.8	0.6	2.3	1.7	1.7	0.9	1.6	0.4	0.6	0.3
	PrecStd	7.7	2.3	1.9	2.5	2.0	1.9	1.9	1.9	2.2	1.9	2.0	2.5	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	57.8	65.0	72.6	78.7	86.4	89.4	90.5	79.0	72.3	61.9	55.5
		MCWB	46.0	46.3	51.0	56.5	63.1	69.3	67.9	66.7	63.5	59.3	52.6	47.0
	2%	DB	50.7	53.1	60.9	67.5	74.0	81.1	84.1	83.8	74.6	67.5	57.4	52.0
		MCWB	45.4	44.6	49.1	54.1	60.8	66.8	66.7	66.6	62.9	57.9	50.5	46.5
	5%	DB	48.1	50.0	56.9	63.8	70.5	77.5	80.3	79.8	70.8	64.0	54.6	49.6
		MCWB	43.7	43.1	47.0	52.4	58.8	65.4	65.5	65.4	61.2	56.3	49.5	45.5
	10%	DB	45.0	46.9	53.2	60.0	66.8	73.8	76.8	76.0	67.1	60.8	51.9	47.2
		MCWB	41.3	41.9	45.7	50.2	57.0	63.2	64.1	64.3	59.3	55.1	47.7	43.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	48.3	52.8	57.9	65.4	71.3	70.2	70.5	66.3	61.2	54.4	49.8
		MCDB	51.7	54.6	61.9	69.7	76.0	82.6	84.2	81.3	74.5	68.6	58.6	52.5
	2%	WB	46.3	45.9	50.3	55.1	62.3	68.1	68.0	68.0	63.9	59.1	52.0	47.6
		MCDB	49.4	51.2	57.5	65.4	71.6	78.6	80.5	80.2	71.9	65.1	55.9	50.5
	5%	WB	44.0	44.2	48.3	53.1	59.9	65.9	66.4	66.4	62.0	57.4	49.9	45.9
		MCDB	47.4	49.1	55.2	62.2	68.4	75.9	78.3	78.0	69.2	62.8	53.8	49.1
	10%	WB	41.8	42.4	46.3	51.1	57.7	64.0	64.8	64.8	60.1	55.6	47.9	43.8
		MCDB	44.8	46.5	52.4	58.9	64.9	72.6	75.3	74.5	66.1	60.0	51.4	47.0
Mean Daily Temperature Range	5% DB	MDBR	8.7	10.2	13.0	14.8	15.0	15.9	16.4	15.6	13.6	12.0	9.6	8.8
		MCDBR	11.7	15.4	19.0	20.7	20.6	21.0	21.9	21.4	18.9	16.8	14.0	11.6
		MCWBR	8.1	10.0	10.9	11.4	11.2	11.0	9.5	9.4	9.8	9.7	9.2	8.3
	5% WB	MCDBR	10.4	13.4	16.5	18.9	18.9	19.7	19.9	19.2	16.6	15.3	12.7	10.6
		MCWBR	8.2	9.4	10.1	10.8	10.8	10.7	9.3	9.2	9.2	9.7	8.9	8.2
Clear-Sky Solar Irradiance	taub	0.296	0.319	0.351	0.386	0.393	0.397	0.395	0.389	0.368	0.349	0.316	0.293	
	taud	2.460	2.397	2.349	2.268	2.287	2.311	2.309	2.341	2.383	2.426	2.469	2.463	
	Ebn at Noon	252	268	275	275	276	275	274	271	266	253	241	239	
	Edh at Noon	21	27	33	40	40	40	39	36	32	26	21	18	
All-Sky Solar Radiation	RadAvg	347	607	997	1378	1601	1892	1809	1572	1193	748	397	281	
	RadStd	46	97	154	207	158	174	161	148	114	70	49	55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (102 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	+0.70	+0.54	N/A	N/A	+94	+29

Nomenclature: See separate page