

PLAFFEIEN, Switzerland

WMO: 066280

Lat: 46.7478N

Lon: 7.2661E

Elev: 3415

StdP: 12.97

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	15.7	5.5	8.3	18.9	9.4	10.1	21.3	38.1	42.9	34.3	41.9	5.6	160	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	78.2	63.5	75.1	62.4	72.3	61.2	65.2	75.1	63.6	72.8	62.1	70.6	6.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.4	92.3	70.8	59.8	87.0	68.8	58.4	82.8	67.2	32.1	75.6	30.7	73.1	29.6	70.7	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.1	22.5	17.7	DB	8.8	82.2	4.5	2.9	5.6	84.3	3.0	86.0	0.5	87.7	-2.8	89.8	(4)
(5)			WB	7.8	68.6	4.5	2.0	4.6	70.1	1.9	71.2	-0.6	72.4	-3.9	73.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.7	31.0	31.7	37.9	43.7	51.1	58.1	61.4	60.7	53.5	47.4	38.1	33.0	(6)	
	DBStd	13.13	7.93	8.75	7.92	7.53	6.98	7.23	6.26	6.44	6.29	7.10	7.84	8.03	(7)	
	HDD50	2835	589	513	378	213	71	13	2	3	36	131	360	526	(8)	
	HDD65	7121	1054	933	840	638	431	226	145	166	345	545	807	991	(9)	
	CDD50	1276	0	0	3	25	106	256	356	334	142	51	3	0	(10)	
	CDD65	87	0	0	0	0	1	19	34	32	1	0	0	0	(11)	
	CDH74	371	0	0	0	0	4	84	153	130	0	0	0	0	(12)	
	CDH80	35	0	0	0	0	0	7	16	12	0	0	0	0	(13)	
	Wind	WSAvg	6.3	7.2	7.0	7.6	6.3	6.1	5.9	5.5	5.5	5.4	6.1	7.4	(14)	
	Precipitation	PrecAvg	54.0	3.2	3.3	3.4	3.9	5.7	6.1	6.4	5.9	4.4	3.9	4.1	(15)	
(16)		PrecMax	68.3	8.5	10.5	9.8	7.1	9.4	11.2	12.6	9.6	7.0	7.4	8.4	(16)	
(17)		PrecMin	44.6	0.7	0.8	1.4	1.3	1.7	2.6	2.8	1.2	2.5	0.5	0.2	(17)	
(18)		PrecStd	6.5	2.0	2.4	1.9	1.6	2.2	2.0	2.2	2.0	1.4	1.6	2.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	53.1	58.8	67.1	73.2	80.7	82.2	81.7	72.1	65.7	57.1	51.9	(19)	
		MCWB	41.5	41.2	47.5	52.4	59.5	64.9	64.3	64.5	61.3	55.1	47.7	40.9	(20)	
	2%	DB	47.4	48.6	55.4	62.3	69.0	76.3	78.1	77.6	69.1	62.3	53.6	48.4	(21)	
		MCWB	40.9	39.9	45.6	50.9	56.8	62.8	63.2	63.6	60.0	54.1	46.4	41.6	(22)	
	5%	DB	44.5	45.8	52.1	58.7	65.5	73.1	74.9	74.4	65.8	59.5	51.3	46.0	(23)	
		MCWB	38.9	38.9	43.6	49.0	55.1	61.3	62.2	62.3	58.2	52.8	45.1	40.2	(24)	
	10%	DB	41.8	43.0	48.9	55.2	62.3	69.9	71.7	71.1	63.0	56.9	48.9	43.8	(25)	
		MCWB	36.9	37.2	42.1	47.0	53.6	59.7	60.8	61.1	56.4	51.4	43.8	38.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	43.9	49.0	54.2	61.4	67.6	66.9	67.1	63.0	58.1	50.1	45.2	(27)	
		MCDB	48.5	48.9	56.3	64.1	70.8	78.1	77.8	76.8	69.8	62.2	54.7	48.5	(28)	
	2%	WB	42.2	41.3	46.5	51.5	58.5	64.4	64.8	65.1	60.9	55.7	47.9	42.9	(29)	
		MCDB	45.9	46.4	53.4	60.6	66.9	74.0	75.0	74.9	67.3	60.2	52.0	46.5	(30)	
	5%	WB	39.7	39.5	44.6	49.4	56.2	62.3	63.2	63.3	59.0	53.9	46.0	41.2	(31)	
		MCDB	43.3	44.5	50.9	57.6	64.0	71.3	72.7	72.1	64.6	58.1	50.1	45.1	(32)	
	10%	WB	37.4	37.8	42.6	47.5	54.0	60.5	61.7	61.7	57.1	52.0	44.2	39.3	(33)	
		MCDB	41.3	42.5	48.0	54.5	61.1	68.7	70.4	69.8	62.2	56.2	48.2	43.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	9.6	11.4	12.9	13.5	13.8	14.0	13.2	11.6	10.5	8.9	8.9	(35)	
		MCDBR	11.5	12.5	15.2	17.2	17.7	17.2	17.4	16.4	14.7	13.4	11.8	11.4	(36)	
		MCWBR	8.3	8.6	10.1	10.8	11.0	10.5	9.6	9.9	9.9	9.5	8.5	8.0	(37)	
	5% WB	MCDBR	10.5	11.8	13.8	16.2	16.3	16.4	16.0	15.5	13.6	12.0	10.6	10.6	(38)	
		MCWBR	8.3	8.8	9.7	10.6	10.7	10.3	9.6	10.0	9.6	9.3	8.3	8.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.262	0.286	0.321	0.356	0.368	0.370	0.369	0.360	0.341	0.320	0.289	0.262	(40)	
	taud		2.431	2.381	2.357	2.319	2.333	2.365	2.357	2.394	2.436	2.486	2.500	2.454	(41)	
	Ebn at Noon		269	283	287	285	284	284	282	280	277	267	257	256	(42)	
	Edh at Noon		21	28	33	38	39	38	37	35	30	25	20	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		414	687	1052	1384	1585	1880	1839	1601	1247	802	445	336	(44)	
	RadStd		49	101	153	199	141	176	159	147	111	81	59	56	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+1.62	+0.76	+0.54	N/A	N/A	+140	+38	(46)
(47)	Regional (111 neighbors)	N/A	N/A	N/A	+1.33	+0.76	+0.58	N/A	N/A	+103	+32	(47)

Nomenclature: See separate page