

MOEHLIN, Switzerland

WMO: 066410

Lat: 47.5722N

Lon: 7.8778E

Elev: 1115

StdP: 14.11

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.9	23.3	8.2	8.7	16.5	17.6	13.9	24.9	22.1	37.0	20.6	37.4	6.7	110	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	88.9	69.2	85.0	68.5	81.2	66.9	71.2	83.5	69.6	81.8	67.9	78.9	5.9	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	104.5	76.6	65.6	98.4	73.5	64.3	94.0	71.2	35.7	83.9	34.2	81.8	32.8	79.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	17.0	14.9	14.0	93.7	6.7	2.4	9.2	95.5	5.3	96.9	1.6	98.3	-3.3	100.0
			12.4	75.1	6.6	1.3	7.7	76.1	3.8	76.8	0.1	77.6	-4.8	78.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	36.0	36.1	43.9	50.7	56.7	64.5	67.6	67.3	60.3	52.4	42.9	37.7	(6)
	DBStd	13.04	6.59	7.80	5.92	6.65	6.28	5.96	5.90	6.08	5.41	6.11	6.01	5.63	(7)
	HDD50	1762	434	390	199	72	12	0	0	0	0	49	224	382	(8)
	HDD65	5280	898	809	653	429	267	80	39	47	160	389	662	847	(9)
	CDD50	2289	1	1	11	94	219	436	546	535	310	124	11	1	(10)
	CDD65	333	0	0	0	0	9	66	120	118	20	0	0	0	(11)
	CDH74	3186	0	0	0	21	115	686	1211	992	161	0	0	0	(12)
	CDH80	1038	0	0	0	2	14	221	439	339	23	0	0	0	(13)
(14) Wind	WSAvg	5.5	6.8	6.7	6.1	5.0	4.5	4.3	4.2	4.2	4.4	5.8	6.5	7.6	(14)
(15) Precipitation	PrecAvg	54.2	4.3	4.1	3.9	3.9	4.9	4.8	4.8	4.5	4.0	4.5	4.9	5.6	(15)
	PrecMax	72.2	10.2	10.2	13.6	8.1	8.3	9.9	9.8	10.7	7.8	8.9	11.8	11.7	(16)
	PrecMin	39.7	0.4	1.3	1.0	0.3	1.7	1.1	1.4	0.8	2.0	0.4	0.2	0.2	(17)
	PrecStd	8.4	2.5	2.2	2.6	2.1	1.9	2.1	1.9	2.0	1.8	2.1	2.8	2.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.4	59.1	67.4	77.2	82.0	90.7	93.8	91.8	83.0	71.9	62.7	55.1	(19)
		MCWB	51.7	49.2	52.3	58.9	67.3	72.2	69.9	69.7	66.5	60.7	55.1	50.2	(20)
	2%	DB	50.4	54.1	64.1	72.1	77.0	86.2	89.7	87.9	79.3	67.9	58.5	52.0	(21)
		MCWB	46.2	47.0	51.2	56.7	63.4	69.9	68.3	69.7	65.0	60.0	53.2	48.8	(22)
	5%	DB	47.0	50.2	59.7	68.5	73.8	81.7	85.1	83.9	74.5	64.1	54.5	48.6	(23)
		MCWB	44.3	45.1	49.3	55.9	62.0	68.0	67.3	68.5	63.7	58.3	50.9	46.2	(24)
	10%	DB	44.4	45.8	55.5	64.4	69.7	77.3	80.7	79.7	70.5	61.0	51.0	45.9	(25)
		MCWB	42.4	41.9	47.6	53.5	59.0	65.6	66.1	67.0	62.0	56.8	48.7	44.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	50.4	54.0	60.7	67.5	74.5	72.5	73.4	68.1	62.9	56.5	51.2	(27)
		MCDB	56.2	56.9	64.7	76.2	79.1	87.0	87.4	85.4	78.7	68.5	61.3	53.5	(28)
	2%	WB	47.2	47.7	51.8	58.0	64.8	71.4	70.2	71.0	66.4	60.8	53.5	48.9	(29)
		MCDB	49.7	53.6	61.8	68.8	74.3	83.5	84.1	82.6	75.7	65.6	57.6	51.5	(30)
	5%	WB	44.5	45.2	49.9	56.1	62.1	68.8	68.4	69.6	64.9	59.2	51.2	46.6	(31)
		MCDB	46.7	50.1	58.1	66.2	69.8	79.9	80.9	81.3	72.6	62.8	54.2	48.4	(32)
	10%	WB	42.6	42.5	48.1	53.9	59.9	66.6	67.1	67.9	63.0	57.4	49.0	44.2	(33)
		MCDB	44.2	45.6	54.4	62.4	67.2	75.7	78.1	78.0	68.6	60.2	50.7	45.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	11.9	17.3	18.9	18.5	19.4	20.4	19.7	17.8	13.7	9.5	8.7	(35)
		MCDBR	13.6	19.9	26.9	27.3	25.8	26.5	28.3	25.9	23.6	18.6	15.0	12.4	(36)
		MCWBR	10.0	12.9	15.2	13.1	12.5	12.1	10.4	10.0	11.2	11.0	9.9	9.2	(37)
	5% WB	MCDBR	12.9	19.1	23.4	25.0	22.5	24.6	24.0	23.5	20.9	16.5	14.1	11.5	(38)
		MCWBR	9.7	12.9	13.7	12.8	11.7	12.0	10.1	9.5	10.3	10.4	9.7	8.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.309	0.336	0.371	0.407	0.417	0.421	0.421	0.414	0.390	0.367	0.331	0.306	(40)
	taud		2.438	2.355	2.295	2.222	2.238	2.271	2.266	2.300	2.345	2.392	2.441	2.440	(41)
	Ebn at Noon		245	260	267	268	269	268	266	263	258	245	233	231	(42)
	Edh at Noon		21	28	35	42	43	41	41	38	33	27	21	19	(43)
(44) All-Sky Solar Radiation	RadAvg		344	603	992	1373	1597	1863	1781	1551	1168	729	390	279	(44)
	RadStd		43	93	147	202	161	171	161	152	116	71	47	51	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (116 neighbors)		N/A	N/A	N/A	+1.33	+0.72	+0.56	N/A	N/A	+99	+25

Nomenclature: See separate page