

BEZNAU, Switzerland

WMO: 066460

Lat: 47.5572N

Lon: 8.2333E

Elev: 1073

StdP: 14.14

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 18.4	(c) 22.5	(d) 11.7	(e) 10.4	(f) 21.4	(g) 17.2	(h) 13.6	(i) 25.3	(j) 14.1	(k) 45.2	(l) 12.1	(m) 42.9	(n) 3.3	(o) 40	(p) 0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.5	(c) 89.8	(d) 69.3	(e) 85.8	(f) 68.4	(g) 82.2	(h) 67.1	(i) 71.5	(j) 83.8	(k) 69.9	(l) 81.7	(m) 68.3	(n) 78.9	(o) 3.9	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 68.0	(b) 107.1	(c) 75.1	(d) 66.3	(e) 100.9	(f) 73.0	(g) 65.0	(h) 96.2	(i) 71.3	(j) 35.9	(k) 83.3	(l) 34.5	(m) 81.6	(n) 33.2	(o) 79.3	(p) 79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 11.0	(b) 9.1	(c) 7.5	(e) 12.7	(f) 94.6	(g) 5.4	(h) 2.5	(i) 8.8	(j) 96.4	(k) 5.6	(l) 97.9	(m) 2.6	(n) 99.3	(o) -1.3	(p) 101.1		
			DB													
			WB													
				12.8	75.2	5.7	1.9	8.7	76.6	5.4	77.7	2.2	78.8	-1.9	80.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	35.2	35.9	43.6	51.5	57.7	65.3	68.7	67.9	60.5	52.3	43.2	36.7		
	DBStd	13.51	6.50	7.23	6.07	6.25	6.43	5.91	5.59	5.60	5.45	6.34	6.25	5.91		
	HDD50	1818	460	396	210	58	9	0	0	0	1	53	217	414		
	HDD65	5262	925	816	664	406	239	68	26	35	155	395	655	878		
	CDD50	2409	1	1	10	102	248	460	581	554	315	123	13	1		
	CDD65	375	0	0	0	0	12	78	142	123	20	0	0	0		
	CDH74	3699	0	0	0	29	206	810	1420	1067	164	3	0	0		
	CDH80	1254	0	0	0	3	36	263	547	376	29	0	0	0		
(14) Wind	WSAvg	2.3	2.7	2.5	2.6	2.3	2.4	2.3	2.3	2.0	1.9	1.8	2.2	2.6		
(15) Precipitation	PrecAvg	52.2	4.6	4.3	3.9	3.6	4.5	4.4	4.5	4.2	3.6	4.2	4.7	5.6		
	PrecMax	71.9	11.7	11.3	14.0	7.4	7.7	8.4	8.7	9.4	7.2	8.7	11.5	13.0		
	PrecMin	37.3	0.6	0.9	0.8	0.2	1.4	1.7	1.2	0.7	1.4	0.2	0.2	0.0		
	PrecStd	8.7	2.9	2.8	2.9	1.9	1.7	1.8	1.8	1.7	1.6	2.1	2.7	3.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	60.0	68.3	78.7	85.4	91.6	95.2	92.9	83.5	72.3	63.7	54.6		
		MCWB	49.7	48.9	52.5	59.9	65.9	71.2	70.2	69.2	66.6	61.2	55.4	49.7		
	2%	DB	50.1	53.9	64.7	73.6	79.1	86.8	90.5	88.5	79.0	68.1	58.8	51.0		
		MCWB	46.0	46.0	50.9	56.2	62.4	69.0	68.8	69.6	65.5	59.7	53.5	47.7		
	5%	DB	46.5	49.6	60.1	70.2	75.7	82.6	86.2	84.3	74.5	64.4	55.0	47.9		
		MCWB	43.7	44.5	49.3	56.0	60.8	67.4	67.7	68.9	63.7	58.2	51.2	45.0		
	10%	DB	43.8	45.5	55.5	65.8	71.4	78.5	81.9	80.1	70.9	61.1	51.7	45.2		
		MCWB	41.7	41.8	47.5	53.9	59.5	65.4	66.5	67.3	62.1	57.1	49.0	42.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	50.7	54.5	60.4	67.3	74.1	73.2	73.6	68.9	63.4	56.8	50.3		
		MCDB	54.0	57.0	64.3	74.8	78.9	87.2	87.2	84.4	79.0	69.1	61.3	52.7		
	2%	WB	46.6	47.0	52.0	58.1	64.8	70.8	71.0	71.3	66.6	61.1	54.2	48.1		
		MCDB	49.0	52.5	61.5	70.5	74.9	83.1	83.6	83.0	75.3	65.5	58.0	50.9		
	5%	WB	44.1	44.5	50.0	56.2	62.4	68.5	69.5	69.8	65.0	59.4	51.7	45.6		
		MCDB	46.3	49.0	58.7	67.7	71.5	79.0	81.5	81.2	72.2	62.9	54.7	47.5		
	10%	WB	41.9	41.9	48.0	54.4	60.3	66.6	67.9	68.2	63.2	57.7	49.4	43.1		
		MCDB	43.7	45.2	54.6	64.5	69.1	76.0	78.8	78.1	68.9	60.6	51.4	44.9		
(35) Mean Daily Temperature Range	MDBR		8.8	12.6	18.7	20.9	19.5	19.7	20.5	19.9	18.2	14.4	10.0	8.6		
	5% DB	MCDBR	13.4	21.0	28.9	30.5	28.1	28.0	29.5	27.4	24.3	19.4	15.4	12.5		
		MCWBR	9.9	13.5	16.1	14.4	12.4	11.7	9.8	10.4	11.7	11.5	9.9	9.7		
	5% WB	MCDBR	12.9	19.4	25.1	27.9	24.3	25.6	25.4	24.5	21.4	17.4	14.4	12.0		
		MCWBR	9.8	13.1	14.3	13.7	11.3	11.4	9.7	10.1	10.7	10.9	10.0	9.8		
(40) Clear-Sky Solar Irradiance	taub		0.310	0.338	0.375	0.406	0.418	0.422	0.423	0.415	0.390	0.368	0.332	0.306		
	taud		2.431	2.344	2.282	2.228	2.237	2.273	2.265	2.300	2.349	2.386	2.437	2.434		
	Ebn at Noon		245	259	266	268	269	268	266	262	258	245	233	231		
	Edh at Noon		21	29	36	41	43	41	41	38	33	27	21	19		
(44) All-Sky Solar Radiation	RadAvg		351	613	999	1371	1590	1837	1764	1538	1154	721	393	287		
	RadStd		41	89	140	198	160	169	161	155	117	75	47	48		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (114 neighbors)	N/A	N/A	N/A	+1.31	+0.76	+0.59	N/A	N/A	+101	+27

Nomenclature: See separate page