

SCHUEPFHEIM, Switzerland

WMO: 066510

Lat: 46.947N

Lon: 8.012E

Elev: 2440

StdP: 13.45

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.7	15.4	5.1	7.8	9.9	12.1	11.1	16.2	18.3	31.5	16.6	31.8	6.6	30	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	84.4	67.5	80.9	66.3	77.6	64.9	69.1	81.5	67.3	78.6	65.7	75.7	7.4	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	100.3	74.8	63.2	95.0	72.5	61.8	90.4	70.7	34.7	81.8	33.2	78.7	31.9	75.9	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	13.7	11.9	DB	4.4	88.7	5.6	2.7	0.4	90.7	-2.9	92.2	-6.0	93.8	-10.1	95.7	(4)
(5)			WB	3.0	71.8	5.2	1.9	-0.7	73.1	-3.8	74.2	-6.7	75.3	-10.5	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	32.3	31.7	39.7	46.4	52.5	60.7	63.9	63.1	56.3	49.1	39.8	34.9
	DBStd	13.14	7.72	8.85	6.46	6.52	6.55	6.08	5.49	5.52	5.56	6.47	6.99	6.67
	HDD50	2460	548	513	320	144	50	1	0	0	10	95	310	469
	HDD65	6468	1012	932	784	559	389	157	86	104	263	493	755	934
	CDD50	1595	1	0	1	35	127	323	430	407	199	67	5	0
	CDD65	129	0	0	0	0	1	29	51	46	2	0	0	0
	CDH74	1557	0	0	0	3	30	390	606	482	45	1	0	0
	CDH80	356	0	0	0	0	1	103	153	99	0	0	0	0
Wind	WSAvg	4.7	5.1	5.1	5.3	5.0	5.1	4.9	4.7	4.2	4.4	4.1	4.2	4.8
Precipitation	PrecAvg	61.5	3.7	3.9	4.1	4.6	6.5	6.7	7.0	6.8	4.8	4.2	4.4	4.5
	PrecMax	76.8	9.4	11.2	9.4	9.2	10.9	10.6	13.5	15.5	9.4	7.2	10.3	10.7
	PrecMin	47.6	0.3	1.3	1.7	1.3	1.5	3.6	2.8	1.6	2.1	0.2	0.0	0.2
	PrecStd	7.4	2.3	2.5	2.0	1.9	2.6	1.7	2.6	2.8	1.7	1.7	2.3	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	58.1	64.0	72.6	77.7	87.7	88.9	86.4	78.1	70.1	62.1	53.0
		MCWB	48.1	46.1	50.3	57.2	62.3	68.9	68.7	68.4	64.7	58.6	52.1	46.1
	2%	DB	48.6	51.6	60.1	68.3	73.4	83.4	84.5	82.8	75.1	66.9	57.9	50.0
		MCWB	43.7	44.2	48.7	54.8	60.3	67.9	66.7	67.6	63.6	56.9	50.7	45.1
	5%	DB	45.4	47.0	56.4	65.3	69.8	78.7	80.9	79.5	71.4	63.0	53.5	47.8
		MCWB	41.7	42.0	46.9	53.3	57.7	65.2	65.5	66.8	61.8	55.5	48.5	43.7
	10%	DB	42.0	42.7	52.2	60.9	66.2	74.2	77.0	76.1	67.7	59.3	50.0	44.6
		MCWB	39.3	38.9	44.8	50.6	56.1	63.2	64.2	65.6	59.9	54.3	46.4	41.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	47.5	51.9	58.0	63.8	72.2	70.0	70.9	66.5	61.0	53.6	48.6
		MCDB	53.0	53.4	60.8	69.9	75.5	85.1	85.0	81.6	74.4	67.6	60.3	50.0
	2%	WB	44.9	44.2	49.2	55.5	61.5	68.9	68.1	69.0	64.2	58.1	51.1	45.9
		MCDB	48.4	50.3	58.8	66.9	70.7	81.1	81.5	80.3	72.8	64.1	56.5	49.2
	5%	WB	41.9	41.5	47.3	53.5	58.7	66.4	66.4	67.4	62.5	56.4	49.2	44.1
		MCDB	44.9	46.4	55.7	63.4	66.0	77.4	78.5	77.8	70.2	61.3	52.7	47.4
	10%	WB	39.7	39.0	45.3	51.1	56.7	64.2	64.7	65.7	60.8	54.8	46.8	41.5
		MCDB	41.8	42.6	51.6	58.8	64.6	72.7	74.7	74.7	66.7	58.6	49.6	44.3
Mean Daily Temperature Range	5% DB	MDBR	11.7	13.6	17.5	19.5	18.4	18.8	19.3	19.4	17.7	16.1	13.4	13.0
		MCDBR	14.8	21.2	26.3	28.5	25.2	26.6	27.1	25.3	23.5	22.6	19.4	16.8
		MCWBR	10.9	13.8	16.5	16.2	13.1	13.1	12.0	12.5	12.8	13.8	12.7	11.6
	5% WB	MCDBR	14.0	19.6	24.5	26.4	22.7	24.5	24.6	23.8	21.6	19.8	17.9	15.3
		MCWBR	10.7	13.4	15.4	15.4	12.6	12.5	11.9	12.4	12.6	12.6	12.2	11.0
Clear-Sky Solar Irradiance	taub		0.279	0.308	0.351	0.391	0.408	0.411	0.413	0.401	0.374	0.346	0.309	0.277
	taud		2.385	2.314	2.261	2.212	2.224	2.264	2.256	2.301	2.360	2.415	2.445	2.404
	Ebn at Noon		259	272	275	273	272	271	269	267	265	255	245	246
	Edh at Noon		22	30	36	42	43	42	42	38	33	27	21	19
All-Sky Solar Radiation	RadAvg		420	699	1078	1390	1567	1839	1798	1565	1204	775	442	344
	RadStd		50	95	155	208	151	169	159	147	115	82	59	53

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (121 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+1.31	+0.72	+0.56	N/A	N/A	+104	+29

Nomenclature: See separate page