

WAEDENSWIL, Switzerland

WMO: 066730

Lat: 47.2208N

Lon: 8.6778E

Elev: 487

StdP: 95.62

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.6	(c) -5.8	(d) -12.2	(e) 1.4	(f) -6.8	(g) -9.7	(h) 1.7	(i) -4.7	(j) 9.6	(k) 6.0	(l) 8.4	(m) 5.6	(n) 2.8	(o) 30	(p) 0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.1	(c) 30.1	(d) 19.8	(e) 28.1	(f) 19.2	(g) 26.4	(h) 18.5	(i) 20.8	(j) 27.8	(k) 19.9	(l) 26.5	(m) 19.2	(n) 25.0	(o) 2.0	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	14.0	23.5	17.6	13.4	22.7	17.0	12.9	22.0	62.0	28.0	59.1	26.6	56.5	25.1	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.8	(b) 6.3	(c) 5.1	(e) -9.3	(f) 32.7	(g) 2.3	(h) 1.3	(i) -11.0	(j) 33.7	(k) -12.3	(l) 34.4	(m) -13.6	(n) 35.2	(o) -15.3	(p) 36.1		
(a) 7.8	(b) 6.3	(c) 5.1	(e) -10.2	(f) 22.4	(g) 2.3	(h) 0.8	(i) -11.9	(j) 23.0	(k) -13.3	(l) 23.5	(m) -14.6	(n) 23.9	(o) -16.2	(p) 24.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	1.2	1.9	6.1	10.6	14.1	18.5	20.0	19.3	15.2	11.1	5.7	2.0	(6)
(7)		DBStd	7.67	4.06	4.14	4.12	3.96	3.78	3.78	3.27	3.29	3.22	3.50	3.50	3.56	(7)
(8)		HDD10.0	1097	273	228	131	41	7	1	0	0	2	31	134	249	(8)
(9)		HDD18.3	3051	531	461	380	233	138	45	21	28	102	226	379	507	(9)
(10)		CDD10.0	1282	1	1	9	58	136	254	308	287	158	63	6	0	(10)
(11)		CDD18.3	195	0	0	0	0	8	49	72	57	9	0	0	0	(11)
(12)		CDH23.3	1312	0	0	0	7	67	358	486	358	36	0	0	0	(12)
(13)		CDH26.7	341	0	0	0	1	8	96	137	97	1	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.9	1.9	2.0	1.9	2.0	1.8	1.7	1.6	1.6	1.5	1.7	1.8	(14)
(15)	Precipitation	PrecAvg	1632	86	97	104	116	173	193	196	194	140	108	115	110	(15)
(16)		PrecMax	2026	185	254	222	261	330	291	360	352	286	199	294	253	(16)
(17)		PrecMin	1286	7	38	35	19	25	103	80	43	53	10	0	0	(17)
(18)		PrecStd	176	49	52	50	55	73	51	73	73	51	45	62	60	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	13.4	18.8	24.2	27.8	31.9	32.3	31.9	26.2	21.1	16.8	11.5	(19)
(20)			MCWB	9.4	8.0	10.6	13.8	17.2	20.6	20.5	20.2	18.6	15.5	11.5	8.2	(20)
(21)		2%	DB	10.1	10.9	16.3	21.7	25.3	29.3	30.1	29.3	24.4	18.8	13.7	9.4	(21)
(22)			MCWB	6.8	6.4	9.6	12.6	16.0	19.5	19.7	20.0	17.8	14.4	10.4	7.2	(22)
(23)		5%	DB	8.1	9.0	14.3	19.7	23.0	27.3	28.0	27.1	22.1	17.2	11.6	7.9	(23)
(24)			MCWB	5.9	5.5	8.7	11.8	14.9	18.8	19.2	19.5	16.8	13.7	9.4	6.3	(24)
(25)		10%	DB	6.4	7.2	12.3	17.4	20.9	25.2	26.1	25.0	20.3	15.7	10.3	6.7	(25)
(26)			MCWB	4.6	4.4	7.8	10.7	14.2	18.0	18.6	18.7	16.1	13.1	8.4	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	8.8	11.4	14.6	18.2	21.8	21.8	21.7	19.6	16.2	11.8	8.8	(27)
(28)			MCDWB	12.9	12.6	16.8	22.5	25.5	29.9	30.1	28.7	24.8	19.2	14.6	10.9	(28)
(29)		2%	WB	7.4	7.1	10.2	13.3	16.9	20.4	20.6	20.7	18.3	15.2	10.7	7.5	(29)
(30)			MCDWB	9.5	10.3	15.0	20.3	23.5	27.4	27.9	27.4	23.1	17.8	13.0	9.1	(30)
(31)		5%	WB	5.9	5.8	9.2	12.2	15.8	19.4	19.7	19.8	17.3	14.1	9.7	6.5	(31)
(32)			MCDWB	7.8	8.4	13.4	18.5	21.1	25.7	26.3	25.9	21.4	16.6	11.7	7.9	(32)
(33)		10%	WB	4.7	4.6	8.1	11.2	14.7	18.5	19.0	19.0	16.4	13.3	8.6	5.4	(33)
(34)			MCDWB	6.3	6.9	12.0	16.5	19.8	24.1	24.9	24.2	19.6	15.4	10.2	6.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.6	7.8	9.1	8.9	9.1	8.6	7.6	6.3	4.7	4.0	(35)	
(36)			MCDBR	6.7	8.9	11.2	12.7	12.6	12.5	12.3	11.9	10.3	8.5	7.2	5.7	(36)
(37)			MCWBR	4.7	5.5	6.2	6.2	5.8	5.2	5.1	5.1	5.1	4.9	4.6	4.1	(37)
(38)		5% WB	MCDBR	6.4	8.2	10.3	11.8	11.1	11.3	11.1	11.0	9.5	7.6	6.8	5.5	(38)
(39)			MCWBR	4.7	5.3	5.8	6.0	5.3	5.0	4.8	4.9	4.7	4.6	4.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.309	0.348	0.388	0.404	0.411	0.413	0.404	0.375	0.345	0.311	0.280	(40)	
(41)		taud	2.403	2.343	2.313	2.258	2.268	2.296	2.285	2.327	2.387	2.455	2.478	2.425	(41)	
(42)		Ebn at Noon	809	855	869	864	861	855	847	840	832	806	770	769	(42)	
(43)		Edh at Noon	68	90	108	126	130	127	127	117	100	81	64	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.27	2.14	3.35	4.36	4.94	5.70	5.55	4.84	3.66	2.34	1.34	1.05	(44)	
(45)		RadStd	0.14	0.28	0.46	0.65	0.50	0.53	0.50	0.48	0.37	0.26	0.17	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	N/A
(47) Regional (121 neighbors)		N/A	N/A	N/A	+0.70	+0.41	+0.33	N/A	N/A	+57	+16

Nomenclature: See separate page