

AADORF-TAENIKON, Switzerland

WMO: 066790

Lat: 47.4800N

Lon: 8.9050E

Elev: 540

StdP: 95.01

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.7	-8.2	-13.5	1.2	-10.3	-10.6	1.6	-7.3	8.7	7.6	7.7	7.4	1.6	60	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	30.1	19.9	28.2	19.2	26.4	18.5	20.8	27.8	19.9	26.5	19.1	25.1	2.1	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	14.1	24.1	17.5	13.4	22.9	16.8	12.7	21.8	62.4	27.9	59.1	26.7	56.3	25.1	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	5.6	4.7	-14.7	33.1	3.2	2.3	-17.0	34.7	-18.9	36.1	-20.7	37.3	-23.1	39.0		
			-15.1	22.7	3.1	0.9	-17.4	23.3	-19.2	23.8	-21.0	24.3	-23.2	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	0.5	0.7	4.9	9.2	13.2	17.4	18.8	18.3	14.1	9.9	4.6	1.1
	DBStd	7.69	4.61	4.78	4.11	3.63	3.80	3.54	3.06	3.13	3.27	3.77	3.79	4.13
	HDD10.0	1283	296	259	162	58	12	1	0	0	5	48	167	275
	HDD18.3	3376	554	493	417	276	165	60	32	41	131	261	413	533
	CDD10.0	1076	1	1	4	33	111	221	273	256	128	46	4	0
	CDD18.3	126	0	0	0	0	6	31	47	39	4	0	0	0
	CDH23.3	1272	0	0	0	6	88	324	464	351	39	0	0	0
	CDH26.7	352	0	0	0	1	24	85	136	104	2	0	0	0
Wind	WSAvg	1.6	1.9	1.9	1.9	1.6	1.7	1.5	1.5	1.4	1.3	1.3	1.6	1.8
Precipitation	PrecAvg	1333	79	82	89	96	144	151	150	147	109	92	96	99
	PrecMax	1693	190	210	242	192	293	243	283	260	229	172	213	219
	PrecMin	1052	6	25	25	13	32	61	59	21	50	3	0	0
	PrecStd	167	49	44	48	47	63	46	61	58	45	44	53	53
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	14.2	19.0	23.8	29.4	31.6	32.5	32.5	26.4	21.5	16.5	12.0
		MCWB	8.5	8.2	10.8	13.8	17.4	20.7	20.2	19.7	18.4	15.4	11.6	8.4
	2%	DB	10.6	11.4	16.3	21.4	25.5	29.1	30.1	29.5	24.5	19.4	14.0	10.3
		MCWB	7.6	6.9	9.6	12.9	16.5	19.8	19.8	19.9	17.7	14.6	10.5	7.9
	5%	DB	9.0	9.5	14.1	19.2	23.1	27.1	28.0	27.2	22.2	17.5	12.0	8.8
		MCWB	6.2	6.0	8.7	12.0	15.1	18.8	19.2	19.3	16.7	13.7	9.4	6.7
	10%	DB	7.0	7.4	12.0	17.0	20.7	24.9	25.9	24.9	20.1	15.7	10.2	7.2
		MCWB	5.0	4.9	7.7	11.0	14.3	18.0	18.4	18.5	15.8	12.9	8.2	5.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	8.7	11.5	14.6	18.7	22.3	21.9	21.7	19.6	16.6	12.2	9.3
		MCDB	11.9	13.0	17.0	22.2	26.1	29.7	29.7	28.6	24.7	20.0	15.1	10.9
	2%	WB	7.8	7.4	10.2	13.4	17.2	20.5	20.6	20.5	18.4	15.2	10.9	8.1
		MCDB	10.1	10.8	14.8	20.3	24.0	27.2	27.9	27.4	23.0	18.3	13.5	10.0
	5%	WB	6.4	6.2	9.2	12.3	16.0	19.4	19.7	19.7	17.2	14.1	9.7	6.9
		MCDB	8.6	9.1	13.3	18.4	21.7	25.6	26.5	26.0	21.5	16.8	11.7	8.7
	10%	WB	5.1	4.9	8.1	11.2	14.7	18.3	18.8	18.8	16.1	13.1	8.4	5.6
		MCDB	7.0	7.4	11.7	16.1	19.7	24.1	24.9	24.2	19.5	15.3	10.0	7.1
Mean Daily Temperature Range	5% DB	MDBR	5.6	7.3	9.6	11.3	10.5	10.7	10.9	10.4	9.5	8.1	6.1	5.4
		MCDBR	7.6	10.9	14.2	16.3	15.5	14.8	15.1	14.6	12.9	11.1	9.2	7.3
		MCWBR	5.2	7.0	8.5	8.9	7.7	6.9	6.5	6.5	7.0	6.9	6.2	5.3
	5% WB	MCDBR	7.0	10.1	12.6	14.9	13.3	13.5	13.6	13.4	11.8	10.3	8.5	6.7
		MCWBR	5.2	6.8	7.8	8.2	6.9	6.5	6.2	6.3	6.7	6.8	6.0	5.2
Clear-Sky Solar Irradiance	taub	0.288	0.312	0.347	0.383	0.396	0.402	0.404	0.396	0.370	0.342	0.311	0.283	
	taud	2.455	2.390	2.359	2.289	2.291	2.314	2.302	2.338	2.393	2.461	2.495	2.461	
	Ebn at Noon	805	853	871	869	868	863	855	846	836	807	768	765	
	Edh at Noon	65	86	103	122	127	125	125	115	99	80	63	58	
All-Sky Solar Radiation	RadAvg	1.14	1.98	3.19	4.33	5.00	5.73	5.53	4.83	3.62	2.27	1.26	0.94	
	RadStd	0.12	0.27	0.43	0.62	0.50	0.53	0.51	0.50	0.37	0.24	0.15	0.14	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	
(47)	Regional (117 neighbors)	N/A	N/A	N/A	+0.71	+0.42	+0.34	N/A	N/A	+57	+16	

Nomenclature: See separate page