

GENEVA COINTRIN, Switzerland

WMO: 067000

Lat: 46.2475N

Lon: 6.1278E

Elev: 1411

StdP: 13.96

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	24.5	13.3	11.4	25.8	16.3	13.2	27.7	26.1	33.8	21.7	38.4	6.3	260	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	88.6	67.6	85.1	66.5	81.9	65.5	69.2	83.7	67.9	81.2	66.6	78.7	8.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	96.4	73.3	63.4	92.1	72.2	62.3	88.5	71.4	34.1	83.8	33.0	81.5	32.0	79.0	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	17.4	14.8	DB	17.1	93.5	4.0	3.7	14.2	96.1	11.9	98.3	9.7	100.4	6.8	103.1	(4)
(5)			WB	15.7	71.7	3.9	1.3	12.9	72.6	10.6	73.4	8.4	74.1	5.6	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	35.9	37.8	44.6	51.1	58.6	65.7	69.3	68.3	60.7	53.3	43.1	37.2	(6)
(7)		DBStd	13.32	6.21	6.40	6.25	6.17	5.91	6.44	5.73	5.57	5.73	5.94	6.13	6.20	(7)
(8)		HDD50	1686	437	343	187	60	6	0	0	0	2	37	218	396	(8)
(9)		HDD65	5083	902	763	633	416	211	69	24	30	152	365	657	861	(9)
(10)		CDD50	2493	1	0	19	94	272	471	598	566	323	137	11	1	(10)
(11)		CDD65	417	0	0	0	0	13	91	158	131	24	0	0	0	(11)
(12)		CDH74	3628	0	0	0	12	149	827	1392	1091	153	4	0	0	(12)
(13)		CDH80	1105	0	0	0	0	24	241	464	359	17	0	0	0	(13)
(14)	Wind	WSAvg	5.1	5.2	5.7	6.0	5.8	5.1	5.2	4.8	4.3	4.6	4.2	4.8	5.3	(14)
(15)	Precipitation	PrecAvg	36.9	3.0	2.8	2.7	2.6	3.0	3.3	3.0	3.2	3.5	3.3	3.6	3.2	(15)
(16)		PrecMax	54.2	7.8	7.5	11.1	5.7	7.5	7.7	6.9	9.7	10.7	8.4	11.6	7.8	(16)
(17)		PrecMin	21.7	0.3	0.0	0.2	0.1	0.2	0.1	0.4	0.2	0.2	0.1	0.2	0.0	(17)
(18)		PrecStd	6.9	1.8	1.8	1.9	1.5	1.4	1.7	1.6	1.9	2.6	2.0	2.2	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	59.0	67.8	75.8	83.1	90.7	93.5	93.4	82.6	73.3	62.5	55.6	(19)
(20)			MCWB	48.2	47.6	52.5	57.4	63.5	68.7	68.4	68.1	65.1	60.1	53.6	49.4	(20)
(21)		2%	DB	51.2	54.4	63.0	70.9	78.1	86.2	88.9	87.8	78.6	68.7	58.0	51.8	(21)
(22)			MCWB	46.3	46.2	50.2	55.1	61.3	66.9	67.3	67.2	64.1	58.9	51.8	47.4	(22)
(23)		5%	DB	48.2	50.9	59.2	67.3	74.2	82.6	85.2	84.0	74.9	65.4	54.7	49.2	(23)
(24)			MCWB	44.1	44.4	48.7	53.3	59.6	65.6	66.5	66.6	62.3	57.8	50.1	45.6	(24)
(25)		10%	DB	45.5	47.8	55.9	63.5	70.6	78.9	81.6	80.2	71.3	62.5	52.0	46.6	(25)
(26)			MCWB	42.2	42.6	47.2	51.8	57.9	64.2	65.4	65.5	61.0	56.4	48.4	43.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	49.2	53.8	58.5	65.5	71.5	70.8	70.7	67.5	62.1	54.8	50.3	(27)
(28)			MCDWB	53.7	55.9	63.7	72.2	79.3	86.2	87.8	85.6	78.7	69.4	59.6	53.7	(28)
(29)		2%	WB	46.7	47.0	51.5	56.2	62.9	68.6	69.0	69.1	65.2	60.4	52.7	48.1	(29)
(30)			MCDWB	50.2	53.1	59.8	68.3	74.5	82.0	84.1	83.0	75.0	66.3	56.7	50.8	(30)
(31)		5%	WB	44.6	45.1	49.8	54.2	61.0	66.9	67.7	67.7	63.6	58.8	50.8	45.8	(31)
(32)			MCDWB	48.0	50.2	57.7	64.9	71.2	79.1	81.3	80.5	72.4	64.2	54.1	48.7	(32)
(33)		10%	WB	42.3	43.1	48.0	52.6	59.1	65.2	66.4	66.3	62.0	57.1	48.9	43.8	(33)
(34)			MCDWB	45.1	47.3	55.1	62.1	68.1	76.5	78.7	77.7	69.6	61.6	51.8	46.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.7	13.2	16.9	18.0	18.3	19.4	20.2	19.9	17.3	14.1	11.2	9.5	(35)
(36)			MCDBR	14.1	19.6	23.4	25.3	25.4	25.4	26.3	26.2	22.4	18.6	15.3	13.3	(36)
(37)			MCWBR	10.0	12.6	13.0	11.9	11.3	10.0	9.0	9.6	9.9	10.2	9.9	9.6	(37)
(38)		5% WB	MCDWB	13.3	17.4	20.9	23.1	22.2	23.2	23.2	23.5	19.6	16.7	13.9	11.7	(38)
(39)			MCWBR	9.8	11.8	12.1	11.2	10.4	9.6	8.7	9.3	9.0	9.4	9.5	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.315	0.351	0.388	0.397	0.397	0.394	0.386	0.368	0.351	0.318	0.290	(40)	
(41)		taud	2.449	2.397	2.359	2.285	2.305	2.341	2.343	2.376	2.410	2.451	2.488	2.468	(41)	
(42)		Ebn at Noon	259	273	277	275	276	276	275	273	268	256	246	246	(42)	
(43)		Edh at Noon	22	28	33	39	40	39	38	36	31	26	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	427	700	1074	1403	1616	1918	1888	1641	1276	815	457	351	(44)	
(45)		RadStd	49	99	145	191	148	169	158	134	104	82	57	53	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+0.81	+0.65	N/A	N/A	N/A	N/A	(46)
(47)	Regional (74 neighbors)	N/A	N/A	N/A	N/A	+0.61	+0.41	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page