

LA DOLE, Switzerland

WMO: 067020

Lat: 46.4247N

Lon: 6.0994E

Elev: 5480

StdP: 12.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.0	11.4	-12.0	3.5	28.5	-5.0	5.1	27.5	53.1	27.5	49.7	23.2	23.1	80	0.921

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	70.6	58.6	67.8	57.3	65.0	56.2	60.8	67.7	59.0	65.4	57.2	63.2	11.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.1	88.6	64.5	56.3	83.0	62.4	54.6	77.9	60.5	29.7	67.7	28.3	65.4	27.1	63.3	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.4	40.4	34.8	5.5	74.2	5.1	3.8	1.8	76.9	-1.2	79.2	-4.1	81.3	-7.8	84.0
			4.6	64.4	5.2	1.9	0.9	65.7	-2.2	66.9	-5.1	67.9	-8.9	69.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.0	27.4	27.1	31.3	36.6	44.0	50.8	53.9	54.3	47.9	43.0	33.6	29.5	(6)
	DBStd	12.50	7.32	8.70	7.85	7.88	7.51	7.78	6.91	7.12	7.03	7.64	8.39	7.99	(7)
	HDD50	4184	700	642	579	406	215	85	39	36	120	234	492	636	(8)
	HDD65	9125	1165	1062	1044	851	651	430	348	338	513	681	941	1101	(9)
	CDD50	548	0	0	0	4	28	108	161	170	58	18	1	0	(10)
	CDD65	14	0	0	0	0	0	3	4	7	0	0	0	0	(11)
	CDH74	28	0	0	0	0	0	8	7	13	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
	WSAvg	16.8	20.2	20.1	18.8	15.7	15.3	14.1	14.0	13.3	14.3	15.9	19.2	20.6	(14)
	PrecAvg	50.3	3.9	3.6	3.5	3.9	4.2	4.1	4.2	4.2	4.4	4.8	4.8	4.7	(15)
(16) Precipitation	PrecMax	63.3	10.0	10.4	13.3	7.0	7.1	8.0	8.3	9.5	11.7	9.3	13.0	11.1	(16)
	PrecMin	37.8	0.6	0.3	0.6	1.1	1.1	1.5	1.8	0.4	1.5	0.6	0.7	0.1	(17)
	PrecStd	6.9	2.3	2.4	2.6	1.9	1.7	1.9	1.7	1.9	2.7	2.3	2.8	2.4	(18)
	PrecStd	6.9	2.3	2.4	2.6	1.9	1.7	1.9	1.7	1.9	2.7	2.3	2.8	2.4	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	49.0	51.0	58.6	65.0	73.8	74.2	75.5	66.4	61.2	53.9	49.3	(19)
		MCWB	33.2	34.7	39.7	47.2	54.2	60.7	59.3	59.0	56.6	49.9	42.5	33.8	(20)
	2%	DB	43.2	45.0	47.8	54.4	61.1	69.0	69.9	70.5	62.8	57.9	50.1	45.4	(21)
		MCWB	32.3	33.8	38.6	44.7	51.7	58.2	58.3	58.2	54.8	47.6	40.5	34.0	(22)
	5%	DB	39.8	41.7	44.8	50.9	57.9	65.5	66.7	67.7	60.0	55.1	47.3	42.5	(23)
		MCWB	32.6	32.6	36.8	42.7	49.6	56.5	57.1	57.0	53.0	46.4	39.5	33.1	(24)
	10%	DB	37.0	38.3	42.2	47.7	54.8	62.4	64.0	64.7	57.4	52.8	44.6	39.7	(25)
		MCWB	31.8	31.5	35.5	40.9	48.0	54.9	56.0	56.2	51.4	45.8	38.8	33.2	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.8	38.2	42.6	48.6	55.9	63.6	62.8	62.9	59.4	52.4	45.9	40.2	(27)
		MCDB	40.0	42.5	48.0	56.3	62.7	71.1	69.8	70.4	64.0	57.3	49.6	42.1	(28)
	2%	WB	36.6	36.1	40.2	45.7	53.0	60.0	60.3	60.5	56.2	50.5	43.3	37.9	(29)
		MCDB	38.7	39.8	44.6	52.5	59.3	66.7	67.1	67.5	60.8	54.2	46.5	39.9	(30)
	5%	WB	34.8	34.4	38.5	43.6	50.9	57.6	58.5	58.5	54.2	48.9	41.8	36.5	(31)
		MCDB	37.0	38.5	42.8	49.5	56.5	63.6	64.8	65.0	58.6	52.7	45.0	38.7	(32)
	10%	WB	33.0	32.9	36.7	41.6	48.7	55.4	56.7	56.9	52.3	47.4	40.0	34.9	(33)
		MCDB	35.7	37.1	40.9	46.6	53.6	60.9	62.6	62.9	56.3	51.1	43.3	37.5	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.3	8.8	10.0	10.7	11.3	11.4	10.7	10.0	9.2	7.9	8.1	(35)
		MCDBR	9.8	11.1	11.1	13.6	13.5	13.9	13.9	12.8	12.3	11.0	10.2	10.5	(36)
		MCWBR	6.1	7.0	7.9	9.3	10.1	11.3	10.3	10.3	10.5	8.4	7.6	6.2	(37)
	5% WB	MCDBR	8.0	9.3	10.4	12.9	13.0	13.5	13.2	12.4	11.5	9.7	9.0	8.0	(38)
		MCWBR	7.1	7.4	8.1	9.3	10.4	11.6	10.7	10.7	10.2	8.2	8.0	6.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.245	0.262	0.287	0.313	0.321	0.323	0.321	0.316	0.302	0.290	0.265	0.244	(40)
	taud		2.528	2.509	2.507	2.454	2.465	2.483	2.477	2.504	2.531	2.565	2.579	2.540	(41)
	Ebn at Noon		282	297	301	300	300	298	297	296	292	281	271	270	(42)
	Edh at Noon		19	24	29	33	34	34	33	31	28	23	18	17	(43)
(44) All-Sky Solar Radiation	RadAvg		413	685	1062	1401	1614	1913	1869	1625	1266	807	447	338	(44)
	RadStd		48	100	146	195	149	174	160	138	104	78	54	52	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-3.65	+1.46	N/A	N/A	N/A	N/A	N/A	+5
(47) Regional (75 neighbors)	N/A	N/A	N/A	N/A	+0.61	+0.45	N/A	N/A	N/A	N/A

Nomenclature: See separate page