

NYON-CHANGINS, Switzerland

WMO: 067050

Lat: 46.4011N

Lon: 6.2278E

Elev: 432

StdP: 96.24

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-4.3	-11.7	1.4	-4.5	-9.4	1.8	-3.0	12.3	-1.4	10.4	2.1	4.0	340	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	30.4	19.7	28.5	19.3	26.8	18.7	20.7	28.1	20.0	26.8	19.2	25.6	3.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.8	24.0	17.5	13.2	23.2	16.8	12.6	22.4	61.8	28.4	59.0	27.1	56.4	25.7	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	10.3	8.5	7.1	DB	-8.6	33.1	2.3	2.1	-10.3	34.7	-11.6	35.9	-12.9	37.1	-14.5	38.7
(5)				WB	-9.7	22.4	2.3	0.9	-11.4	23.0	-12.8	23.5	-14.1	24.0	-15.8	24.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	2.0	2.7	6.6	10.7	14.0	18.7	20.4	19.7	15.8	11.6	6.2	2.6
	DBStd	7.39	3.62	3.70	3.60	3.46	3.35	3.43	3.13	3.17	3.01	3.29	3.24	3.42
	HDD10.0	977	247	206	113	32	5	0	0	0	1	23	121	229
	HDD18.3	2894	506	438	363	228	139	37	15	22	84	209	366	487
	CDD10.0	1331	1	0	9	54	129	261	323	300	176	73	5	0
	CDD18.3	207	0	0	0	0	5	48	81	63	10	0	0	0
	CDH23.3	1537	0	0	0	2	41	375	617	453	49	1	0	0
	CDH26.7	409	0	0	0	0	4	94	178	130	3	0	0	0
Wind	WSAvg	2.5	2.6	2.8	3.1	2.8	2.6	2.5	2.4	2.2	2.4	2.1	2.5	2.6
Precipitation	PrecAvg	1278	99	92	88	98	107	105	106	106	112	123	123	120
	PrecMax	1608	254	263	339	179	181	202	212	242	296	237	331	281
	PrecMin	959	15	7	14	28	28	39	45	11	37	15	17	2
	PrecStd	174	59	60	67	49	43	47	44	49	69	58	72	62
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	13.7	18.1	23.2	26.8	31.6	32.9	33.5	27.0	22.1	15.8	12.3
		MCWB	8.7	8.7	10.6	14.1	17.5	20.4	20.0	19.9	17.9	15.4	11.5	9.2
	2%	DB	10.3	11.0	16.0	20.8	24.3	29.3	30.6	29.8	24.8	19.6	13.8	10.0
		MCWB	7.9	7.0	9.5	12.9	16.3	19.9	19.5	19.6	17.7	14.7	10.7	8.2
	5%	DB	8.7	9.2	14.2	19.2	22.3	27.3	28.6	27.7	22.9	17.8	12.1	8.8
		MCWB	6.8	6.2	8.9	12.0	15.3	19.0	19.1	19.4	16.7	14.2	10.1	7.1
	10%	DB	7.2	7.7	12.5	17.3	20.4	25.4	26.7	25.7	21.2	16.3	10.8	7.5
		MCWB	5.6	5.3	8.1	11.2	14.3	18.1	18.5	18.5	16.0	13.4	8.9	6.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	9.1	11.5	14.9	18.6	22.1	21.5	21.6	19.7	16.5	12.3	9.7
		MCDB	11.3	12.4	16.0	21.5	24.9	29.5	29.8	29.0	24.8	20.0	14.5	11.1
	2%	WB	8.2	7.7	10.4	13.6	17.1	20.7	20.5	20.6	18.4	15.5	11.2	8.5
		MCDB	9.9	10.6	14.6	19.9	22.9	27.6	28.1	27.9	23.1	18.3	13.2	9.8
	5%	WB	6.9	6.5	9.5	12.5	16.0	19.6	19.8	19.7	17.4	14.6	10.3	7.3
		MCDB	8.7	8.9	13.3	18.2	21.0	26.0	26.8	26.4	21.8	17.1	11.9	8.7
	10%	WB	5.7	5.4	8.5	11.5	14.8	18.5	19.0	19.0	16.5	13.7	9.2	6.2
		MCDB	7.2	7.5	12.0	16.6	19.4	24.5	25.5	25.1	20.5	16.0	10.7	7.4
Mean Daily Temperature Range	5% DB	MDBR	4.8	6.0	7.8	9.2	9.2	10.0	10.2	9.8	8.6	6.9	5.3	4.6
		MCDBR	6.6	8.6	11.0	12.5	12.4	12.7	13.1	12.7	11.2	9.1	7.1	6.2
		MCWBR	4.8	5.8	6.3	6.7	6.6	5.9	5.4	5.6	5.6	5.5	5.0	4.8
	5% WB	MCDBR	6.5	7.8	9.7	11.5	11.3	11.9	11.8	11.8	9.6	8.1	6.5	5.6
		MCWBR	4.7	5.6	5.8	6.4	6.3	5.9	5.2	5.4	5.1	5.1	4.8	4.5
Clear-Sky Solar Irradiance	taub	0.292	0.316	0.352	0.389	0.398	0.399	0.396	0.388	0.369	0.352	0.318	0.291	
	taud	2.449	2.398	2.360	2.284	2.304	2.340	2.340	2.340	2.373	2.409	2.449	2.488	2.468
	Ebn at Noon	812	857	871	866	869	868	865	858	843	804	772	772	
	Edh at Noon	68	87	105	124	126	122	121	112	99	83	66	60	
All-Sky Solar Radiation	RadAvg	1.34	2.20	3.37	4.41	5.06	6.00	5.89	5.12	4.00	2.56	1.43	1.09	
	RadStd	0.15	0.32	0.47	0.61	0.46	0.55	0.50	0.44	0.33	0.26	0.18	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (80 neighbors)	N/A	N/A	N/A	N/A	+0.35	+0.25	N/A	N/A	N/A	N/A

Nomenclature: See separate page