

AIGLE, Switzerland

WMO: 067120

Lat: 46.3267N

Lon: 6.9244E

Elev: 1257

StdP: 14.04

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 17.9	(c) 22.5	(d) 12.3	(e) 10.8	(f) 22.5	(g) 16.1	(h) 13.0	(i) 26.0	(j) 23.4	(k) 43.0	(l) 20.2	(m) 42.9	(n) 3.2	(o) 180	(p) 0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.8	(c) 84.0	(d) 68.7	(e) 81.3	(f) 67.5	(g) 78.8	(h) 66.3	(i) 70.2	(j) 80.9	(k) 68.8	(l) 78.7	(m) 67.4	(n) 76.6	(o) 6.8	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	102.4	75.1	65.1	97.2	73.7	63.8	92.9	72.5	34.9	81.2	33.6	79.1	32.5	76.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.3	(b) 14.5	(c) 12.2	(e) 11.6	(f) 88.1	(g) 6.6	(h) 3.3	(i) 6.9	(j) 90.5	(k) 3.1	(l) 92.4	(m) -0.6	(n) 94.2	(o) -5.4	(p) 96.6		
(a) 18.3	(b) 14.5	(c) 12.2	(e) 11.0	(f) 73.6	(g) 6.5	(h) 1.8	(i) 6.3	(j) 74.8	(k) 2.5	(l) 75.9	(m) -1.1	(n) 76.9	(o) -5.8	(p) 78.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	35.2	37.2	44.0	50.6	57.9	64.4	67.5	66.5	59.1	52.1	42.6	36.7	(6)
(7)		DBStd	12.85	6.66	6.57	6.03	6.18	5.67	5.68	5.00	4.99	5.06	5.63	6.40	6.30	(7)
(8)		HDD50	1779	458	359	198	67	7	0	0	0	2	43	233	412	(8)
(9)		HDD65	5301	923	778	650	433	227	80	32	42	185	401	673	877	(9)
(10)		CDD50	2229	0	1	14	84	253	431	541	511	275	108	10	1	(10)
(11)		CDD65	277	0	0	0	1	9	61	109	88	9	0	0	0	(11)
(12)		CDH74	2006	0	0	0	6	66	464	827	598	44	1	0	0	(12)
(13)		CDH80	374	0	0	0	0	4	80	173	117	0	0	0	0	(13)
(14)	Wind	WSAvg	4.5	4.2	4.7	5.1	5.7	5.1	4.7	4.5	4.0	3.5	3.6	3.9	4.5	(14)
(15)	Precipitation	PrecAvg	51.5	3.6	3.4	3.2	3.8	4.9	5.1	5.4	5.1	4.4	4.3	4.2	4.2	(15)
(16)		PrecMax	63.1	9.6	8.4	11.1	6.6	9.0	11.3	13.2	9.7	8.8	8.8	8.9	9.4	(16)
(17)		PrecMin	41.9	0.8	0.8	1.1	0.8	1.5	2.3	2.2	0.8	2.0	0.6	0.0	0.0	(17)
(18)		PrecStd	6.6	2.1	2.1	2.1	1.8	2.2	2.1	2.2	2.1	1.8	1.9	2.3	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	57.6	64.4	73.7	79.2	85.5	88.2	87.6	78.4	70.1	64.3	55.9	(19)
(20)		0.4%	MCWB	45.3	46.6	52.1	56.8	63.7	69.2	69.1	70.2	66.3	59.5	50.9	45.8	(20)
(21)		2%	DB	49.2	52.4	60.5	69.4	75.6	82.3	84.3	83.1	74.9	66.7	57.6	50.2	(21)
(22)		2%	MCWB	43.9	45.2	50.3	55.2	62.0	68.2	68.4	68.9	64.7	58.5	50.6	45.7	(22)
(23)		5%	DB	46.4	49.4	57.6	66.2	72.3	79.3	81.5	80.1	71.9	64.0	54.3	47.7	(23)
(24)		5%	MCWB	42.5	43.5	48.7	53.8	60.1	66.2	67.5	67.5	63.1	57.1	49.8	44.2	(24)
(25)		10%	DB	44.1	46.5	54.5	62.8	69.2	76.2	78.8	77.2	69.1	61.3	51.7	45.5	(25)
(26)		10%	MCWB	40.9	42.0	47.3	52.2	58.8	64.7	66.4	66.4	61.5	55.9	48.2	42.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	48.3	53.5	58.7	66.2	71.6	71.9	72.3	68.0	61.7	53.9	48.5	(27)
(28)		0.4%	MCD B	51.4	53.7	61.1	69.7	76.0	83.0	83.2	83.0	75.6	66.8	58.7	52.0	(28)
(29)		2%	WB	44.8	46.1	51.5	56.4	63.6	69.3	70.0	70.2	65.7	59.9	51.8	46.4	(29)
(30)		2%	MCD B	47.9	51.3	58.5	67.2	73.0	79.8	81.0	80.5	72.9	64.6	55.7	48.9	(30)
(31)		5%	WB	42.9	44.2	49.6	54.7	61.6	67.5	68.6	68.5	63.9	58.3	50.2	44.7	(31)
(32)		5%	MCD B	45.8	48.7	56.0	64.4	69.9	77.3	78.7	77.9	70.5	62.6	54.2	47.5	(32)
(33)		10%	WB	41.1	42.2	47.8	53.0	59.7	65.8	67.3	67.0	62.3	56.5	48.4	42.7	(33)
(34)		10%	MCD B	44.0	46.1	53.5	61.4	67.3	74.5	76.7	75.5	67.8	60.5	51.5	45.1	(34)
(35)	Mean Daily Temperature Range		MDBR	10.9	12.5	15.8	17.6	16.8	18.0	18.8	17.8	16.8	15.2	12.6	10.6	(35)
(36)		5% DB	MCD BR	12.8	16.4	20.3	23.4	22.2	22.8	23.6	22.6	20.0	18.1	15.5	12.3	(36)
(37)		5% DB	MCWBR	8.7	10.8	11.9	12.2	11.4	11.4	10.8	11.2	11.2	11.1	10.0	8.4	(37)
(38)		5% WB	MCD BR	12.1	15.3	18.5	21.8	19.9	20.8	20.9	20.4	18.5	16.1	14.2	11.6	(38)
(39)		5% WB	MCWBR	8.7	10.6	11.3	11.9	10.8	11.0	10.4	10.7	10.8	10.4	9.6	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.311	0.357	0.400	0.416	0.416	0.413	0.401	0.379	0.355	0.317	0.283	(40)	
(41)		taud	2.358	2.290	2.240	2.208	2.231	2.283	2.287	2.331	2.379	2.426	2.451	2.403	(41)	
(42)		Ebn at Noon	259	272	273	271	270	270	269	268	264	254	245	246	(42)	
(43)		Edh at Noon	23	30	37	43	43	41	40	37	32	27	22	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	453	730	1083	1389	1584	1883	1870	1629	1277	829	472	371	(44)	
(45)		RadStd	51	101	151	191	135	172	156	139	108	88	65	56	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) +1.30	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (98 neighbors)	N/A	N/A	N/A	N/A	+0.70	+0.52	N/A	N/A	+103 +34	(47)

Nomenclature: See separate page