

EVOLINE-VILLAZ, Switzerland

WMO: 067220

Lat: 46.1122N

Lon: 7.5086E

Elev: 1828

StdP: 81.21

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.8	-11.9	-26.4	0.4	-10.0	-23.2	0.6	-8.6	6.6	-2.2	5.1	-1.1	1.3	40	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	22.5	13.2	20.9	12.7	19.4	12.1	14.1	20.6	13.4	19.4	12.7	18.2	3.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	10.6	15.8	10.8	10.1	15.5	10.1	9.6	15.2	45.7	20.7	43.5	19.6	41.5	18.3	17.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.6	3.9	DB	-15.8	25.1	2.9	1.8	-17.9	26.4	-19.6	27.5	-21.2	28.5	-23.3	29.7	(4)
(5)			WB	-17.1	15.7	2.3	0.6	-18.8	16.2	-20.2	16.6	-21.5	16.9	-23.2	17.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-2.9	-3.0	0.2	4.1	7.1	11.7	13.3	12.9	9.5	6.7	1.5	-1.2	(6)	
	DBStd	7.14	4.39	4.92	4.48	4.01	3.91	3.91	3.50	3.72	3.56	4.17	4.70	4.49	(7)	
	HDD10.0	2174	399	366	302	179	107	27	12	15	50	114	257	347	(8)	
	HDD18.3	4861	657	599	561	427	349	201	158	173	264	361	507	606	(9)	
	CDD10.0	362	0	0	0	2	16	77	115	104	36	11	1	0	(10)	
	CDD18.3	7	0	0	0	0	0	2	2	3	0	0	0	0	(11)	
	CDH23.3	28	0	0	0	0	0	8	9	11	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	1.5	1.2	1.2	1.5	1.9	1.8	1.8	1.7	1.6	1.4	1.3	1.2	1.2	(14)	
(15) Precipitation	PrecAvg	706	51	48	48	49	71	67	67	68	51	56	67	62	(15)	
	PrecMax	920	147	205	113	98	161	130	154	143	155	167	186	158	(16)	
	PrecMin	439	10	2	14	3	23	30	21	26	14	5	17	5	(17)	
	PrecStd	115	35	46	26	26	42	27	26	29	32	37	43	38	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	9.5	11.7	15.8	19.4	24.2	24.5	24.9	19.9	17.3	12.6	8.9	(19)	
		MCWB	1.7	2.0	3.8	7.0	10.7	13.5	14.0	13.3	11.8	8.8	4.8	1.6	(20)	
	2%	DB	6.2	7.1	9.7	13.7	16.9	21.8	22.3	22.1	18.2	15.0	10.4	6.9	(21)	
		MCWB	0.6	0.6	2.7	5.9	9.2	13.0	13.1	13.3	11.0	7.7	3.8	0.9	(22)	
	5%	DB	4.7	5.0	8.0	11.7	15.0	19.9	20.7	20.2	16.4	13.5	8.7	5.6	(23)	
		MCWB	-0.1	-0.2	1.9	5.1	8.3	12.3	12.7	12.6	10.3	7.1	3.2	0.1	(24)	
	10%	DB	3.2	3.2	6.3	10.0	13.1	18.0	19.1	18.6	14.7	12.0	7.3	4.4	(25)	
		MCWB	-0.8	-1.2	0.9	4.1	7.3	11.5	12.2	12.0	9.4	6.4	2.4	-0.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	2.8	4.9	7.7	11.4	14.7	14.9	15.1	12.9	10.1	6.3	3.2	(27)	
		MCDB	5.7	6.8	9.5	14.2	17.4	22.0	21.6	21.8	18.3	14.6	9.5	6.0	(28)	
	2%	WB	1.7	1.5	3.4	6.4	10.0	13.7	14.0	14.0	11.7	9.0	4.9	2.1	(29)	
		MCDB	4.7	5.5	7.9	12.5	15.8	20.2	20.6	20.1	16.7	13.0	8.7	5.2	(30)	
	5%	WB	0.6	0.3	2.4	5.4	8.8	12.8	13.3	13.2	10.8	8.1	3.9	1.2	(31)	
		MCDB	3.9	4.3	6.8	10.8	13.5	18.7	19.2	18.9	15.3	11.9	7.6	4.3	(32)	
	10%	WB	-0.6	-0.9	1.4	4.5	7.9	11.8	12.6	12.4	9.9	7.2	3.0	0.2	(33)	
		MCDB	2.9	2.9	5.4	9.2	12.3	17.2	18.1	17.7	13.7	11.0	6.6	3.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	5.9	7.1	8.1	8.0	8.6	8.9	8.0	7.6	7.1	5.8	5.6	(35)	
		MCDBR	6.1	6.7	8.5	9.6	10.0	10.4	10.5	9.8	9.0	8.3	7.0	6.2	(36)	
		MCWBR	4.4	4.6	5.1	5.6	5.8	5.7	5.3	5.4	5.4	5.4	4.6	4.0	(37)	
	5% WB	MCDBR	5.8	6.5	7.8	9.1	9.0	9.6	9.5	8.8	8.1	7.4	6.6	6.0	(38)	
		MCWBR	4.6	5.0	4.9	5.4	5.5	5.7	5.4	5.4	5.2	5.2	4.6	4.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.226	0.248	0.289	0.329	0.346	0.351	0.347	0.336	0.316	0.293	0.256	0.225	(40)	
	taud		2.326	2.270	2.214	2.231	2.292	2.319	2.324	2.367	2.418	2.460	2.437	2.358	(41)	
	Ebn at Noon		904	941	939	927	919	913	911	910	903	878	858	866	(42)	
	Edh at Noon		73	96	119	130	127	125	122	112	97	80	66	63	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.48	2.35	3.46	4.39	5.01	5.97	5.97	5.20	4.07	2.64	1.52	1.22	(44)	
	RadStd		0.17	0.32	0.47	0.58	0.43	0.52	0.48	0.41	0.34	0.29	0.22	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (104 neighbors)	N/A	N/A	N/A	+0.71	+0.40	+0.30	N/A	N/A	+56	+16

Nomenclature: See separate page