

ZERMATT, Switzerland

WMO: 067480

Lat: 46.0292N

Lon: 7.7525E

Elev: 1640

StdP: 83.12

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-12.5	-24.3	0.5	-10.3	-22.6	0.6	-10.0	6.6	0.5	5.2	-2.1	1.3	220	0.651

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	24.7	13.3	22.9	12.8	21.2	12.2	14.2	21.8	13.5	20.5	12.8	19.3	4.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	10.6	14.4	11.1	10.1	13.9	10.4	9.6	13.7	45.2	21.7	43.2	20.6	41.3	19.5	16.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.9	5.8	-16.4	27.5	2.3	1.6	-18.1	28.6	-19.5	29.6	-20.8	30.5	-22.5	31.6		
(5)			-17.6	15.6	2.2	0.5	-19.2	15.9	-20.5	16.2	-21.7	16.5	-23.2	16.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	-3.9	-3.1	0.7	5.1	8.3	12.9	14.4	13.8	10.3	6.8	1.2	-2.4
	DBStd	7.45	3.76	4.40	3.99	3.56	3.53	3.54	3.13	3.32	3.21	3.70	4.20	4.01
	HDD10.0	2126	431	368	289	151	75	12	4	7	35	107	263	386
	HDD18.3	4741	689	602	547	398	311	166	127	146	242	357	513	644
	CDD10.0	439	0	0	0	3	22	99	140	123	43	8	0	0
	CDD18.3	11	0	0	0	0	0	2	4	4	0	0	0	0
	CDH23.3	116	0	0	0	0	1	31	42	42	1	0	0	0
	CDH26.7	8	0	0	0	0	0	3	3	3	0	0	0	0
Wind	WSAvg	1.8	1.3	1.5	1.8	2.3	2.4	2.3	2.2	2.1	1.9	1.7	1.4	1.3
Precipitation	PrecAvg	806	44	44	48	62	101	79	68	76	68	84	79	55
	PrecMax	1134	107	152	104	174	228	181	154	159	222	300	261	133
	PrecMin	460	7	1	9	3	37	32	23	26	19	21	8	3
	PrecStd	148	29	34	26	46	53	31	26	33	47	58	60	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	9.5	13.0	17.7	21.7	26.2	26.8	26.9	22.0	18.2	12.7	7.7
		MCWB	1.4	2.1	3.8	7.3	10.9	13.4	14.2	13.6	11.9	8.7	4.6	1.4
	2%	DB	4.4	6.3	10.7	15.4	19.1	24.0	24.4	24.3	20.1	16.1	10.2	5.5
		MCWB	0.3	0.7	3.0	6.1	9.6	12.9	13.3	13.3	11.0	7.9	3.8	0.8
	5%	DB	2.6	4.1	8.7	13.4	16.9	21.8	22.7	22.1	18.1	14.3	8.4	3.7
		MCWB	-0.4	-0.4	2.3	5.3	8.4	12.2	12.9	12.6	10.1	7.1	3.4	0.1
	10%	DB	1.1	2.3	6.6	11.4	14.7	19.8	20.9	20.2	16.1	12.5	6.5	2.1
		MCWB	-1.4	-1.2	1.2	4.4	7.7	11.6	12.4	12.1	9.4	6.8	2.8	-0.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	2.9	4.9	7.9	11.6	14.6	15.1	15.0	12.9	10.3	6.7	3.0
		MCDB	4.7	7.5	10.8	15.5	19.9	22.8	24.0	23.2	18.7	14.4	9.4	5.4
	2%	WB	1.1	1.4	3.6	6.7	10.3	13.7	14.2	14.0	11.9	9.2	5.1	1.7
		MCDB	3.4	5.1	8.9	13.8	16.9	21.6	21.9	21.1	17.5	13.1	8.0	4.1
	5%	WB	0.0	0.3	2.7	5.7	9.3	12.9	13.5	13.2	11.0	8.4	4.2	0.7
		MCDB	2.0	3.3	7.2	12.2	15.0	20.2	20.5	19.7	16.0	12.2	7.1	2.9
	10%	WB	-1.2	-0.9	1.8	4.9	8.4	12.1	12.9	12.6	10.2	7.5	3.2	-0.3
		MCDB	1.0	1.8	5.9	10.4	13.5	18.7	19.3	18.5	14.9	11.3	6.3	1.8
Mean Daily Temperature Range	5% DB	MDBR	7.5	8.3	9.1	10.0	10.0	10.8	11.1	10.4	9.8	9.4	7.4	7.1
		MCDBR	8.5	10.1	11.6	12.6	13.2	13.9	13.5	13.4	12.5	11.7	9.6	8.3
		MCWBR	5.8	6.3	6.2	6.2	6.1	5.9	5.5	5.6	5.7	5.8	5.3	5.2
	5% WB	MCDBR	7.5	9.2	10.2	11.7	11.5	12.4	12.1	11.6	10.6	9.5	8.2	7.5
		MCWBR	5.5	5.9	5.6	5.8	5.5	5.6	5.4	5.3	5.2	5.0	4.9	5.1
Clear-Sky Solar Irradiance	taub		0.240	0.267	0.315	0.362	0.379	0.386	0.381	0.368	0.345	0.318	0.274	0.238
	taud		2.296	2.225	2.152	2.145	2.201	2.229	2.246	2.293	2.346	2.395	2.395	2.330
	Ebn at Noon		878	913	907	892	886	879	879	877	869	844	827	841
	Edh at Noon		76	101	128	142	139	136	132	121	105	86	70	66
All-Sky Solar Radiation	RadAvg		1.51	2.39	3.53	4.42	5.05	5.98	6.01	5.22	4.05	2.60	1.53	1.25
	RadStd		0.18	0.31	0.47	0.59	0.44	0.49	0.47	0.40	0.33	0.30	0.23	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (104 neighbors)	N/A	N/A	N/A	+0.71	+0.41	+0.31	N/A	N/A	+57	+16

Nomenclature: See separate page