

GUETSCH OB ANDERMATT, Switzerland

WMO: 067500

Lat: 46.653N

Lon: 8.615E

Elev: 7494

StdP: 11.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	5.0	-20.2	2.4	21.6	-15.5	3.1	21.2	49.2	21.3	43.4	21.5	13.6	10	0.925

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	63.4	52.6	60.6	51.0	58.1	50.0	54.1	61.0	52.5	58.8	51.0	56.7	11.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
51.1	73.7	56.9	49.5	69.4	55.7	48.1	65.8	54.2	25.8	61.4	24.7	59.0	23.6	56.8	59.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
42.6	34.9	29.9	DB	-1.7	68.4	4.5	2.6	-4.9	70.3	-7.5	71.8	-10.0	73.3	-13.3	75.2
			WB	-2.1	57.2	4.7	1.5	-5.4	58.3	-8.2	59.1	-10.8	60.0	-14.2	61.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.9	21.3	21.0	24.6	29.1	36.5	44.7	48.4	48.6	42.5	37.5	28.0	23.6	(6)
(7)		DBStd	12.53	7.63	8.48	7.77	6.98	6.57	7.63	6.47	6.77	7.14	7.69	8.48	8.07	(7)
(8)		HDD50	6047	889	811	788	627	419	192	107	108	239	388	661	818	(8)
(9)		HDD65	11350	1354	1231	1253	1077	883	608	515	508	676	851	1111	1283	(9)
(10)		CDD50	173	0	0	0	0	2	34	57	65	13	2	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	13.7	15.3	14.9	14.6	14.9	13.8	11.6	11.4	11.3	11.9	14.3	15.4	15.1	(14)
(15)	Precipitation	PrecAvg	62.8	3.6	3.6	3.7	5.2	6.5	6.1	5.5	6.2	6.1	5.4	6.8	4.0	(15)
(16)		PrecMax	81.7	8.4	9.3	7.8	11.4	17.2	11.6	10.2	9.4	16.8	17.0	22.8	8.5	(16)
(17)		PrecMin	43.3	0.9	0.9	0.5	0.8	2.0	2.4	2.6	1.9	0.9	0.7	1.1	0.4	(17)
(18)		PrecStd	9.8	1.9	2.1	2.0	2.8	3.7	2.4	2.0	1.8	3.9	3.5	4.9	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	42.7	42.2	46.8	56.9	66.3	66.4	67.6	60.7	56.5	49.1	42.7	(19)
(20)		0.4%	MCWB	29.8	29.9	31.2	37.9	46.9	52.3	54.2	53.2	48.7	43.8	36.5	29.0	(20)
(21)		2%	DB	37.7	39.1	39.4	43.7	52.0	61.7	62.5	63.6	57.1	52.2	44.6	39.0	(21)
(22)		2%	MCWB	28.3	27.9	30.6	36.5	43.7	50.9	52.9	52.9	47.8	41.4	34.7	28.2	(22)
(23)		5%	DB	34.6	35.8	37.0	40.9	48.5	58.4	59.9	60.2	54.2	49.4	41.3	36.2	(23)
(24)		5%	MCWB	26.3	26.6	29.5	34.8	42.0	49.8	51.5	51.0	46.1	39.8	32.7	27.4	(24)
(25)		10%	DB	31.4	32.2	34.7	38.2	45.5	55.2	57.3	57.6	51.4	46.8	38.4	33.8	(25)
(26)		10%	MCWB	25.1	25.4	28.6	33.3	40.1	48.2	50.2	50.1	44.5	38.6	31.4	26.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.1	31.5	34.1	39.5	47.7	54.8	56.1	56.2	51.7	45.9	39.4	33.6	(27)
(28)		0.4%	MCDWB	36.5	37.6	38.7	44.4	55.0	62.4	63.5	63.2	57.5	53.4	46.0	36.6	(28)
(29)		2%	WB	30.3	29.5	32.4	37.5	45.0	52.5	54.0	54.1	49.3	43.7	36.7	31.4	(29)
(30)		2%	MCDWB	34.9	35.0	36.6	42.2	50.6	59.5	60.9	61.0	55.0	49.1	41.7	34.5	(30)
(31)		5%	WB	28.2	27.9	31.0	35.8	42.6	50.6	52.5	52.4	47.4	42.0	34.7	29.7	(31)
(32)		5%	MCDWB	32.2	34.0	35.0	40.2	47.5	56.9	58.5	58.6	52.4	46.7	38.7	33.1	(32)
(33)		10%	WB	26.4	26.3	29.6	33.9	40.6	48.8	50.9	50.8	45.7	40.6	33.0	28.1	(33)
(34)		10%	MCDWB	30.2	31.7	33.5	37.5	44.9	54.6	56.2	56.5	50.2	44.9	36.7	32.2	(34)
(35)	Mean Daily Temperature Range		MDBR	8.0	8.0	8.1	7.8	8.6	10.9	11.1	10.7	10.2	9.7	7.8	8.1	(35)
(36)		5% DB	MCDBR	9.5	9.8	8.9	9.6	12.1	14.2	13.7	13.5	13.1	12.6	10.2	9.8	(36)
(37)			MCWBR	6.5	6.1	6.0	6.3	8.1	8.9	9.0	9.0	9.1	8.2	6.7	6.8	(37)
(38)			MCDBR	9.0	9.2	8.1	8.9	11.5	13.5	13.0	12.9	12.3	11.2	9.0	9.2	(38)
(39)		5% WB	MCWBR	7.4	7.1	6.0	6.2	7.9	8.9	9.0	9.0	8.7	7.7	6.6	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.221	0.243	0.282	0.320	0.336	0.343	0.342	0.333	0.309	0.286	0.249	0.219	(40)	
(41)		taud	2.365	2.320	2.283	2.277	2.338	2.358	2.355	2.396	2.459	2.506	2.486	2.397	(41)	
(42)		Ebn at Noon	289	300	301	297	294	292	291	289	288	281	275	277	(42)	
(43)		Edh at Noon	22	29	35	39	38	38	37	35	30	24	20	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	489	792	1176	1410	1524	1786	1776	1543	1196	789	483	407	(44)	
(45)		RadStd	60	94	168	226	153	161	156	140	118	92	70	54	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) -3.58	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (122 neighbors)	N/A	N/A	N/A	+1.30	+0.76	+0.58	N/A	N/A	+103	+27	(47)

Nomenclature: See separate page