

GUETSCH OB ANDERMATT, Switzerland

WMO: 067500

Lat: 46.653N

Lon: 8.615E

Elev: 2284

StdP: 76.73

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.7	-15.0	-29.0	0.3	-5.8	-26.4	0.4	-6.0	22.0	-6.0	19.4	-5.8	6.1	10	0.925

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	17.5	11.5	15.9	10.6	14.5	10.0	12.3	16.1	11.4	14.9	10.6	13.7	5.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	10.5	13.8	9.7	9.9	13.2	8.9	9.4	12.3	42.1	16.3	39.5	15.0	37.1	13.8	15.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	15.6	13.4	DB	-18.7	20.2	2.5	1.5	-20.5	21.3	-22.0	22.1	-23.4	22.9	-25.2	24.0	(4)
(5)			WB	-18.9	14.0	2.6	0.8	-20.8	14.6	-22.3	15.1	-23.8	15.5	-25.7	16.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-5.9	-6.1	-4.1	-1.6	2.5	7.1	9.1	9.2	5.8	3.1	-2.2	-4.7
	DBStd	6.96	4.24	4.71	4.32	3.88	3.65	4.24	3.59	3.76	3.97	4.27	4.71	4.48
	HDD10.0	3359	494	451	438	348	233	107	59	60	133	216	367	454
	HDD18.3	6306	752	684	696	598	491	338	286	282	376	473	617	713
	CDD10.0	96	0	0	0	0	1	19	32	36	7	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.1	6.8	6.6	6.5	6.6	6.2	5.2	5.1	5.0	5.3	6.4	6.9	6.7
Precipitation	PrecAvg	1594	91	92	95	133	164	156	139	158	155	138	172	101
	PrecMax	2075	213	236	199	290	436	295	259	239	427	432	579	215
	PrecMin	1099	23	22	13	21	52	60	65	49	24	19	27	10
	PrecStd	249	49	54	50	72	93	60	51	46	98	89	125	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	5.9	5.7	8.2	13.8	19.1	19.1	19.8	15.9	13.6	9.5	6.0
		MCWB	-1.2	-1.2	-0.4	3.3	8.3	11.3	12.4	11.8	9.3	6.6	2.5	-1.7
	2%	DB	3.2	3.9	4.1	6.5	11.1	16.5	17.0	17.5	14.0	11.2	7.0	3.9
		MCWB	-2.0	-2.3	-0.8	2.5	6.5	10.5	11.6	11.6	8.8	5.2	1.5	-2.1
	5%	DB	1.4	2.1	2.8	5.0	9.2	14.7	15.5	15.7	12.3	9.7	5.2	2.3
		MCWB	-3.1	-3.0	-1.4	1.6	5.5	9.9	10.8	10.6	7.8	4.3	0.4	-2.5
	10%	DB	-0.3	0.1	1.5	3.5	7.5	12.9	14.0	14.2	10.8	8.2	3.6	1.0
		MCWB	-3.8	-3.7	-1.9	0.7	4.5	9.0	10.1	10.1	7.0	3.7	-0.3	-3.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	-0.3	1.2	4.2	8.7	12.7	13.4	13.5	10.9	7.7	4.1	0.9
		MCDB	2.5	3.1	3.7	6.9	12.8	16.9	17.5	17.3	14.1	11.9	7.8	2.5
	2%	WB	-0.9	-1.4	0.2	3.1	7.2	11.4	12.2	12.3	9.6	6.5	2.6	-0.3
		MCDB	1.6	1.7	2.6	5.7	10.3	15.3	16.1	16.1	12.8	9.5	5.4	1.4
	5%	WB	-2.1	-2.3	-0.5	2.1	5.9	10.3	11.4	11.3	8.5	5.6	1.5	-1.3
		MCDB	0.1	1.1	1.7	4.5	8.6	13.8	14.7	14.8	11.3	8.2	3.7	0.6
	10%	WB	-3.1	-3.2	-1.3	1.0	4.8	9.3	10.5	10.4	7.6	4.8	0.6	-2.1
		MCDB	-1.0	-0.2	0.8	3.1	7.1	12.5	13.5	13.6	10.1	7.2	2.6	0.1
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.5	4.5	4.3	4.8	6.1	6.2	5.9	5.7	5.4	4.3	4.5
		MCDBR	5.3	5.4	4.9	5.3	6.7	7.9	7.6	7.5	7.3	7.0	5.7	5.4
		MCWBR	3.6	3.4	3.3	3.5	4.5	5.0	5.0	5.0	5.1	4.6	3.7	3.8
	5% WB	MCDBR	5.0	5.1	4.5	4.9	6.4	7.5	7.2	7.1	6.8	6.2	5.0	5.1
		MCWBR	4.1	4.0	3.3	3.4	4.4	4.9	5.0	5.0	4.8	4.3	3.7	4.3
Clear-Sky Solar Irradiance	taub	0.221	0.243	0.282	0.320	0.336	0.343	0.342	0.333	0.309	0.286	0.249	0.219	
	taud	2.365	2.320	2.283	2.277	2.338	2.358	2.355	2.396	2.459	2.506	2.486	2.397	
	Ebn at Noon	910	947	948	935	928	919	916	912	909	886	866	873	
	Edh at Noon	69	90	111	123	121	119	118	109	93	76	62	59	
All-Sky Solar Radiation	RadAvg	1.54	2.50	3.71	4.45	4.80	5.63	5.60	4.86	3.77	2.49	1.52	1.28	
	RadStd	0.19	0.30	0.53	0.71	0.48	0.51	0.49	0.44	0.37	0.29	0.22	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (122 neighbors)	N/A	N/A	N/A	+0.72	+0.42	+0.32	N/A	N/A	+57	+15

Nomenclature: See separate page