

DAVOS, Switzerland

WMO: 067840

Lat: 46.8130N

Lon: 9.8435E

Elev: 5223

StdP: 12.13

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.1	(c) 6.2	(d) -10.2	(e) 3.9	(f) 6.1	(g) -3.9	(h) 5.4	(i) 8.6	(j) 19.8	(k) 28.8	(l) 17.0	(m) 28.1	(n) 2.3	(o) 20	(p) 0.675

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	75.5	57.1	72.4	56.0	69.3	54.8	59.1	70.5	57.5	68.4	56.3	66.2	8.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.3	79.0	61.9	53.8	74.7	60.1	52.4	71.0	58.7	28.2	70.4	27.1	68.5	26.2	66.7	65.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.7	(b) 15.4	(c) 13.3	(e) -3.1	(f) 80.5	(g) 5.0	(h) 2.4	(i) -6.6	(j) 82.2	(k) -9.5	(l) 83.6	(m) -12.3	(n) 84.9	(o) -15.9	(p) 86.6		
(4) 18.7	(5) 15.4	(6) 13.3	(7) -4.1	(8) 62.1	(9) 4.7	(10) 1.5	(11) -7.5	(12) 63.2	(13) -10.2	(14) 64.1	(15) -12.9	(16) 65.0	(17) -16.3	(18) 66.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.1	23.4	24.7	31.2	38.9	45.5	53.3	55.7	55.4	48.5	43.1	33.6	26.1		
	DBStd	13.58	7.29	8.78	7.75	6.71	6.61	6.66	6.19	6.10	6.33	7.36	8.23	7.94		
	HDD50	4260	824	707	583	333	170	42	22	21	100	225	493	740		
	HDD65	9115	1289	1127	1048	782	605	351	292	301	494	678	943	1205		
	CDD50	628	0	0	0	1	30	142	199	188	56	12	0	0		
	CDD65	7	0	0	0	0	0	2	3	2	0	0	0	0		
	CDH74	143	0	0	0	0	0	36	59	48	0	0	0	0		
	CDH80	6	0	0	0	0	0	3	2	1	0	0	0	0		
(14) Wind	WSAvg	4.9	3.4	4.1	4.6	5.4	5.8	5.9	6.1	5.7	5.5	4.7	4.2	3.7		
(15) Precipitation	PrecAvg	46.1	2.8	2.9	2.8	2.8	3.8	5.4	5.7	6.0	4.0	3.3	3.6	3.0		
	PrecMax	62.3	7.0	9.8	6.3	6.7	6.5	10.4	9.3	10.4	7.4	7.8	10.2	8.4		
	PrecMin	36.3	0.3	0.7	0.5	0.6	1.3	2.6	3.0	1.5	1.5	0.2	0.0	0.2		
	PrecStd	5.8	1.8	2.0	1.5	1.2	1.6	1.9	1.5	1.9	1.6	1.6	2.0	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	47.7	54.0	62.8	70.6	78.9	79.1	78.3	71.0	66.0	56.4	46.2		
		MCWB	34.5	35.8	39.0	46.0	51.7	56.7	57.7	57.4	54.8	49.5	43.8	37.2		
	2%	DB	39.1	42.8	50.4	58.7	66.1	74.0	75.4	75.0	67.0	61.7	51.6	41.8		
		MCWB	33.5	33.7	37.7	44.0	50.0	55.9	57.4	57.5	53.0	48.1	41.8	34.8		
	5%	DB	36.0	39.5	47.2	55.1	62.0	70.5	71.9	71.4	63.8	58.2	48.1	38.4		
		MCWB	31.8	31.9	36.4	42.4	48.3	54.9	56.0	56.4	52.1	46.6	39.8	33.1		
	10%	DB	33.5	36.1	43.5	51.3	58.2	66.6	68.4	67.7	60.0	54.5	44.4	35.6		
		MCWB	30.7	30.7	34.8	40.1	46.6	53.7	54.9	55.1	50.3	45.3	38.3	31.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.9	37.6	40.9	47.2	54.0	60.0	60.9	61.1	57.2	51.9	45.5	38.6		
		MCDB	39.4	43.7	50.0	59.4	65.7	70.9	72.5	72.1	66.6	61.0	53.5	43.6		
	2%	WB	34.5	35.0	38.8	45.3	51.5	57.6	58.9	59.2	54.7	49.7	42.8	36.1		
		MCDB	37.5	40.8	47.7	56.6	62.1	69.5	71.1	70.1	63.2	58.0	49.4	39.6		
	5%	WB	32.7	33.0	37.1	43.1	49.5	56.2	57.4	57.5	53.1	48.0	40.6	34.3		
		MCDB	35.3	37.7	45.2	52.9	59.5	67.4	68.3	67.5	61.0	55.5	46.6	37.1		
	10%	WB	30.8	31.2	35.3	41.2	47.6	54.7	56.0	56.0	51.4	46.5	38.8	32.4		
		MCDB	33.5	35.8	42.5	49.8	56.7	64.7	65.6	65.3	58.3	52.8	43.8	35.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	16.7	17.2	17.5	17.1	18.0	18.2	17.6	16.7	17.3	14.0	12.7		
		MCDBR	15.5	19.6	22.2	24.0	24.2	24.8	24.6	23.9	23.0	23.3	18.7	15.1		
		MCWBR	11.4	12.6	12.4	12.0	11.6	11.1	10.6	10.7	12.0	12.5	11.2	10.1		
		MCDBR	13.7	17.0	19.2	21.9	21.0	22.0	21.5	21.2	19.8	19.8	17.0	13.0		
	5% WB	MCWBR	10.8	11.6	11.2	11.4	10.8	10.8	10.6	10.6	11.1	11.4	10.8	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.226	0.246	0.282	0.323	0.339	0.346	0.345	0.339	0.311	0.286	0.255	0.225		
	taud		2.374	2.322	2.293	2.319	2.385	2.405	2.404	2.440	2.506	2.552	2.517	2.414		
	Ebn at Noon		285	299	300	296	293	291	290	287	288	281	272	273		
	Edh at Noon		22	29	35	37	36	36	36	33	28	23	19	18		
(44) All-Sky Solar Radiation	RadAvg		474	771	1152	1407	1539	1781	1771	1544	1187	785	472	393		
	RadStd		55	92	154	211	159	157	151	145	121	93	70	52		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A
(47) Regional (113 neighbors)		N/A	N/A	N/A	+1.19	+0.74	+0.61	N/A	N/A	+104	+27

Nomenclature: See separate page