

PIZ CORVATSCH, Switzerland

WMO: 067910

Lat: 46.4181N

Lon: 9.8211E

Elev: 10823

StdP: 9.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.4	-7.0	-31.5	1.4	12.1	-26.3	1.9	12.6	35.0	12.3	30.5	11.0	15.2	40	0.977

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	48.5	41.2	46.4	40.1	44.5	38.8	43.2	46.7	41.6	45.0	40.1	43.4	5.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.5	58.1	44.7	39.6	54.0	43.0	38.1	50.8	41.5	20.0	46.9	19.0	45.2	18.1	43.6	50.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.2	25.4	22.3	DB	-12.8	51.6	4.7	2.7	-16.2	53.5	-18.9	55.1	-21.6	56.6	-25.0	58.5	(4)
(5)			WB	-13.4	46.4	4.5	2.0	-16.6	47.8	-19.2	49.0	-21.7	50.1	-24.9	51.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	11.5	10.9	13.7	18.2	25.8	33.0	36.9	37.1	30.9	26.7	18.4	13.7		
	DBStd	11.95	7.98	8.77	8.15	6.86	6.03	6.69	5.83	5.75	6.45	7.15	8.71	8.53		
	HDD50	9804	1194	1095	1125	953	752	509	407	400	573	722	949	1125		
	HDD65	15279	1659	1515	1590	1403	1217	959	872	865	1023	1187	1399	1590		
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	10.0	13.5	12.2	11.9	9.5	8.8	7.6	7.2	7.0	7.8	10.0	11.9	13.3		
	PrecAvg	38.2	2.0	1.3	1.6	2.7	3.9	4.3	4.2	4.3	3.7	4.1	4.2	1.9		
(15) Precipitation	PrecMax	59.6	6.8	5.4	6.1	6.3	9.1	10.8	8.6	7.4	9.7	12.4	18.5	4.8		
	PrecMin	21.7	0.1	0.0	0.0	0.0	1.6	1.1	2.0	0.6	0.3	0.0	0.0	0.0		
	PrecStd	8.7	1.6	1.2	1.2	1.9	1.8	2.3	1.5	1.5	2.7	2.8	4.5	1.3		
	PrecStd	8.7	1.6	1.2	1.2	1.9	1.8	2.3	1.5	1.5	2.7	2.8	4.5	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.4	32.4	30.6	34.0	41.2	50.8	50.6	51.5	45.7	41.8	36.8	31.8		
		MCWB	22.2	22.0	22.1	26.3	34.8	40.1	43.8	43.3	35.5	30.8	26.2	21.8		
	2%	DB	27.8	28.8	28.2	31.7	38.3	46.5	48.3	48.5	43.0	39.4	33.8	28.6		
		MCWB	20.3	19.7	21.4	26.0	32.6	39.8	41.9	40.7	34.5	29.5	24.2	19.9		
	5%	DB	24.8	25.6	26.0	29.6	35.9	44.0	46.1	46.5	41.1	37.3	31.4	26.3		
		MCWB	18.8	18.5	20.2	24.7	31.3	38.5	40.5	40.2	33.7	29.1	24.1	19.3		
	10%	DB	22.4	22.4	23.9	27.2	33.6	41.8	44.1	44.5	39.2	35.4	28.7	24.3		
		MCWB	17.2	17.1	19.2	23.3	29.9	37.0	39.0	39.1	33.0	28.0	22.8	18.7		
	0.4%	WB	25.4	24.9	25.3	29.6	36.7	43.4	46.2	45.7	40.3	35.1	30.6	25.2		
		MCDB	27.2	29.1	27.5	31.6	39.5	47.3	48.9	48.9	42.6	37.7	32.7	27.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	22.1	21.3	23.3	27.6	34.1	41.1	43.4	43.3	38.2	33.2	27.9	23.2		
		MCDB	25.1	25.2	25.6	30.0	37.1	45.1	46.8	46.6	40.7	35.7	30.0	25.0		
	5%	WB	20.0	19.5	21.5	25.7	32.3	39.3	41.6	41.6	36.6	31.7	26.0	21.5		
		MCDB	23.7	24.0	24.1	28.2	34.8	43.0	45.0	44.9	39.1	34.1	28.4	24.0		
	10%	WB	18.1	17.9	20.0	24.0	30.6	37.7	40.0	40.1	35.0	30.4	24.4	19.7		
		MCDB	21.4	22.3	22.9	26.3	32.8	41.0	43.2	43.3	37.4	33.0	27.0	22.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	7.9	7.5	7.0	6.6	7.1	7.8	7.4	6.4	6.6	6.9	7.7		
		MCDBR	8.1	8.4	7.6	7.0	7.2	8.4	9.4	8.6	7.2	6.5	6.7	7.3		
		MCWBR	7.0	6.1	6.1	6.8	7.8	8.5	9.3	9.2	8.3	5.9	5.2	5.6		
	5% WB	MCDBR	9.0	9.1	7.4	6.5	6.7	8.1	8.7	8.0	6.5	5.9	5.9	7.9		
		MCWBR	8.9	8.3	7.1	6.8	7.2	8.4	9.0	9.0	8.1	6.5	6.1	7.6		
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(40) Clear-Sky Solar Irradiance	taub		0.187	0.202	0.231	0.265	0.276	0.285	0.281	0.276	0.261	0.241	0.210	0.186		
	taud		2.430	2.394	2.380	2.398	2.485	2.494	2.504	2.537	2.568	2.609	2.564	2.460		
	Ebn at Noon		310	322	322	317	314	311	311	310	307	303	298	299		
	Edh at Noon		20	26	32	35	33	33	32	30	26	21	18	17		
(44) All-Sky Solar Radiation	RadAvg		511	814	1205	1426	1547	1802	1812	1571	1219	805	496	425		
	RadStd		62	95	165	216	156	147	145	136	116	100	77	54		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.84	+1.26	+1.03	N/A	N/A	N/A	N/A
(47)	Regional (103 neighbors)	+0.59	N/A	N/A	+1.28	+0.79	+0.61	N/A	N/A	+110	+27

Nomenclature: See separate page