

LE TOUQUET AP, France

WMO: 070030

Lat: 50.5144N

Lon: 1.6228E

Elev: 36

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.9	28.1	19.6	14.7	27.0	22.8	17.2	29.8	26.7	45.3	23.8	45.3	5.6	150	0.576

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	81.0	67.5	77.0	66.0	73.3	64.0	69.0	78.7	67.0	74.8	65.2	71.4	9.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.3	93.6	73.2	63.9	89.0	70.9	62.6	85.1	68.6	33.0	78.7	31.5	74.6	30.1	71.7	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.4	21.3	18.5	DB	20.4	90.7	4.0	4.4	17.5	93.9	15.1	96.5	12.9	99.0	9.9	102.2
			WB	19.5	73.3	4.0	1.3	16.7	74.2	14.3	75.0	12.1	75.8	9.2	76.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.9	41.0	41.4	44.9	49.7	55.0	59.8	63.3	63.0	60.0	54.4	47.1	42.8	
	DBStd	9.77	6.72	6.19	5.41	5.53	5.41	4.91	4.56	4.34	4.78	5.33	5.38	6.66	
	HDD50	1154	281	244	171	70	14	0	0	0	1	20	120	233	
	HDD65	4859	743	661	622	459	314	169	88	88	161	329	537	688	
	CDD50	1861	3	3	14	61	168	296	412	404	301	157	32	10	
	CDD65	92	0	0	0	0	3	15	35	27	11	1	0	0	
	CDH74	714	0	0	0	2	44	142	282	181	59	4	0	0	
	CDH80	166	0	0	0	0	5	31	78	44	8	0	0	0	
Wind	WSAvg	9.1	9.8	10.4	9.7	8.9	8.9	8.7	8.5	8.1	8.2	8.9	9.7	9.9	
Precipitation	PrecAvg	33.7	3.1	2.3	1.9	2.0	2.3	2.2	2.3	2.6	2.8	3.8	4.4	4.0	
	PrecMax	45.6	5.7	6.1	6.0	5.8	4.8	5.2	5.3	5.3	6.3	9.5	10.4	8.1	
	PrecMin	22.5	0.4	0.6	0.2	0.1	0.2	0.9	0.3	0.4	0.1	0.9	1.3	0.9	
	PrecStd	6.0	1.4	1.4	1.2	1.4	1.1	1.1	1.2	1.5	1.5	2.0	2.2	2.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	58.4	64.6	73.3	78.9	84.3	87.6	85.2	80.1	72.5	62.3	57.3	
		MCWB	51.5	50.3	53.7	60.1	64.3	69.2	70.7	69.2	66.7	63.7	58.4	53.5	
	2%	DB	52.9	53.5	59.7	67.9	73.5	78.0	80.9	79.3	74.4	66.5	59.0	55.2	
		MCWB	50.4	49.1	52.5	57.6	62.0	66.5	67.7	67.1	65.4	61.2	55.5	52.5	
	5%	DB	51.3	51.1	56.0	63.1	68.9	73.1	76.3	73.8	70.2	63.7	57.2	53.7	
		MCWB	49.0	48.3	50.5	55.2	60.0	63.5	66.0	64.8	63.1	59.4	54.1	50.9	
	10%	DB	50.0	49.5	52.6	59.0	64.7	69.1	72.0	70.2	67.4	62.0	55.6	52.2	
		MCWB	47.8	47.1	48.6	53.1	58.0	61.5	64.1	63.4	61.7	58.3	52.7	49.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	52.0	55.7	61.5	67.5	70.3	71.7	71.1	69.1	64.3	59.4	54.6
			MCDB	54.0	55.7	61.4	69.8	76.1	81.8	84.6	82.0	77.6	69.4	61.7	56.0
2%		WB	50.9	50.3	53.1	58.0	63.5	67.2	69.0	68.0	66.4	62.0	56.4	53.0	
		MCDB	52.4	52.5	58.3	66.5	70.9	76.5	79.1	75.9	72.9	65.8	58.5	54.8	
5%		WB	49.4	48.9	51.0	55.8	60.9	64.5	66.8	65.9	64.3	60.4	54.7	51.5	
		MCDB	50.9	50.7	55.1	62.4	67.8	71.8	74.4	72.2	68.5	63.0	56.9	53.4	
10%		WB	48.1	47.4	49.4	53.4	58.6	62.1	64.7	64.4	62.9	59.0	53.0	49.9	
		MCDB	49.8	49.3	52.1	58.1	64.0	67.5	70.9	69.0	66.4	61.5	55.3	51.8	
Mean Daily Temperature Range		5% DB	MDBR	8.5	9.6	11.8	14.7	14.8	14.5	13.9	14.2	13.8	12.1	10.4	8.8
			MCDBR	7.3	11.6	18.1	20.8	22.4	23.0	23.2	21.3	17.7	13.7	10.8	8.0
	MCWBR		7.2	8.8	11.6	12.6	12.9	13.2	12.3	11.5	10.4	9.5	9.1	7.7	
	5% WB	MCDBR	7.2	9.4	15.1	19.3	20.1	20.4	20.9	17.9	14.7	12.3	9.7	8.3	
		MCWBR	7.6	8.0	10.4	12.1	12.6	12.5	12.0	10.8	9.3	9.4	8.8	8.4	
Clear-Sky Solar Irradiance	taub	0.331	0.349	0.386	0.406	0.414	0.413	0.411	0.403	0.382	0.366	0.340	0.324		
	taud	2.387	2.370	2.267	2.233	2.267	2.293	2.305	2.349	2.391	2.418	2.409	2.371		
	Ebn at Noon	220	247	256	265	268	268	267	263	256	237	214	202		
	Edh at Noon	20	27	35	40	41	40	39	36	31	25	20	18		
All-Sky Solar Radiation	RadAvg	267	495	885	1423	1685	1866	1793	1500	1115	630	306	205		
	RadStd	22	71	106	119	120	157	143	102	67	57	32	24		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page