

ABBEVILLE, France

WMO: 070050

Lat: 50.1361N

Lon: 1.8339E

Elev: 236

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.2	26.6	17.5	13.4	25.6	21.4	16.2	28.1	34.8	50.3	31.5	50.3	8.1	70	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.3	83.1	67.4	79.1	66.1	75.3	64.1	69.2	80.2	67.3	76.5	65.5	73.1	8.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	94.5	73.2	63.8	89.3	71.0	62.4	85.2	69.1	33.4	80.4	31.8	76.6	30.5	73.4	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.8	23.1	20.3	DB	19.6	91.4	5.2	4.6	15.8	94.7	12.7	97.4	9.8	100.0	6.0	103.3	(4)
(5)			WB	18.6	72.7	5.1	1.2	14.9	73.6	11.9	74.3	9.1	75.0	5.4	75.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	40.0	41.0	45.1	49.5	55.1	60.1	63.9	64.2	59.5	53.7	46.2	41.0
	DBStd	10.43	7.22	6.49	5.73	5.92	5.79	5.01	4.83	4.77	4.70	5.77	6.06	7.15
	HDD50	1286	313	254	169	78	16	0	0	0	0	30	141	285
	HDD65	4989	775	671	617	464	311	165	80	72	177	351	563	743
	CDD50	1903	3	3	18	64	175	302	432	442	284	145	28	7
	CDD65	128	0	0	0	0	5	17	46	48	11	1	0	0
	CDH74	1081	0	0	0	5	52	178	400	371	70	5	0	0
	CDH80	280	0	0	0	0	5	43	110	113	9	0	0	0
Wind	WSAvg	9.8	11.4	11.2	11.0	9.8	9.5	8.8	8.8	8.6	8.4	9.5	9.9	10.8
Precipitation	PrecAvg	32.5	2.7	2.2	2.0	2.0	2.5	2.6	2.7	3.0	2.6	3.1	3.4	3.6
	PrecMax	44.1	5.6	5.8	6.5	5.4	4.7	5.4	5.2	5.6	5.0	8.1	6.7	7.7
	PrecMin	23.0	0.2	0.6	0.2	0.2	0.4	0.7	0.9	0.6	0.1	0.6	0.6	0.9
	PrecStd	5.6	1.2	1.4	1.3	1.3	1.2	1.3	1.2	1.5	1.3	1.6	1.6	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	58.3	65.3	74.6	78.8	85.5	88.7	89.1	80.9	72.7	62.1	57.0
		MCWB	52.5	51.0	53.8	58.8	64.8	69.0	69.2	69.5	66.1	63.4	58.3	53.9
	2%	DB	53.8	54.0	60.3	68.9	74.7	79.3	82.8	82.8	75.5	67.0	58.7	55.1
		MCWB	51.2	49.8	52.2	57.4	62.8	66.6	67.3	67.3	63.9	61.1	55.5	52.5
	5%	DB	51.3	51.8	56.5	63.6	70.0	74.1	78.6	77.8	70.8	63.7	56.7	53.0
		MCWB	48.8	48.5	50.9	54.1	60.2	64.0	65.9	65.9	62.0	59.0	54.0	50.7
	10%	DB	49.4	49.8	53.4	59.5	65.5	69.9	74.2	73.1	67.6	61.5	54.6	51.0
		MCWB	47.2	47.1	49.3	52.2	58.0	62.2	64.3	63.6	60.4	57.8	52.2	48.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.6	52.5	55.8	62.0	67.5	70.4	71.4	71.1	68.4	64.4	59.1	54.8
		MCDB	55.2	56.1	61.8	71.5	76.5	82.4	84.3	83.1	76.9	69.8	61.3	56.3
	2%	WB	51.5	50.6	53.5	57.6	63.7	67.5	69.1	68.9	65.4	61.8	56.2	52.8
		MCDB	53.5	53.3	58.2	66.4	71.7	77.2	80.1	80.0	72.6	66.0	58.2	54.6
	5%	WB	49.2	49.0	51.6	55.2	61.1	65.1	67.1	66.7	63.4	59.9	54.4	51.0
		MCDB	51.1	51.3	55.8	62.5	68.3	72.7	76.2	75.1	68.7	63.0	56.4	52.8
	10%	WB	47.3	47.3	49.7	53.0	58.7	62.8	65.1	64.8	61.9	58.3	52.4	48.9
		MCDB	49.2	49.6	52.9	58.5	64.6	68.6	72.6	71.2	66.4	60.9	54.4	50.8
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.4	11.9	15.2	14.9	15.2	15.6	15.3	14.5	11.7	8.9	8.0
		MCDBR	9.0	12.0	17.3	21.7	22.2	23.7	24.3	23.6	19.8	14.2	9.4	8.5
		MCWBR	8.1	9.1	11.0	12.2	12.2	13.2	11.4	10.5	10.2	9.1	7.9	7.7
	5% WB	MCDBR	8.8	10.5	14.8	19.6	19.7	20.7	21.2	20.1	16.3	12.5	9.0	8.5
MCWBR		8.3	8.6	10.1	11.7	11.9	12.4	11.1	10.1	9.4	8.8	8.0	8.0	
Clear-Sky Solar Irradiance	taub	0.326	0.345	0.381	0.403	0.410	0.410	0.408	0.400	0.378	0.362	0.335	0.320	
	taud	2.390	2.362	2.256	2.211	2.239	2.265	2.276	2.321	2.368	2.405	2.406	2.367	
	Ebn at Noon	224	249	259	266	269	269	268	264	258	240	218	207	
	Edh at Noon	21	27	35	41	42	41	40	36	31	25	20	18	
All-Sky Solar Radiation	RadAvg	271	500	879	1392	1637	1815	1735	1466	1109	638	317	216	
	RadStd	26	75	107	137	133	163	144	115	73	57	33	28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page