

ABBEVILLE, France

WMO: 070050

Lat: 50.1361N

Lon: 1.8339E

Elev: 72

StdP: 100.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-3.0	-8.0	1.9	-3.6	-5.9	2.3	-2.2	15.6	10.2	14.1	10.2	3.6	70	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.5	(c) 28.4	(d) 19.7	(e) 26.2	(f) 18.9	(g) 24.1	(h) 17.9	(i) 20.7	(j) 26.8	(k) 19.6	(l) 24.7	(m) 18.6	(n) 22.8	(o) 4.0	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.5	22.9	17.7	12.8	21.6	16.9	12.2	20.6	59.7	26.9	56.2	24.8	53.0	23.0	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	10.3	9.1	-6.9	33.0	2.9	2.5	-9.0	34.8	-10.7	36.3	-12.3	37.8	-14.5	39.6
			-7.5	22.6	2.8	0.7	-9.5	23.1	-11.1	23.5	-12.7	23.9	-14.8	24.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	4.4	5.0	7.3	9.7	12.9	15.6	17.7	17.9	15.3	12.1	7.9	5.0
	DBStd	5.80	4.01	3.60	3.19	3.29	3.21	2.78	2.68	2.65	2.61	3.21	3.37	3.97
	HDD10.0	714	174	141	94	43	9	0	0	0	0	17	78	158
	HDD18.3	2772	431	373	343	258	173	92	44	40	98	195	313	413
	CDD10.0	1057	2	2	10	36	97	168	240	246	158	81	16	4
	CDD18.3	71	0	0	0	0	3	9	26	27	6	1	0	0
	CDH23.3	601	0	0	0	3	29	99	222	206	39	3	0	0
	CDH26.7	156	0	0	0	0	3	24	61	63	5	0	0	0
Wind	WSAvg	4.4	5.1	5.0	4.9	4.4	4.2	3.9	3.9	3.8	3.8	4.2	4.4	4.8
Precipitation	PrecAvg	826	68	57	52	51	63	66	69	77	65	80	87	92
	PrecMax	1121	141	148	166	136	119	137	131	142	127	206	171	196
	PrecMin	584	5	15	6	5	9	18	23	16	2	15	14	23
	PrecStd	142	31	35	34	33	30	34	31	39	34	41	40	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.6	18.5	23.6	26.0	29.7	31.5	31.7	27.2	22.6	16.7	13.9
		MCWB	11.4	10.6	12.1	14.9	18.2	20.6	20.6	20.8	19.0	17.4	14.6	12.1
	2%	DB	12.1	12.2	15.7	20.5	23.7	26.3	28.2	28.2	24.2	19.4	14.8	12.8
		MCWB	10.7	9.9	11.2	14.1	17.1	19.2	19.6	19.6	17.7	16.1	13.0	11.4
	5%	DB	10.7	11.0	13.6	17.6	21.1	23.4	25.9	25.5	21.6	17.6	13.7	11.7
		MCWB	9.4	9.2	10.5	12.3	15.7	17.8	18.9	18.8	16.7	15.0	12.2	10.4
	10%	DB	9.7	9.9	11.9	15.3	18.6	21.1	23.4	22.9	19.8	16.4	12.6	10.5
		MCWB	8.4	8.4	9.6	11.2	14.4	16.8	17.9	17.5	15.8	14.3	11.2	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	11.4	13.2	16.7	19.7	21.3	21.9	21.7	20.2	18.0	15.1	12.6
		MCDB	12.9	13.4	16.5	21.9	24.7	28.0	29.1	28.4	24.9	21.0	16.3	13.5
	2%	WB	10.8	10.4	11.9	14.2	17.6	19.7	20.6	20.5	18.6	16.5	13.4	11.5
		MCDB	11.9	11.8	14.6	19.1	22.1	25.1	26.7	26.6	22.6	18.9	14.5	12.6
	5%	WB	9.5	9.4	10.9	12.9	16.2	18.4	19.5	19.3	17.4	15.5	12.4	10.5
		MCDB	10.6	10.7	13.2	16.9	20.2	22.6	24.6	23.9	20.4	17.2	13.6	11.6
	10%	WB	8.5	8.5	9.9	11.7	14.8	17.1	18.4	18.2	16.6	14.6	11.3	9.4
		MCDB	9.6	9.8	11.6	14.7	18.1	20.4	22.6	21.8	19.1	16.1	12.4	10.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.2	6.6	8.4	8.3	8.5	8.7	8.5	8.0	6.5	5.0	4.4
		MCDBR	5.0	6.7	9.6	12.1	12.3	13.1	13.5	13.1	11.0	7.9	5.2	4.7
		MCWBR	4.5	5.1	6.1	6.8	6.8	7.3	6.3	5.8	5.7	5.0	4.4	4.3
	5% WB	MCDBR	4.9	5.8	8.2	10.9	11.0	11.5	11.8	11.2	9.0	6.9	5.0	4.7
		MCWBR	4.6	4.8	5.6	6.5	6.6	6.9	6.1	5.6	5.2	4.9	4.4	4.5
Clear-Sky Solar Irradiance	taub	0.326	0.345	0.381	0.403	0.410	0.410	0.408	0.400	0.378	0.362	0.335	0.320	
	taud	2.390	2.362	2.256	2.211	2.239	2.265	2.276	2.321	2.368	2.405	2.406	2.367	
	Ebn at Noon	706	786	815	837	848	849	844	833	812	756	687	651	
	Edh at Noon	65	85	111	130	132	129	126	115	99	80	63	58	
All-Sky Solar Radiation	RadAvg	0.85	1.58	2.77	4.39	5.16	5.72	5.47	4.62	3.50	2.01	1.00	0.68	
	RadStd	0.08	0.24	0.34	0.43	0.43	0.42	0.51	0.45	0.36	0.23	0.18	0.10	0.09

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (59 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page