

LILLE-LESQUIN AP, France

WMO: 070150

Lat: 50.5700N

Lon: 3.0975E

Elev: 48

StdP: 100.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	-3.4	-9.0	1.8	-2.9	-6.8	2.1	-2.1	14.5	9.3	13.4	9.6	3.5	50	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	29.8	19.9	27.6	19.1	25.6	18.1	20.9	27.6	19.9	25.8	19.0	24.2	3.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.5	23.1	17.7	12.8	22.3	17.0	12.2	21.2	60.3	27.7	56.9	25.9	54.0	24.2	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.1	9.0	DB	-7.5	33.8	2.7	2.3	-9.5	35.4	-11.0	36.7	-12.5	38.0	-14.5	39.6	(4)
(5)			WB	-8.0	22.9	2.7	0.8	-10.0	23.4	-11.5	23.9	-13.1	24.3	-15.0	24.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	4.0	4.7	7.3	10.3	13.6	16.5	18.8	18.5	15.5	11.9	7.5	4.5	(6)
(7)		DBStd	6.25	3.99	3.65	3.31	3.46	3.44	3.16	3.10	2.96	2.83	3.25	3.35	3.90	(7)
(8)		HDD10.0	753	188	149	95	37	6	0	0	0	1	18	87	172	(8)
(9)		HDD18.3	2746	445	382	342	242	153	73	32	32	93	201	324	428	(9)
(10)		CDD10.0	1165	1	2	11	46	118	194	272	264	166	77	13	3	(10)
(11)		CDD18.3	117	0	0	0	1	6	18	45	38	8	1	0	0	(11)
(12)		CDH23.3	1017	0	0	0	9	58	172	392	324	58	3	0	0	(12)
(13)		CDH26.7	284	0	0	0	0	7	44	117	107	11	0	0	0	(13)
(14)	Wind	WSAvg	4.3	5.0	4.9	4.7	4.2	4.1	3.9	3.8	3.6	3.7	4.1	4.4	4.8	(14)
(15)	Precipitation	PrecAvg	698	54	41	55	46	60	62	64	59	61	62	70	65	(15)
(16)		PrecMax	898	120	80	113	113	124	125	180	129	161	166	139	163	(16)
(17)		PrecMin	438	3	6	2	3	21	4	19	7	6	4	22	10	(17)
(18)		PrecStd	121	29	20	28	26	27	33	39	30	39	37	30	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	14.4	18.9	24.7	27.7	31.0	32.8	32.8	28.1	22.8	16.9	13.6	(19)
(20)			MCWB	11.4	10.1	11.9	15.4	18.8	20.9	21.1	20.8	19.6	17.6	14.4	12.1	(20)
(21)		2%	DB	11.9	12.2	16.2	21.5	25.0	27.5	29.7	29.7	24.9	19.8	14.8	12.5	(21)
(22)			MCWB	10.5	9.7	11.2	14.0	16.6	19.1	19.9	19.8	18.0	15.8	13.0	11.2	(22)
(23)		5%	DB	10.5	11.0	14.0	18.5	22.6	25.2	27.5	27.0	22.4	18.0	13.6	11.4	(23)
(24)			MCWB	9.2	9.1	10.3	12.4	15.6	18.1	19.1	18.8	16.9	14.9	12.0	10.1	(24)
(25)		10%	DB	9.3	10.0	12.3	16.2	20.1	22.8	25.3	24.4	20.6	16.7	12.4	10.1	(25)
(26)			MCWB	8.0	8.3	9.5	11.4	14.5	16.9	18.2	18.0	15.9	14.3	10.9	8.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.3	13.1	16.5	19.7	21.8	22.0	22.2	20.2	18.0	14.9	12.5	(27)
(28)			MCDWB	12.7	13.2	16.1	23.1	26.2	29.3	30.1	29.6	25.9	21.4	16.3	13.2	(28)
(29)		2%	WB	10.6	10.3	12.0	14.4	17.7	19.9	20.8	20.7	18.9	16.6	13.2	11.4	(29)
(30)			MCDWB	11.7	11.6	15.0	19.6	22.8	25.6	27.8	27.1	23.2	19.1	14.4	12.4	(30)
(31)		5%	WB	9.3	9.4	10.9	13.1	16.3	18.7	19.8	19.6	17.7	15.5	12.2	10.2	(31)
(32)			MCDWB	10.4	10.7	13.5	17.5	20.9	24.1	25.7	25.3	21.0	17.5	13.5	11.3	(32)
(33)		10%	WB	8.1	8.4	9.9	11.9	15.1	17.5	18.8	18.6	16.7	14.6	11.1	9.0	(33)
(34)			MCDWB	9.2	9.8	12.0	15.5	19.5	21.9	23.9	23.3	19.7	16.3	12.3	9.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	5.6	7.1	8.7	8.9	9.3	9.4	9.6	8.7	7.2	5.4	4.6	(35)
(36)			MCDBR	5.2	6.8	10.0	12.4	12.7	13.1	13.2	13.9	11.5	8.8	6.1	5.2	(36)
(37)			MCWBR	4.7	5.0	6.0	6.3	6.1	6.3	5.4	5.5	5.5	5.3	4.8	4.7	(37)
(38)		5% WB	MCDWB	5.2	6.0	8.4	10.8	11.3	12.0	11.6	11.9	9.9	7.8	5.6	5.1	(38)
(39)			MCWBR	4.9	4.8	5.5	5.9	6.0	6.5	5.4	5.4	5.2	5.2	4.7	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.331	0.352	0.390	0.416	0.426	0.423	0.424	0.414	0.389	0.369	0.343	0.327	(40)	
(41)		taud	2.376	2.342	2.230	2.180	2.198	2.229	2.231	2.280	2.337	2.387	2.381	2.350	(41)	
(42)		Ebn at Noon	690	771	801	823	832	836	828	817	797	742	666	630	(42)	
(43)		Edh at Noon	65	86	114	133	137	134	132	119	102	81	64	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.51	2.69	4.29	4.99	5.48	5.20	4.42	3.36	1.97	0.96	0.65	(44)	
(45)		RadStd	0.08	0.29	0.36	0.46	0.44	0.50	0.53	0.41	0.25	0.17	0.10	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page