

POINTE DE LA HAGUE, France

WMO: 070200

Lat: 49.7253N

Lon: 1.9397W

Elev: 39

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.0	36.5	25.0	19.1	37.4	27.7	21.6	38.5	43.8	47.0	41.0	47.3	13.2	120	0.754

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	71.0	64.3	69.0	63.5	67.4	62.6	65.5	69.2	64.4	67.6	63.5	66.4	11.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.0	89.3	67.1	63.0	86.3	66.1	62.1	83.5	65.2	30.4	69.4	29.5	67.7	28.9	66.6	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
38.6	34.6	31.5	DB	30.3	78.4	3.2	3.4	28.0	80.8	26.1	82.8	24.3	84.8	22.0	87.2
			WB	28.1	68.4	2.7	2.0	26.1	69.8	24.6	71.0	23.0	72.1	21.1	73.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	46.1	45.6	47.3	50.0	54.2	58.6	62.3	63.6	61.8	57.7	52.1	47.8
	DBStd	7.28	4.70	3.99	3.61	3.34	3.07	2.68	2.36	2.07	2.68	3.73	4.10	4.64
	HDD50	514	131	126	95	38	4	0	0	0	0	2	25	93
	HDD65	4046	586	542	549	449	334	194	90	54	103	227	386	532
	CDD50	1964	9	4	11	39	134	257	380	421	353	241	89	26
	CDD65	22	0	0	0	0	0	1	5	10	5	1	0	0
	CDH74	27	0	0	0	0	1	2	7	8	7	2	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
(14) Wind	WSAvg	16.2	19.9	19.2	16.8	14.5	13.9	12.6	12.4	13.1	14.9	17.5	19.3	19.9
(15) Precipitation	PrecAvg	33.8	3.8	2.8	2.3	2.2	2.0	1.9	1.8	2.1	2.3	3.8	4.4	4.4
	PrecMax	44.6	7.1	5.9	5.7	5.5	4.4	3.9	3.6	5.5	5.5	7.0	9.8	9.1
	PrecMin	24.8	0.7	0.4	0.4	0.2	0.4	0.4	0.4	0.5	0.2	0.9	1.3	1.0
	PrecStd	4.6	1.7	1.7	1.2	1.3	1.1	1.1	0.9	1.2	1.3	1.6	2.1	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	54.8	59.4	62.4	67.3	72.1	73.6	74.4	72.8	69.8	61.7	57.1
		MCWB	52.8	50.8	53.0	55.2	59.4	63.6	64.3	66.2	64.4	61.7	58.7	54.8
	2%	DB	53.7	52.6	55.3	58.9	62.6	67.1	69.9	70.6	69.4	65.6	59.7	55.8
		MCWB	51.8	50.3	51.0	53.6	57.3	61.3	63.8	64.8	63.7	61.1	57.0	53.5
	5%	DB	52.8	51.6	53.2	56.5	60.4	64.6	68.0	68.8	67.1	63.7	58.6	54.8
		MCWB	50.8	49.6	50.0	52.3	56.2	59.8	62.9	63.9	62.3	60.2	55.9	52.5
	10%	DB	51.9	50.8	51.9	54.7	58.8	62.9	66.6	67.3	65.6	62.4	57.6	53.8
		MCWB	49.8	48.7	49.2	51.2	55.2	58.8	62.1	63.0	61.3	59.3	54.8	51.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	52.1	54.0	56.2	60.8	64.1	66.4	67.5	66.1	63.9	59.7	55.7
		MCDB	54.3	53.3	57.7	61.2	64.9	69.9	70.8	72.1	70.3	66.9	60.8	56.4
	2%	WB	52.5	51.1	51.8	54.2	58.0	62.0	64.6	65.9	64.6	62.1	57.8	54.3
		MCDB	53.3	52.1	53.9	57.8	61.6	66.2	68.3	69.2	68.1	64.3	59.3	55.3
	5%	WB	51.3	50.1	50.7	52.8	56.7	60.5	63.6	64.8	63.4	61.0	56.5	53.2
		MCDB	52.3	51.2	52.5	55.8	59.7	63.8	66.9	67.5	66.2	63.0	58.3	54.4
	10%	WB	50.2	49.1	49.8	51.7	55.6	59.4	62.7	63.8	62.4	60.0	55.2	52.0
		MCDB	51.6	50.5	51.5	54.1	58.2	62.2	65.8	66.3	64.8	62.1	57.3	53.6
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.4	6.4	7.6	7.6	7.9	8.0	7.4	7.0	6.3	5.5	5.5
		MCDBR	4.8	5.4	8.4	10.4	10.3	10.9	10.8	10.3	9.6	7.7	5.8	5.1
	5% WB	MCWBR	5.5	5.2	6.2	7.2	6.9	7.3	6.8	6.4	6.5	5.8	6.0	5.9
		MCWBR	4.6	4.8	7.5	9.6	9.5	9.9	9.6	8.7	8.5	6.8	5.3	5.0
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.353	0.387	0.399	0.404	0.398	0.392	0.386	0.376	0.366	0.340	0.330
		taud	2.395	2.387	2.304	2.299	2.338	2.384	2.404	2.442	2.448	2.450	2.433	2.365
	Ebn at Noon	Ebn at Noon	222	248	258	268	272	273	273	270	260	241	219	205
		Edh at Noon	21	27	34	38	38	36	35	32	29	25	20	19
(44) All-Sky Solar Radiation	RadAvg	274	510	899	1437	1718	1890	1820	1515	1150	646	339	222	
	RadStd	23	61	99	120	120	182	112	109	75	49	36	26	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page