

DEAUVILLE ST GATIEN AP, France

WMO: 070310

Lat: 49.3644N

Lon: 0.1669E

Elev: 479

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	27.3	18.3	14.1	27.1	21.7	16.6	29.3	35.4	47.0	27.5	47.9	5.5	70	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	81.8	67.8	77.5	65.6	74.0	64.0	69.1	79.2	67.1	75.2	65.3	72.1	7.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	96.0	73.3	63.9	90.6	70.9	62.4	85.8	68.6	33.5	79.6	31.8	75.2	30.4	72.2	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.4	20.2	17.6	DB	19.8	90.0	3.9	5.5	17.0	93.9	14.7	97.1	12.5	100.2	9.6	104.2	(4)
(5)			WB	18.9	73.3	4.0	1.8	16.0	74.6	13.7	75.6	11.4	76.6	8.5	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	40.8	41.1	45.0	49.5	54.0	59.7	62.9	62.0	58.6	53.6	46.7	41.9		
	DBStd	9.77	6.58	6.51	6.05	5.84	5.57	5.45	4.89	4.89	5.11	5.79	5.45	6.37		
	HDD50	1229	287	254	176	77	19	1	0	1	2	31	125	256		
	HDD65	5065	749	670	620	466	346	177	100	119	200	353	550	715		
	CDD50	1734	3	4	22	61	142	293	400	373	261	144	25	6		
	CDD65	94	0	0	0	0	4	19	35	26	9	1	0	0		
	CDH74	820	0	0	0	6	35	188	314	210	60	7	0	0		
	CDH80	209	0	0	0	0	3	50	92	52	11	1	0	0		
(14) Wind	WSAvg	8.3	10.1	9.8	9.2	7.9	7.9	7.2	7.2	7.0	6.6	8.3	8.9	9.8		
(15) Precipitation	PrecAvg	32.8	2.8	2.4	2.1	2.2	2.3	2.5	2.3	2.7	2.7	3.5	3.5	3.8		
	PrecMax	42.4	5.4	4.6	6.9	4.4	3.7	6.2	4.6	6.5	6.1	7.2	8.0	8.5		
	PrecMin	21.6	0.4	0.4	0.4	0.3	0.5	0.3	0.6	0.4	0.6	0.4	0.8	0.9		
	PrecStd	4.6	1.3	1.2	1.4	1.2	1.0	1.5	1.1	1.7	1.4	1.7	1.6	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.6	59.4	66.3	74.7	78.0	86.1	89.0	86.2	80.7	72.7	62.0	56.7		
		MCWB	53.0	50.3	54.1	59.8	64.3	69.1	69.6	69.8	66.1	63.5	58.2	53.7		
	2%	DB	53.8	54.6	61.6	69.1	73.3	79.2	81.3	80.1	74.5	67.3	58.8	54.8		
		MCWB	51.8	49.7	52.4	57.5	62.2	67.2	67.6	67.3	64.3	61.5	55.4	52.5		
	5%	DB	51.7	52.1	57.8	63.7	68.4	74.3	76.8	74.9	70.6	63.9	56.6	53.0		
		MCWB	49.8	48.6	50.9	54.6	59.3	64.3	65.8	64.9	62.4	59.4	53.9	50.8		
	10%	DB	49.7	50.0	54.2	59.4	64.5	70.1	72.8	70.8	67.3	61.7	54.7	51.1		
		MCWB	47.8	47.2	49.7	52.0	57.3	62.5	64.0	63.4	61.0	58.2	52.3	49.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	52.6	55.7	61.8	66.6	71.5	71.8	71.7	68.4	64.6	59.7	54.9		
		MCDB	54.9	55.3	62.6	71.1	75.8	83.4	85.2	83.6	75.6	70.5	61.6	56.0		
	2%	WB	52.0	50.8	53.7	58.2	62.7	67.6	69.0	68.3	65.7	62.3	56.3	52.9		
		MCDB	53.4	53.6	59.0	67.8	70.1	76.7	79.2	77.4	72.1	66.5	58.1	54.3		
	5%	WB	50.0	49.2	52.0	55.5	60.2	65.2	66.8	66.1	63.6	60.3	54.3	51.3		
		MCDB	51.5	51.6	56.7	62.4	67.2	73.2	75.1	72.6	68.9	63.0	56.2	52.9		
	10%	WB	48.0	47.4	50.0	52.8	58.0	63.0	64.8	64.2	62.0	58.8	52.7	49.3		
		MCDB	49.3	49.7	53.8	58.3	63.7	68.9	71.3	69.4	66.3	61.3	54.5	50.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	10.3	12.6	15.4	15.4	16.1	15.7	15.7	15.8	12.4	10.0	9.2		
		MCDBR	9.1	12.8	18.2	21.7	22.4	23.7	24.7	23.1	19.9	14.1	11.6	10.1		
	5% WB	MCWBR	8.5	9.3	11.3	12.8	13.0	13.2	13.1	12.2	11.1	9.3	8.9	9.0		
		MCWBR	8.8	10.8	15.5	20.7	20.0	21.0	21.8	20.0	17.1	12.8	10.9	9.2		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.340	0.373	0.392	0.397	0.397	0.391	0.386	0.369	0.354	0.330	0.317		
	taud		2.437	2.408	2.313	2.276	2.301	2.333	2.350	2.386	2.417	2.452	2.451	2.404		
	Ebn at Noon		231	255	264	271	273	274	273	270	263	246	226	214		
	Edh at Noon		20	26	34	39	39	38	37	34	30	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		284	519	886	1377	1617	1806	1728	1462	1128	649	343	238		
	RadStd		28	67	102	143	135	177	123	113	73	57	36	31		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page