

DEAUVILLE ST GATIEN AP, France

WMO: 070310

Lat: 49.3644N

Lon: 0.1669E

Elev: 146

StdP: 99.58

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.2	(c) -2.6	(d) -7.6	(e) 2.0	(f) -2.7	(g) -5.7	(h) 2.4	(i) -1.5	(j) 15.8	(k) 8.3	(l) 12.3	(m) 8.8	(n) 2.5	(o) 70	(p) 0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.7	(c) 27.7	(d) 19.9	(e) 25.3	(f) 18.7	(g) 23.3	(h) 17.8	(i) 20.6	(j) 26.2	(k) 19.5	(l) 24.0	(m) 18.5	(n) 22.3	(o) 3.1	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.7	22.9	17.7	12.9	21.6	16.9	12.3	20.3	60.0	26.5	56.1	24.0	52.8	22.3	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.9	9.0	7.9	-6.8	32.2	2.2	3.0	-8.4	34.4	-9.6	36.2	-10.8	37.9	-12.4	40.1
			-7.3	22.9	2.2	1.0	-8.9	23.6	-10.2	24.2	-11.4	24.8	-13.0	25.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	4.9	5.0	7.2	9.7	12.2	15.4	17.2	16.7	14.8	12.0	8.2	5.5
	DBStd	5.43	3.65	3.62	3.36	3.24	3.09	3.03	2.72	2.71	2.84	3.22	3.03	3.54
	HDD10.0	683	159	141	98	43	11	1	0	1	1	17	69	142
	HDD18.3	2814	416	372	344	259	192	98	56	66	111	196	306	397
	CDD10.0	963	2	2	12	34	79	163	222	207	145	80	14	3
	CDD18.3	52	0	0	0	0	2	11	19	14	5	1	0	0
	CDH23.3	456	0	0	0	3	19	104	174	117	33	4	0	0
	CDH26.7	116	0	0	0	0	2	28	51	29	6	1	0	0
(14) Wind	WSAvg	3.7	4.5	4.4	4.1	3.5	3.5	3.2	3.2	3.1	2.9	3.7	4.0	4.4
(15) Precipitation	PrecAvg	833	70	61	53	57	58	64	59	68	68	88	89	96
	PrecMax	1076	136	117	174	112	95	158	117	166	154	183	202	215
	PrecMin	549	10	11	9	7	13	8	16	11	16	10	21	22
	PrecStd	116	32	31	35	31	26	37	27	42	35	42	40	44
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	15.2	19.0	23.7	25.5	30.0	31.7	30.1	27.1	22.6	16.6	13.7
		MCWB	11.6	10.1	12.3	15.5	18.0	20.6	20.9	21.0	19.0	17.5	14.5	12.0
	2%	DB	12.1	12.5	16.4	20.6	22.9	26.2	27.4	26.7	23.6	19.6	14.9	12.7
		MCWB	11.0	9.8	11.3	14.2	16.8	19.6	19.8	19.6	18.0	16.4	13.0	11.4
	5%	DB	10.9	11.2	14.3	17.6	20.2	23.5	24.9	23.8	21.5	17.7	13.7	11.6
		MCWB	9.9	9.2	10.5	12.5	15.2	17.9	18.8	18.3	16.9	15.2	12.1	10.5
	10%	DB	9.8	10.0	12.3	15.2	18.0	21.2	22.7	21.6	19.6	16.5	12.6	10.6
		MCWB	8.8	8.5	9.8	11.1	14.0	16.9	17.8	17.4	16.1	14.6	11.3	9.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.5	13.2	16.6	19.2	21.9	22.1	22.0	20.2	18.1	15.4	12.7
		MCDB	12.7	12.9	17.0	21.7	24.3	28.5	29.6	28.7	24.2	21.4	16.5	13.3
	2%	WB	11.1	10.5	12.1	14.6	17.1	19.8	20.6	20.1	18.7	16.8	13.5	11.6
		MCDB	11.9	12.0	15.0	19.9	21.2	24.8	26.2	25.2	22.3	19.2	14.5	12.4
	5%	WB	10.0	9.5	11.1	13.0	15.7	18.4	19.3	19.0	17.6	15.7	12.4	10.7
		MCDB	10.8	10.9	13.7	16.9	19.5	22.9	23.9	22.5	20.5	17.2	13.4	11.6
	10%	WB	8.9	8.5	10.0	11.6	14.5	17.2	18.2	17.9	16.6	14.9	11.5	9.6
		MCDB	9.6	9.8	12.1	14.6	17.6	20.5	21.9	20.8	19.0	16.3	12.5	10.5
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.7	7.0	8.6	8.6	8.9	8.7	8.7	8.8	6.9	5.6	5.1
		MCDBR	5.1	7.1	10.1	12.1	12.4	13.2	13.7	12.8	11.0	7.8	6.4	5.6
		MCWBR	4.7	5.2	6.3	7.1	7.2	7.3	7.3	6.8	6.2	5.2	4.9	5.0
	5% WB	MCDWR	4.9	6.0	8.6	11.5	11.1	11.7	12.1	11.1	9.5	7.1	6.1	5.1
		MCWBR	4.8	5.0	5.8	7.1	6.9	7.1	7.0	6.6	5.9	5.1	5.1	4.9
(40) Clear-Sky Solar Irradiance	taub		0.323	0.340	0.373	0.392	0.397	0.397	0.391	0.386	0.369	0.354	0.330	0.317
	taud		2.437	2.408	2.313	2.276	2.301	2.333	2.350	2.386	2.417	2.452	2.451	2.404
	Ebn at Noon		729	804	831	853	862	864	862	851	829	776	711	676
	Edh at Noon		64	82	106	122	124	121	118	108	95	78	63	58
(44) All-Sky Solar Radiation	RadAvg		0.90	1.64	2.79	4.34	5.10	5.69	5.45	4.61	3.56	2.04	1.08	0.75
	RadStd		0.09	0.21	0.32	0.45	0.42	0.56	0.39	0.36	0.23	0.18	0.11	0.10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page