

DIEPPE, France

WMO: 070400

Lat: 49.9325N

Lon: 1.0889E

Elev: 125

StdP: 14.63

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	28.2	18.2	13.8	27.7	21.7	16.4	29.8	35.0	45.5	32.3	45.3	8.1	170	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	78.0	66.0	73.6	64.5	70.7	63.6	67.9	74.9	66.2	71.4	64.7	69.3	8.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	94.0	70.6	63.9	89.5	69.0	62.7	85.6	67.6	32.3	75.5	30.9	71.4	29.8	69.4	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
29.1	25.3	22.1	21.3	89.9	4.8	4.7	17.8	93.3	15.0	96.1	12.3	98.7	8.8	102.2		
			19.9	72.1	4.7	2.6	16.6	74.0	13.8	75.5	11.2	77.0	7.9	78.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	41.4	42.3	45.6	49.2	54.8	59.6	63.0	63.7	60.0	55.2	48.3	43.1	
	DBStd	9.47	6.92	6.08	5.23	5.18	4.95	4.37	3.88	3.67	4.10	5.38	5.53	6.73	
	HDD50	1061	270	219	153	73	10	0	0	0	0	18	93	225	
	HDD65	4732	731	635	600	473	320	172	86	69	158	307	502	679	
	CDD50	1882	5	4	18	50	158	289	403	424	300	178	41	12	
	CDD65	77	0	0	0	0	4	11	24	28	9	1	0	0	
	CDH74	356	0	0	0	2	30	83	87	109	42	3	0	0	
	CDH80	98	0	0	0	0	2	27	30	30	9	0	0	0	
Wind	WSAvg	10.7	12.4	12.2	11.2	9.9	9.8	9.2	9.3	9.4	9.9	10.8	11.9	12.4	
Precipitation	PrecAvg	34.4	3.0	2.5	2.0	2.3	2.6	2.5	2.6	2.7	2.8	3.7	3.7	4.0	
	PrecMax	46.9	6.7	5.8	7.2	5.4	5.1	5.7	5.4	6.5	6.5	8.8	8.9	9.8	
	PrecMin	24.9	0.3	0.5	0.3	0.1	0.2	0.8	0.5	0.6	0.5	0.7	0.9	0.8	
	PrecStd	5.9	1.5	1.4	1.5	1.5	1.3	1.3	1.3	1.6	1.7	1.9	1.8	2.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	58.2	64.9	71.6	79.0	84.2	83.7	85.2	80.1	72.5	62.9	57.9	
		MCWB	52.9	50.3	53.9	57.6	66.4	69.3	66.6	67.3	65.4	63.4	58.5	54.2	
	2%	DB	54.4	54.7	58.7	64.7	71.1	74.3	74.6	76.6	72.2	67.4	59.5	56.0	
		MCWB	51.4	50.2	52.0	54.6	60.4	64.8	66.4	66.2	63.1	61.4	56.0	53.0	
	5%	DB	52.1	52.5	55.5	59.9	65.5	68.8	71.4	72.3	68.8	64.5	57.7	54.0	
		MCWB	49.1	48.7	50.7	52.3	58.3	62.6	64.6	65.0	62.3	59.6	54.4	51.2	
	10%	DB	50.2	50.6	52.8	56.5	61.8	66.0	69.1	69.7	66.5	62.4	55.9	52.1	
		MCWB	47.7	47.5	49.2	51.3	56.9	60.9	63.6	63.8	61.2	58.3	52.8	49.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	52.8	55.7	58.5	66.1	69.7	70.0	70.4	67.8	64.4	59.6	55.2
			MCDB	55.7	56.1	61.3	67.8	75.5	83.4	79.4	79.7	74.2	69.8	62.0	56.8
2%		WB	51.6	50.9	53.2	55.7	61.6	65.6	67.3	67.8	65.2	62.1	56.6	53.3	
		MCDB	53.9	53.8	57.4	63.0	68.5	72.6	73.1	73.9	69.8	66.5	59.0	55.4	
5%		WB	49.5	49.3	51.2	53.4	59.1	63.3	65.7	66.1	63.5	60.5	54.9	51.6	
		MCDB	51.6	51.8	54.7	58.4	64.2	68.0	70.3	70.9	67.6	63.6	57.2	53.9	
10%		WB	47.9	47.8	49.6	51.8	57.3	61.6	64.2	64.7	62.1	59.0	53.1	49.6	
		MCDB	50.0	50.3	52.4	55.5	61.4	65.3	68.2	68.8	65.9	61.9	55.6	51.7	
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.8	9.8	11.4	10.7	10.3	10.2	11.2	12.0	10.6	8.5	7.9	
		MCDBR	8.3	11.4	14.1	18.1	18.2	16.8	15.3	16.5	16.4	13.1	9.3	7.8	
		MCWBR	7.5	8.5	9.1	10.0	10.4	10.0	8.6	9.1	9.4	8.4	7.6	7.2	
	5% WB	MCDBR	7.8	9.5	11.9	14.9	15.2	14.9	13.1	14.0	13.5	11.5	8.4	7.9	
		MCWBR	7.6	7.9	8.5	9.1	9.5	9.6	8.2	8.7	8.6	8.4	7.5	7.6	
Clear-Sky Solar Irradiance	taub	0.331	0.349	0.386	0.406	0.412	0.412	0.408	0.401	0.382	0.366	0.339	0.324		
	taud	2.395	2.370	2.267	2.233	2.267	2.299	2.313	2.354	2.390	2.418	2.415	2.375		
	Ebn at Noon	223	249	257	265	269	269	268	264	257	239	218	207		
	Edh at Noon	21	27	35	40	41	40	39	36	31	25	20	18		
All-Sky Solar Radiation	RadAvg	276	508	883	1392	1639	1826	1749	1476	1118	640	323	224		
	RadStd	26	69	104	136	128	167	132	108	68	58	32	28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+1.04	N/A	N/A	N/A	N/A	N/A
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page