

DIEPPE, France

WMO: 070400

Lat: 49.9325N

Lon: 1.0889E

Elev: 38

StdP: 100.87

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.1	-7.7	2.0	-2.4	-5.7	2.3	-1.2	15.6	7.5	14.4	7.4	3.6	170	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	25.6	18.9	23.1	18.1	21.5	17.5	20.0	23.8	19.0	21.9	18.2	20.7	3.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	21.4	17.7	12.8	20.5	17.1	12.2	19.8	57.2	24.2	54.0	21.9	51.5	20.8	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.0	11.3	9.9	-6.0	32.2	2.7	2.6	-7.9	34.1	-9.4	35.6	-10.9	37.1	-12.9	39.0		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-6.7	22.3	2.6	1.4	-8.6	23.3	-10.1	24.2	-11.5	25.0	-13.4	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	5.2	5.7	7.6	9.6	12.7	15.4	17.2	17.6	15.6	12.9	9.0	6.2
	DBStd	5.26	3.84	3.38	2.91	2.88	2.75	2.43	2.16	2.04	2.28	2.99	3.07	3.74
	HDD10.0	589	150	122	85	41	6	0	0	0	0	10	52	125
	HDD18.3	2629	406	353	333	263	178	96	48	38	88	171	279	377
	CDD10.0	1046	3	2	10	28	88	161	224	236	167	99	23	7
	CDD18.3	43	0	0	0	0	2	6	13	16	5	1	0	0
	CDH23.3	198	0	0	0	1	17	46	48	61	23	2	0	0
	CDH26.7	54	0	0	0	0	1	15	17	17	5	0	0	0
Wind	WSAvg	4.8	5.6	5.4	5.0	4.4	4.4	4.1	4.2	4.2	4.4	4.8	5.3	5.6
Precipitation	PrecAvg	873	75	63	52	59	65	64	66	68	72	94	94	102
	PrecMax	1192	169	147	183	136	130	146	138	165	165	224	227	248
	PrecMin	632	8	12	7	3	6	21	12	14	13	18	22	20
	PrecStd	150	39	36	38	37	33	33	33	40	43	47	46	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	14.6	18.3	22.0	26.1	29.0	28.7	29.6	26.7	22.5	17.2	14.4
		MCWB	11.6	10.1	12.2	14.2	19.1	20.7	19.2	19.6	18.5	17.4	14.7	12.3
	2%	DB	12.5	12.6	14.8	18.2	21.7	23.5	23.7	24.8	22.3	19.7	15.3	13.3
		MCWB	10.8	10.1	11.1	12.6	15.8	18.2	19.1	19.0	17.3	16.3	13.3	11.7
	5%	DB	11.1	11.4	13.0	15.5	18.6	20.5	21.9	22.4	20.5	18.1	14.3	12.2
		MCWB	9.5	9.3	10.4	11.3	14.6	17.0	18.1	18.3	16.8	15.4	12.4	10.7
	10%	DB	10.1	10.3	11.6	13.6	16.6	18.9	20.6	21.0	19.2	16.9	13.3	11.2
		MCWB	8.7	8.6	9.5	10.7	13.8	16.0	17.5	17.7	16.2	14.6	11.6	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.6	13.1	14.7	19.0	21.0	21.1	21.3	19.9	18.0	15.3	12.9
		MCDB	13.2	13.4	16.3	19.9	24.2	28.5	26.3	26.5	23.4	21.0	16.7	13.8
	2%	WB	10.9	10.5	11.8	13.2	16.5	18.6	19.6	19.9	18.4	16.7	13.7	11.8
		MCDB	12.2	12.1	14.1	17.2	20.3	22.5	22.8	23.3	21.0	19.2	15.0	13.0
	5%	WB	9.7	9.6	10.7	11.9	15.1	17.4	18.7	19.0	17.5	15.8	12.7	10.9
		MCDB	10.9	11.0	12.6	14.7	17.9	20.0	21.3	21.6	19.8	17.5	14.0	12.2
	10%	WB	8.8	8.8	9.8	11.0	14.0	16.4	17.9	18.2	16.7	15.0	11.7	9.8
		MCDB	10.0	10.1	11.3	13.1	16.3	18.5	20.1	20.4	18.8	16.6	13.1	11.0
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.9	5.5	6.3	5.9	5.7	5.7	6.2	6.7	5.9	4.7	4.4
		MCDBR	4.6	6.4	7.8	10.1	10.1	9.3	8.5	9.2	9.1	7.3	5.2	4.4
		MCWBR	4.2	4.7	5.0	5.6	5.8	5.5	4.8	5.1	5.2	4.6	4.2	4.0
	5% WB	MCDBR	4.4	5.3	6.6	8.3	8.4	8.3	7.3	7.8	7.5	6.4	4.7	4.4
		MCWBR	4.2	4.4	4.7	5.1	5.3	5.3	4.6	4.8	4.8	4.7	4.1	4.2
Clear-Sky Solar Irradiance	taub	0.331	0.349	0.386	0.406	0.412	0.412	0.408	0.401	0.382	0.366	0.339	0.324	
	taud	2.395	2.370	2.267	2.233	2.267	2.299	2.313	2.354	2.390	2.418	2.415	2.375	
	Ebn at Noon	703	784	811	836	847	848	845	833	811	754	687	651	
	Edh at Noon	65	85	111	127	128	125	122	112	97	80	64	58	
All-Sky Solar Radiation	RadAvg	0.87	1.60	2.78	4.39	5.17	5.76	5.51	4.65	3.52	2.02	1.02	0.70	
	RadStd	0.08	0.22	0.33	0.43	0.40	0.53	0.42	0.34	0.21	0.18	0.10	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A	N/A
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page