

PONTOISE, France

WMO: 070530

Lat: 49.0903N

Lon: 2.0286E

Elev: 289

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 20.9	(c) 24.8	(d) 14.2	(e) 11.4	(f) 22.7	(g) 20.8	(h) 15.8	(i) 26.9	(j) 25.4	(k) 49.4	(l) 23.2	(m) 48.8	(n) 5.6	(o) 60	(p) 0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	87.7	67.9	82.8	66.4	80.3	65.4	70.0	83.5	68.1	80.2	66.5	77.0	8.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.3	94.5	74.6	64.1	90.5	72.7	62.5	85.5	71.1	34.2	84.0	32.5	80.5	31.1	77.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Max
(a) 21.2	(b) 18.9	(c) 16.6		(e) 16.8	(f) 97.6	(g) 7.2	(h) 3.6	(i) 11.6	(j) 100.2	(k) 7.4	(l) 102.3	(m) 3.4	(n) 104.3	(o) -1.9	(p) 107.0	(q) 76.9
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	38.8	39.4	45.4	50.1	54.8	61.2	65.4	64.4	59.3	53.3	45.8	40.5
	DBStd	11.17	7.44	7.40	5.61	6.01	5.85	6.29	6.01	5.81	5.26	6.21	6.03	6.95
	HDD50	1386	350	297	161	71	18	1	0	0	2	36	152	298
	HDD65	5082	812	715	609	447	322	148	68	83	182	363	575	758
	CDD50	1979	3	2	18	75	166	338	478	445	283	140	26	5
	CDD65	196	0	0	0	0	5	34	81	63	12	1	0	0
	CDH74	2587	0	0	0	27	91	474	1015	805	157	18	0	0
	CDH80	801	0	0	0	0	5	147	347	266	34	2	0	0
(14) Wind	WSAvg	7.6	8.2	8.7	8.6	7.5	7.3	7.3	7.0	6.5	6.7	7.1	8.2	8.5
(15) Precipitation	PrecAvg	26.8	2.3	2.0	1.8	1.9	2.4	2.2	2.4	2.2	1.9	2.4	2.4	2.8
	PrecMax	38.1	5.4	3.9	6.6	4.8	6.4	4.8	5.8	4.3	4.2	6.0	4.7	7.1
	PrecMin	19.8	0.2	0.3	0.2	0.4	0.2	0.4	0.7	0.4	0.0	0.5	0.6	1.1
	PrecStd	4.5	1.1	1.1	1.3	1.1	1.2	1.0	1.2	1.2	1.1	1.2	1.0	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	60.4	68.1	77.3	80.5	91.1	95.0	93.2	84.5	75.6	64.0	57.5
		MCWB	52.2	50.5	53.5	60.1	67.2	69.2	69.7	69.8	65.9	63.3	59.6	54.0
	2%	DB	53.7	54.0	64.3	73.2	76.9	84.1	87.6	86.4	78.7	71.2	60.7	55.4
		MCWB	51.0	48.8	52.8	57.6	62.7	67.6	68.1	67.7	64.1	62.6	56.8	52.4
	5%	DB	51.6	51.8	59.3	66.5	72.0	79.2	82.8	82.2	73.7	66.1	57.6	53.5
		MCWB	48.7	48.3	50.9	55.5	60.7	66.1	66.2	66.3	62.0	59.7	54.2	50.3
	10%	DB	49.1	49.8	55.4	62.6	68.0	75.0	79.2	78.5	71.2	62.8	55.4	51.4
		MCWB	47.2	46.8	49.5	53.3	58.7	63.8	65.1	63.9	60.6	58.2	52.5	48.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.7	51.8	56.0	62.2	69.4	72.7	71.7	71.9	68.1	65.4	60.6	55.4
		MCDB	55.6	56.1	63.2	76.0	78.1	87.5	90.9	87.4	79.2	72.1	62.9	57.0
	2%	WB	51.6	50.4	54.0	58.3	64.6	69.2	69.7	69.3	65.5	62.8	57.1	52.8
		MCDB	53.7	53.1	61.9	69.9	73.5	80.6	83.7	82.7	73.9	69.1	60.1	55.3
	5%	WB	49.2	48.6	52.0	56.0	61.7	66.9	67.8	67.2	63.8	60.8	54.9	50.9
		MCDB	50.8	51.4	58.5	65.7	69.4	77.2	81.3	78.2	71.8	65.6	57.8	53.3
	10%	WB	47.1	46.6	50.1	54.1	59.5	64.8	65.9	65.4	62.1	59.0	52.9	48.7
		MCDB	48.9	49.5	55.1	61.7	66.7	73.2	76.8	75.1	69.0	62.3	55.5	50.6
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	12.4	16.6	20.4	21.5	22.2	23.6	23.9	21.0	16.4	11.5	10.6
		MCDBR	10.2	15.6	25.0	26.7	28.6	29.8	30.4	30.3	26.0	20.1	14.5	13.0
		MCWBR	8.7	11.4	15.4	15.1	16.9	15.6	13.9	13.8	13.5	12.6	11.4	10.7
	5% WB	MCDBR	10.3	15.0	21.1	25.0	25.8	27.8	28.6	27.6	22.2	18.4	13.2	12.4
		MCWBR	9.2	11.8	13.9	14.8	16.7	16.2	14.3	15.1	13.0	12.1	11.0	10.9
(40) Clear-Sky Solar Irradiance	taub		0.332	0.352	0.387	0.407	0.414	0.415	0.414	0.405	0.379	0.369	0.341	0.325
	taud		2.393	2.352	2.247	2.209	2.227	2.261	2.262	2.310	2.368	2.386	2.403	2.368
	Ebn at Noon		227	250	258	266	268	269	267	264	259	240	220	211
	Edh at Noon		21	28	36	42	43	42	41	37	32	27	21	19
(44) All-Sky Solar Radiation	RadAvg		286	528	897	1375	1616	1800	1708	1474	1139	669	344	239
	RadStd		31	75	111	156	152	172	139	137	88	56	33	35

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page