

PARIS BEAUVAIS TILLE AP, France

WMO: 070550

Lat: 49.4464N

Lon: 2.1272E

Elev: 109

StdP: 100.02

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.9	-3.9	-8.6	1.8	-4.7	-6.4	2.2	-2.6	13.3	9.9	12.0	9.4	2.4	30	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	30.2	19.9	28.0	19.2	26.0	18.4	21.0	28.1	20.0	26.1	19.0	24.6	3.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.7	23.4	17.7	12.9	22.2	16.9	12.2	21.4	61.2	28.3	57.5	26.1	54.4	24.7	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.2	8.2	DB	-8.8	34.5	2.8	2.4	-10.8	36.2	-12.5	37.6	-14.1	38.9	-16.1	40.7	(4)
			WB	-9.2	23.0	2.8	1.0	-11.2	23.7	-12.9	24.3	-14.5	24.9	-16.5	25.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	3.9	4.5	7.0	9.5	12.8	16.1	18.3	18.1	15.1	11.7	7.3	4.4
	DBStd	6.17	4.18	3.73	3.29	3.27	3.25	3.07	3.03	2.99	2.82	3.34	3.53	4.06
	HDD10.0	799	192	155	102	48	10	1	0	0	1	22	94	176
	HDD18.3	2856	448	387	351	266	172	81	38	39	104	207	332	432
	CDD10.0	1078	2	2	9	32	98	183	258	252	153	73	13	3
	CDD18.3	93	0	0	0	0	2	13	38	33	6	1	0	0
	CDH23.3	1133	0	0	0	5	42	183	444	382	72	4	0	0
	CDH26.7	341	0	0	0	0	3	48	141	135	13	1	0	0
Wind	WSAvg	3.9	4.4	4.4	4.3	3.9	3.7	3.4	3.5	3.4	3.5	3.7	3.9	4.2
Precipitation	PrecAvg	734	65	55	50	52	62	60	63	60	53	66	67	82
	PrecMax	1029	160	117	178	122	160	147	136	111	129	173	126	197
	PrecMin	524	5	10	7	11	7	12	17	9	4	17	18	28
	PrecStd	126	33	31	36	30	32	31	31	34	35	33	28	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.9	19.2	24.0	26.8	30.9	33.2	34.0	28.6	23.3	16.8	13.8
		MCWB	11.5	10.4	12.2	15.6	19.1	20.8	20.9	21.0	19.1	17.5	14.6	12.2
	2%	DB	12.2	12.4	16.6	21.2	24.5	27.8	30.1	30.4	25.4	20.2	14.8	12.6
		MCWB	10.8	9.8	11.6	14.5	17.2	19.4	19.7	19.9	17.9	16.2	13.1	11.2
	5%	DB	10.8	11.1	14.2	18.2	22.1	25.2	27.9	27.7	22.8	18.1	13.6	11.5
		MCWB	9.4	9.3	10.7	12.7	16.1	18.4	19.1	18.9	16.7	14.9	12.1	10.3
	10%	DB	9.6	10.0	12.6	15.9	19.8	23.0	25.7	25.0	20.8	16.7	12.5	10.2
		MCWB	8.4	8.4	9.8	11.5	14.8	17.0	18.4	17.7	15.7	14.2	11.1	9.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.5	13.4	17.3	20.2	22.2	21.9	22.4	20.3	18.1	15.2	12.6
		MCDB	13.0	13.5	16.9	22.9	25.6	28.8	30.5	30.7	26.0	21.7	16.4	13.4
	2%	WB	10.9	10.4	12.3	14.8	18.2	20.2	20.8	20.9	18.7	16.7	13.4	11.5
		MCDB	12.0	11.8	15.3	19.7	23.0	26.0	28.3	27.9	23.6	19.5	14.5	12.4
	5%	WB	9.6	9.5	11.2	13.2	16.5	19.0	19.8	19.6	17.6	15.6	12.3	10.4
		MCDB	10.6	10.9	13.9	17.4	20.9	24.3	26.1	25.6	21.4	17.7	13.5	11.4
	10%	WB	8.4	8.5	10.1	11.9	15.3	17.7	18.9	18.6	16.6	14.6	11.2	9.2
		MCDB	9.4	9.9	12.2	15.3	19.2	22.0	24.3	23.7	19.9	16.3	12.4	10.1
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.5	8.5	10.5	10.6	11.1	11.5	11.4	10.4	8.3	6.0	5.2
		MCDBR	5.5	7.9	12.0	14.5	14.8	15.5	16.1	16.3	13.9	10.2	6.5	5.4
		MCWBR	4.8	6.0	7.7	8.5	8.2	8.2	7.1	7.0	7.2	6.6	5.1	4.7
	5% WB	MCDBR	5.4	7.1	10.1	13.1	12.9	13.8	14.0	14.4	11.6	9.1	6.0	5.2
		MCWBR	5.0	5.8	6.9	8.1	7.9	7.9	6.8	7.0	6.7	6.2	5.1	4.8
Clear-Sky Solar Irradiance	taub	0.328	0.347	0.383	0.404	0.412	0.412	0.411	0.402	0.377	0.364	0.337	0.321	
	taud	2.393	2.357	2.248	2.206	2.224	2.256	2.258	2.307	2.362	2.392	2.406	2.368	
	Ebn at Noon	715	790	817	839	848	849	843	833	817	758	696	663	
	Edh at Noon	66	86	113	131	134	131	129	117	100	83	65	60	
All-Sky Solar Radiation	RadAvg	0.88	1.62	2.78	4.31	5.06	5.61	5.33	4.57	3.53	2.07	1.05	0.73	
	RadStd	0.10	0.24	0.34	0.50	0.48	0.54	0.45	0.42	0.27	0.18	0.10	0.10	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page