

CREIL AP, France

WMO: 070570

Lat: 49.2522N

Lon: 2.5208E

Elev: 291

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.3	24.9	16.2	12.6	24.4	20.2	15.3	27.3	35.6	50.8	27.7	49.6	3.3	30	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	86.4	67.9	82.5	66.7	79.1	65.1	69.8	82.3	68.0	79.1	66.4	76.2	7.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	95.5	73.8	64.1	90.4	72.0	62.6	85.9	70.3	33.9	82.6	32.4	79.2	31.1	76.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.4	17.4	15.8	94.3	4.6	3.5	12.5	96.9	9.8	99.0	7.2	101.0	3.9	103.5
			15.2	73.0	4.6	1.4	11.9	74.1	9.2	74.9	6.6	75.7	3.3	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	39.2	40.2	45.1	50.7	56.5	62.4	66.1	65.0	59.9	53.6	45.4	40.2
	DBStd	11.42	7.56	7.09	6.31	6.17	5.87	5.66	5.48	4.92	5.10	6.38	6.48	7.29
	HDD50	1379	338	279	175	63	10	0	0	0	1	38	165	310
	HDD65	4918	799	696	617	430	270	116	52	60	167	354	588	769
	CDD50	2145	4	4	23	84	212	372	500	464	298	150	27	7
	CDD65	206	0	0	0	0	7	37	87	59	14	2	0	0
	CDH74	2155	0	0	0	23	102	416	846	614	144	10	0	0
	CDH80	624	0	0	0	0	13	120	266	199	26	0	0	0
Wind	WSAvg	7.7	8.6	9.4	8.5	7.7	7.4	7.4	7.2	6.3	6.3	7.3	7.9	8.0
Precipitation	PrecAvg	26.1	2.1	1.8	1.7	1.8	2.3	2.3	2.4	2.4	1.9	2.4	2.2	2.7
	PrecMax	38.5	5.4	3.9	6.3	4.7	5.8	4.7	5.7	5.1	4.7	5.6	4.1	6.3
	PrecMin	18.9	0.2	0.3	0.1	0.1	0.1	0.6	0.6	0.4	0.0	0.8	0.4	0.8
	PrecStd	4.5	1.1	1.1	1.3	1.1	1.2	1.1	1.3	1.2	1.1	1.1	0.9	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.4	60.4	68.2	77.1	81.5	89.5	92.3	91.5	83.9	75.1	63.3	57.7
		MCWB	52.9	50.3	53.0	60.1	66.1	69.5	70.0	68.8	66.5	62.7	58.2	54.0
	2%	DB	54.1	55.1	63.7	72.7	76.8	83.3	86.8	85.2	78.6	69.6	59.8	55.2
		MCWB	51.2	49.0	52.4	57.7	62.9	67.3	68.0	67.2	64.9	61.6	55.9	52.2
	5%	DB	51.8	52.6	59.3	66.9	72.8	78.7	82.6	80.6	73.9	65.5	57.2	53.2
		MCWB	48.9	48.6	50.8	55.2	60.9	65.4	66.8	65.9	62.9	59.4	53.7	50.3
	10%	DB	49.6	50.5	55.5	62.7	68.4	74.5	78.9	76.3	70.3	62.7	54.7	50.8
		MCWB	47.1	47.2	49.4	53.0	58.6	63.4	65.5	63.6	61.1	58.0	51.9	48.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	52.2	55.7	62.7	68.1	72.7	71.9	71.6	68.8	64.6	59.7	54.8
		MCDB	55.6	55.6	63.4	75.1	78.6	85.6	87.9	85.9	77.9	70.8	62.0	56.5
	2%	WB	51.7	50.7	53.8	58.7	64.7	68.9	69.8	68.9	66.3	62.1	56.5	52.6
		MCDB	53.6	53.7	59.9	69.6	74.0	79.6	82.7	81.7	75.3	67.7	59.3	54.7
	5%	WB	49.3	49.1	52.0	56.0	61.9	66.6	67.9	66.8	64.3	60.3	54.3	50.7
		MCDB	51.4	52.1	57.9	65.0	69.8	76.1	79.4	77.1	71.6	64.6	56.8	52.9
	10%	WB	47.3	47.3	50.2	53.9	59.8	64.6	66.2	65.2	62.6	58.6	52.2	48.4
		MCDB	49.3	50.1	55.4	61.4	66.8	72.7	76.7	73.7	68.7	62.1	54.6	50.5
Mean Daily Temperature Range	5% DB	MDBR	9.3	12.0	15.6	18.6	18.4	19.0	19.2	19.9	19.0	14.5	10.7	9.6
		MCDBR	9.3	14.7	23.1	25.9	25.2	26.5	26.4	28.3	25.0	17.4	11.8	9.6
		MCWBR	8.0	10.5	13.3	13.5	12.9	12.6	10.6	12.4	12.4	10.3	8.8	8.1
	5% WB	MCDBR	9.2	12.3	18.3	22.8	21.5	23.1	23.2	23.6	20.3	15.9	11.1	9.5
		MCWBR	8.3	9.8	11.7	12.7	12.3	12.3	10.1	11.6	11.0	10.2	9.0	8.4
Clear-Sky Solar Irradiance	taub		0.330	0.351	0.386	0.407	0.415	0.415	0.416	0.406	0.379	0.369	0.341	0.325
	taud		2.394	2.355	2.247	2.210	2.225	2.257	2.254	2.305	2.367	2.385	2.403	2.369
	Ebn at Noon		227	250	258	266	268	268	266	263	259	239	220	210
	Edh at Noon		21	28	36	42	43	42	41	37	32	27	21	19
All-Sky Solar Radiation	RadAvg		280	520	894	1375	1617	1789	1695	1465	1131	667	334	230
	RadStd		33	80	111	160	163	167	149	146	95	54	33	36

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page