

LANDIVISIAU AP, France

WMO: 071060

Lat: 48.5256N

Lon: 4.1472W

Elev: 348

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.4	32.5	24.2	18.6	33.3	27.2	21.4	35.4	33.6	48.2	30.2	48.8	7.5	70	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	77.7	65.5	73.8	63.6	70.8	62.5	67.0	74.7	65.3	71.0	63.9	68.4	10.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	92.1	68.8	63.1	87.6	67.1	62.0	84.1	65.8	31.7	75.3	30.3	71.0	29.3	68.5	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	24.5	21.7	26.0	85.0	3.3	4.3	23.6	88.0	21.7	90.5	19.8	92.9	17.5	96.0		
(5)			24.7	70.6	3.4	2.6	22.2	72.5	20.3	74.1	18.4	75.6	15.9	77.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	44.3	44.1	46.6	49.5	54.2	59.0	62.1	61.4	59.5	54.7	49.0	45.5	(6)
(7)		DBStd	8.00	5.01	5.10	4.95	4.82	4.59	4.39	3.97	3.60	4.43	4.82	4.56	5.29	(7)
(8)		HDD50	795	181	171	127	64	13	0	0	0	1	12	71	155	(8)
(9)		HDD65	4595	640	584	570	464	337	189	109	122	176	320	480	604	(9)
(10)		CDD50	1722	6	7	22	50	142	269	374	353	284	158	41	16	(10)
(11)		CDD65	46	0	0	0	0	1	8	17	10	9	1	0	0	(11)
(12)		CDH74	328	0	0	0	4	16	81	121	59	42	5	0	0	(12)
(13)		CDH80	61	0	0	0	0	1	20	26	9	4	1	0	0	(13)
(14)	Wind	WSAvg	10.5	12.0	11.9	11.5	10.7	10.0	9.5	9.4	9.2	9.0	9.7	10.9	11.9	(14)
(15)	Precipitation	PrecAvg	40.8	4.9	4.1	2.6	3.2	2.6	2.1	2.3	2.4	2.4	4.1	4.9	5.2	(15)
(16)		PrecMax	49.9	9.9	8.5	7.1	7.4	5.4	5.1	4.8	5.7	6.0	7.3	10.1	10.5	(16)
(17)		PrecMin	31.0	1.0	0.7	0.4	0.7	0.5	0.3	0.6	0.6	0.3	0.8	1.4	0.8	(17)
(18)		PrecStd	4.6	2.3	2.1	1.5	1.7	1.3	1.3	1.2	1.5	1.5	1.4	2.1	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.6	59.8	66.0	72.4	75.9	83.0	83.3	80.7	79.2	70.7	62.4	58.0	(19)
(20)			MCWB	54.0	52.0	54.7	57.4	63.6	69.0	68.5	66.0	65.5	62.8	58.0	54.8	(20)
(21)		2%	DB	54.4	54.6	59.5	65.4	68.9	74.9	77.0	74.1	73.9	66.3	59.6	56.4	(21)
(22)			MCWB	52.9	50.7	52.0	55.6	59.9	64.0	65.3	64.7	64.2	60.9	56.8	54.4	(22)
(23)		5%	DB	53.2	53.0	55.7	60.4	65.4	70.6	73.2	70.4	69.8	63.6	57.5	54.9	(23)
(24)			MCWB	51.7	50.6	51.3	53.4	58.2	62.2	63.4	62.9	62.3	59.6	55.3	53.4	(24)
(25)		10%	DB	52.0	51.7	53.6	57.0	62.2	67.3	69.8	67.8	66.7	61.8	56.0	53.6	(25)
(26)			MCWB	50.5	49.8	50.5	51.4	56.3	60.5	62.1	61.5	61.1	58.6	53.9	52.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	54.0	55.8	59.6	64.4	69.2	69.2	68.7	68.0	63.8	59.9	56.3	(27)
(28)			MCD B	55.3	56.4	62.9	68.2	72.7	79.8	80.0	77.3	76.6	67.8	61.1	56.8	(28)
(29)		2%	WB	53.6	52.4	53.8	56.2	61.0	65.4	66.5	66.1	65.6	62.2	57.4	54.9	(29)
(30)			MCD B	54.1	53.7	57.0	63.6	67.5	72.7	74.5	71.0	70.9	65.0	58.8	55.9	(30)
(31)		5%	WB	52.2	51.2	52.4	54.1	58.9	63.1	64.8	64.6	63.8	60.7	55.7	53.7	(31)
(32)			MCD B	52.9	52.5	54.9	59.0	64.2	69.0	70.7	68.2	67.7	63.1	57.4	54.9	(32)
(33)		10%	WB	50.9	49.9	51.1	52.5	57.1	61.2	63.2	63.1	62.2	59.3	54.1	52.3	(33)
(34)			MCD B	51.8	51.5	53.4	56.3	61.0	66.0	67.9	66.3	65.5	61.3	55.7	53.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	9.9	11.4	13.3	13.6	13.8	13.6	13.4	13.9	11.8	9.7	9.0	(35)
(36)			MCDBR	9.3	11.3	14.8	19.0	18.7	20.3	19.9	17.7	18.1	13.5	10.5	9.0	(36)
(37)			MCWBR	8.7	8.8	9.7	11.1	11.1	11.5	10.1	9.8	9.9	8.6	8.6	8.4	(37)
(38)		5% WB	MCDBR	8.5	9.7	12.6	16.5	16.7	18.0	16.9	14.8	15.5	11.6	10.3	8.6	(38)
(39)			MCWBR	8.9	8.8	9.1	10.3	10.6	11.0	9.7	9.3	9.6	8.3	9.2	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.347	0.372	0.381	0.385	0.378	0.378	0.367	0.357	0.354	0.334	0.325	(40)	
(41)		taud	2.396	2.377	2.318	2.312	2.344	2.388	2.391	2.442	2.454	2.454	2.426	2.364	(41)	
(42)		Ebn at Noon	230	254	266	275	278	280	278	277	269	249	227	214	(42)	
(43)		Edh at Noon	22	27	34	38	38	36	36	33	30	25	21	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	304	555	919	1434	1702	1850	1758	1502	1195	700	377	254	(44)	
(45)		RadStd	24	60	95	125	147	197	100	122	86	53	33	30	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page