

VELIZY-VILLACOUBLAY AB, France

WMO: 071470

Lat: 48.770N

Lon: 2.205E

Elev: 176

StdP: 99.23

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.6	-3.0	-9.4	1.7	-2.4	-7.0	2.1	-1.3	11.4	9.0	10.3	8.3	3.2	30	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	30.4	19.8	28.3	19.0	26.5	18.3	20.9	28.2	20.0	26.3	19.1	24.8	3.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.7	23.5	17.7	12.9	22.5	16.8	12.2	21.5	61.2	28.2	57.8	26.2	54.7	24.9	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.1	7.2	-6.8	34.1	2.2	2.4	-8.4	35.8	-9.7	37.2	-10.9	38.6	-12.5	40.3
			-7.4	22.9	2.3	1.1	-9.1	23.7	-10.4	24.4	-11.7	25.0	-13.3	25.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	4.1	4.9	7.8	10.4	14.0	17.3	19.4	19.3	15.8	12.2	7.5	4.7	(6)
(7)		DBStd	6.50	3.88	3.68	3.50	3.56	3.58	3.58	3.50	3.39	3.09	3.38	3.40	3.74	(7)
(8)		HDD10.0	731	185	146	85	37	6	1	0	0	1	17	88	167	(8)
(9)		HDD18.3	2668	442	377	326	239	141	62	28	27	88	190	325	423	(9)
(10)		CDD10.0	1274	1	2	17	48	131	219	292	287	175	87	13	3	(10)
(11)		CDD18.3	168	0	0	0	1	7	30	61	56	12	1	0	0	(11)
(12)		CDH23.3	1347	0	0	0	7	55	243	512	449	76	4	0	0	(12)
(13)		CDH26.7	384	0	0	0	0	5	66	154	147	13	0	0	0	(13)
(14)	Wind	WSAvg	3.7	4.1	4.1	4.0	3.8	3.7	3.5	3.4	3.2	3.3	3.5	3.6	4.0	(14)
(15)	Precipitation	PrecAvg	643	52	47	44	49	61	54	57	46	59	57	63	(15)	
(16)		PrecMax	916	131	100	138	132	168	116	173	128	101	137	113	171	(16)
(17)		PrecMin	477	5	5	8	7	2	8	16	7	0	11	12	23	(17)
(18)		PrecStd	108	25	25	29	29	33	26	33	29	26	30	24	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	15.1	19.7	24.3	27.1	31.5	33.5	28.3	23.5	16.7	13.6	(19)	
(20)			MCWB	11.5	9.9	11.6	14.7	18.5	21.0	20.9	20.8	18.5	17.0	14.3	12.0	(20)
(21)		2%	DB	11.8	12.2	17.1	21.3	24.9	28.6	30.2	30.5	25.6	20.7	14.9	12.3	(21)
(22)			MCWB	10.4	9.2	11.1	13.3	16.4	19.4	19.7	19.7	17.5	16.1	13.2	11.0	(22)
(23)		5%	DB	10.5	11.0	14.9	18.6	22.8	26.1	28.2	28.0	23.1	18.6	13.5	11.2	(23)
(24)			MCWB	9.2	8.9	10.1	12.1	15.6	18.3	18.9	19.0	16.7	15.1	11.9	10.0	(24)
(25)		10%	DB	9.3	9.9	13.1	16.4	20.6	24.0	26.2	25.7	21.2	17.0	12.3	10.0	(25)
(26)			MCWB	8.1	8.2	9.7	11.1	14.7	17.2	18.3	18.0	15.6	14.3	10.9	8.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.1	13.1	15.9	19.3	22.4	21.8	19.7	18.0	15.0	12.4	(27)	
(28)			MCDWB	12.8	13.0	16.7	23.0	25.6	29.6	30.1	30.3	25.5	21.6	16.2	13.1	(28)
(29)		2%	WB	10.6	10.1	12.0	14.0	17.8	20.4	20.8	20.7	18.5	16.6	13.3	11.2	(29)
(30)			MCDWB	11.5	11.6	15.3	19.2	23.2	26.4	28.2	28.0	23.5	19.6	14.5	12.1	(30)
(31)		5%	WB	9.4	9.3	11.0	12.7	16.4	19.1	19.8	19.7	17.5	15.6	12.2	10.2	(31)
(32)			MCDWB	10.4	10.7	13.9	17.3	21.1	24.3	26.3	25.9	21.8	18.1	13.4	11.1	(32)
(33)		10%	WB	8.2	8.3	10.1	11.7	15.2	18.0	18.9	18.7	16.5	14.7	11.1	9.1	(33)
(34)			MCDWB	9.2	9.8	12.8	15.5	19.5	23.1	24.9	24.3	20.3	16.6	12.2	9.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.5	7.0	8.2	8.7	9.2	9.5	8.6	6.8	5.0	4.5	(35)	
(36)			MCDBR	5.2	6.9	9.8	11.1	11.5	12.3	12.4	12.4	10.9	8.6	5.7	4.9	(36)
(37)			MCWBR	4.5	4.8	5.4	5.4	5.7	5.6	4.8	4.8	4.8	4.9	4.4	4.4	(37)
(38)		5% WB	MCDBR	5.1	6.1	7.9	9.7	10.5	10.7	10.8	10.9	9.5	7.8	5.3	4.9	(38)
(39)			MCWBR	4.7	4.9	5.1	5.2	5.9	5.7	4.8	5.0	4.9	4.9	4.4	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.333	0.353	0.387	0.404	0.411	0.413	0.411	0.401	0.375	0.370	0.342	0.326	(40)	
(41)		taud	2.388	2.342	2.241	2.216	2.234	2.264	2.262	2.312	2.373	2.372	2.393	2.361	(41)	
(42)		Ebn at Noon	718	788	816	842	851	850	844	836	823	756	697	667	(42)	
(43)		Edh at Noon	68	89	115	130	133	130	129	117	100	85	67	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.91	1.70	2.88	4.36	5.14	5.73	5.43	4.72	3.64	2.15	1.10	0.77	(44)	
(45)		RadStd	0.10	0.24	0.36	0.49	0.50	0.54	0.45	0.46	0.30	0.17	0.11	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page