

PARIS ONLY AP, France

WMO: 071490

Lat: 48.7167N

Lon: 2.3844E

Elev: 89

StdP: 100.26

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.7	-3.0	-8.9	1.8	-2.2	-6.6	2.2	-1.5	13.2	9.9	11.7	9.2	2.8	30	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	31.4	20.2	29.3	19.5	27.4	18.7	21.4	29.0	20.4	27.2	19.5	25.7	3.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	13.9	23.8	18.0	13.1	22.9	17.1	12.4	22.1	62.3	29.0	58.9	27.4	55.8	25.6	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.1	8.8	7.8	-7.4	35.3	2.4	2.1	-9.2	36.9	-10.6	38.1	-12.0	39.3	-13.8	40.9	
			DB												
			WB	-8.0	23.2	2.5	1.0	-9.8	23.9	-11.2	24.5	-12.6	25.1	-14.4	25.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	4.5	5.2	8.1	11.0	14.7	18.1	20.2	19.9	16.3	12.6	7.9	5.0
	DBStd	6.59	4.03	3.70	3.34	3.43	3.34	3.29	3.28	3.16	2.84	3.40	3.54	3.85
	HDD10.0	670	174	137	76	27	3	0	0	0	0	14	81	158
	HDD18.3	2512	429	368	316	221	122	44	17	17	74	178	313	412
	CDD10.0	1402	2	2	18	58	148	243	318	307	188	96	17	4
	CDD18.3	202	0	0	0	1	8	37	76	66	13	1	0	0
	CDH23.3	1824	0	0	0	16	84	337	683	592	104	8	0	0
	CDH26.7	582	0	0	0	1	11	98	231	220	22	1	0	0
Wind	WSAvg	3.8	4.2	4.2	4.1	3.9	3.8	3.7	3.6	3.3	3.4	3.5	3.6	4.1
Precipitation	PrecAvg	635	49	46	43	49	62	56	57	55	47	57	55	59
	PrecMax	880	117	86	120	121	166	121	175	128	101	130	106	152
	PrecMin	470	5	5	8	6	3	5	19	6	0	18	10	19
	PrecStd	103	23	23	26	30	32	28	35	28	27	28	24	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	15.8	20.5	25.3	28.1	32.3	34.6	35.8	29.2	24.6	17.5	14.1
		MCWB	11.9	10.2	12.4	16.0	18.9	21.1	21.2	21.6	19.2	17.4	14.4	12.3
	2%	DB	12.4	13.0	17.8	22.7	25.7	29.4	31.2	31.6	26.3	21.5	15.5	12.9
		MCWB	10.8	9.8	11.5	14.4	17.2	19.8	20.1	20.2	17.8	16.6	13.4	11.3
	5%	DB	11.1	11.7	15.5	19.7	23.5	27.1	29.2	29.0	23.7	19.2	14.1	11.8
		MCWB	9.6	9.4	10.8	12.9	16.1	18.8	19.4	19.3	17.0	15.3	12.3	10.4
	10%	DB	9.9	10.5	13.7	17.3	21.3	24.9	27.2	26.5	21.8	17.6	12.9	10.6
		MCWB	8.6	8.7	10.1	11.7	15.2	17.7	18.7	18.3	15.9	14.5	11.3	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.3	11.6	13.6	16.8	20.0	22.7	22.2	22.5	20.2	18.2	15.3	12.7
		MCDB	13.4	13.7	17.6	23.9	26.5	30.3	31.3	31.4	26.7	22.4	16.5	13.7
	2%	WB	11.1	10.6	12.5	14.8	18.2	20.9	21.2	21.2	18.8	17.0	13.7	11.6
		MCDB	12.2	12.3	16.0	20.7	24.1	26.9	29.1	28.9	24.0	20.5	15.2	12.6
	5%	WB	9.8	9.8	11.5	13.5	16.8	19.6	20.2	20.2	17.8	16.0	12.5	10.6
		MCDB	10.9	11.3	14.5	18.4	21.8	25.4	27.2	26.7	22.3	18.5	13.9	11.7
	10%	WB	8.6	8.8	10.5	12.3	15.6	18.4	19.3	19.1	16.9	15.0	11.5	9.5
		MCDB	9.7	10.4	13.3	16.5	20.3	23.8	25.7	25.0	20.7	17.2	12.8	10.5
Mean Daily Temperature Range	5% DB	MDBR	5.0	6.4	8.2	9.3	9.4	9.8	10.2	10.4	9.7	7.8	5.7	5.0
		MCDBR	5.6	8.0	11.5	13.1	12.9	13.4	13.5	14.4	12.9	9.9	6.6	5.1
		MCWBR	4.7	5.6	6.6	6.6	6.1	5.9	5.0	5.4	5.8	5.6	4.7	4.3
	5% WB	MCDBR	5.4	6.8	9.2	11.5	11.3	11.7	11.8	12.4	10.7	8.8	5.9	5.0
		MCWBR	4.8	5.3	5.9	6.1	6.0	5.9	4.8	5.3	5.4	5.4	4.6	4.4
Clear-Sky Solar Irradiance	taub	0.336	0.357	0.392	0.411	0.417	0.420	0.419	0.408	0.381	0.375	0.347	0.331	
	taud	2.383	2.333	2.231	2.201	2.222	2.251	2.249	2.301	2.365	2.363	2.388	2.356	
	Ebn at Noon	714	783	811	835	845	843	837	830	818	751	692	662	
	Edh at Noon	69	90	116	132	135	132	131	119	101	86	68	63	
All-Sky Solar Radiation	RadAvg	0.91	1.70	2.89	4.37	5.15	5.75	5.44	4.73	3.64	2.16	1.10	0.76	
	RadStd	0.11	0.24	0.36	0.49	0.51	0.53	0.46	0.46	0.31	0.17	0.11	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page