

PARIS LE BOURGET AP, France

WMO: 071500

Lat: 48.9675N

Lon: 2.4275E

Elev: 66

StdP: 100.53

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-2.7	-8.3	1.9	-2.6	-6.2	2.3	-1.1	11.6	11.0	10.2	10.6	2.5	30	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	31.3	20.1	29.1	19.3	27.1	18.5	21.2	29.0	20.2	27.0	19.3	25.5	3.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.6	23.7	17.7	12.8	22.7	16.9	12.2	22.0	61.7	28.9	58.1	27.3	55.1	25.6	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.3	-6.6	35.8	2.1	2.5	-8.1	37.6	-9.3	39.1	-10.5	40.5	-12.0	42.3		
(5)			-7.1	23.0	2.1	1.1	-8.7	23.8	-9.9	24.5	-11.1	25.1	-12.6	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	4.8	5.4	8.2	11.3	14.5	18.0	19.9	19.4	16.6	12.8	8.1	5.3	(6)
(7)		DBStd	6.41	4.05	3.81	3.44	3.38	3.34	3.33	3.26	3.00	2.90	3.46	3.45	3.86	(7)
(8)		HDD10.0	640	165	134	76	24	3	0	0	0	0	14	74	150	(8)
(9)		HDD18.3	2469	419	363	313	212	126	45	19	21	68	174	306	403	(9)
(10)		CDD10.0	1393	4	3	21	62	143	241	306	291	197	100	19	6	(10)
(11)		CDD18.3	181	0	0	0	1	7	36	67	53	16	2	0	0	(11)
(12)		CDH23.3	1669	0	0	0	20	87	331	620	478	123	9	0	0	(12)
(13)		CDH26.7	524	0	0	0	1	12	102	217	166	26	1	0	0	(13)
(14)	Wind	WSAvg	3.5	3.8	3.9	3.8	3.6	3.4	3.3	3.3	3.0	3.3	3.5	3.8	(14)	
(15)	Precipitation	PrecAvg	641	50	45	43	49	61	55	58	46	58	56	62	(15)	
(16)		PrecMax	900	125	95	136	127	157	114	180	117	97	130	114	155	(16)
(17)		PrecMin	482	5	6	9	9	1	6	17	6	0	15	11	23	(17)
(18)		PrecStd	106	24	24	29	30	31	26	37	28	26	28	24	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	16.1	20.7	25.6	28.2	32.7	34.6	35.8	29.6	24.6	17.9	14.8	(19)
(20)			MCWB	12.0	10.4	12.2	16.1	19.1	21.0	21.0	21.8	19.3	17.2	14.9	12.5	(20)
(21)		2%	DB	13.0	13.4	18.1	23.1	25.6	29.6	31.3	31.0	27.0	21.8	16.1	13.4	(21)
(22)			MCWB	11.0	9.9	11.8	14.6	17.3	19.9	19.9	19.8	18.1	16.8	13.7	11.4	(22)
(23)		5%	DB	11.7	12.2	15.9	19.9	23.7	27.0	29.0	28.2	24.4	19.4	14.6	12.2	(23)
(24)			MCWB	9.9	9.6	11.0	13.2	16.4	18.6	19.3	19.0	17.3	15.5	12.4	10.5	(24)
(25)		10%	DB	10.5	11.0	13.9	17.7	21.2	24.8	26.8	25.9	22.3	17.8	13.2	11.1	(25)
(26)			MCWB	8.8	8.7	10.3	12.1	15.3	17.8	18.6	17.8	16.4	14.7	11.3	9.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	11.7	13.6	17.1	20.2	22.7	22.0	22.5	20.4	18.4	15.6	12.9	(27)
(28)			MCD B	14.0	14.2	17.6	24.3	27.0	30.4	31.7	32.4	26.9	22.3	17.1	14.3	(28)
(29)		2%	WB	11.2	10.7	12.6	15.1	18.3	20.7	21.0	21.0	19.0	17.0	13.9	11.8	(29)
(30)			MCD B	12.7	12.8	16.5	21.1	24.0	27.2	29.0	28.8	24.7	20.6	15.8	13.1	(30)
(31)		5%	WB	10.0	9.9	11.6	13.7	17.0	19.5	20.0	19.7	18.1	16.0	12.6	10.7	(31)
(32)			MCD B	11.5	11.8	15.0	18.8	22.1	25.5	27.0	26.1	22.9	18.9	14.3	12.1	(32)
(33)		10%	WB	8.9	8.9	10.6	12.5	15.7	18.4	19.1	18.8	17.2	15.1	11.5	9.6	(33)
(34)			MCD B	10.3	10.8	13.7	16.9	20.3	23.8	25.7	24.2	21.5	17.4	13.2	11.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	6.4	8.3	9.5	9.8	10.0	10.3	10.5	9.9	7.8	5.8	5.2	(35)
(36)			MCDBR	5.1	8.1	12.1	13.6	13.5	14.1	14.3	14.9	13.3	9.8	6.9	5.4	(36)
(37)			MCWBR	4.4	5.6	6.8	6.8	6.6	6.1	5.3	6.0	6.0	5.5	5.1	4.5	(37)
(38)		5% WB	MCD BR	5.0	6.7	9.6	11.8	12.0	12.2	12.4	13.0	10.9	8.9	6.3	5.3	(38)
(39)			MCWBR	4.5	5.2	6.0	6.4	6.6	6.1	5.1	6.0	5.6	5.4	5.0	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.357	0.392	0.412	0.419	0.420	0.420	0.409	0.382	0.375	0.346	0.330	(40)	
(41)		taud	2.387	2.341	2.236	2.205	2.224	2.255	2.254	2.304	2.367	2.372	2.393	2.361	(41)	
(42)		Ebn at Noon	711	782	809	834	843	842	836	828	815	750	690	659	(42)	
(43)		Edh at Noon	68	89	115	132	134	131	130	118	101	85	67	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.90	1.67	2.86	4.35	5.13	5.70	5.39	4.68	3.61	2.13	1.08	0.75	(44)	
(45)		RadStd	0.11	0.25	0.35	0.50	0.51	0.53	0.46	0.46	0.31	0.17	0.10	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page