

PARIS VATRY AP, France

WMO: 071660

Lat: 48.7772N

Lon: 4.1647E

Elev: 179

StdP: 99.19

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.9	-4.9	-9.8	1.7	-6.0	-7.2	2.1	-3.9	14.3	8.9	13.2	8.4	3.1	30	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	31.0	20.2	28.9	19.5	26.9	19.0	21.4	28.3	20.5	26.9	19.6	25.4	3.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.2	23.7	18.2	13.3	22.7	17.3	12.6	21.7	62.8	28.4	59.7	27.1	56.6	25.1	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.6	10.2	9.1	-10.0	35.0	3.0	2.6	-12.1	36.8	-13.9	38.3	-15.6	39.7	-17.7	41.6		
			-10.4	23.3	3.0	0.9	-12.6	23.9	-14.4	24.5	-16.1	24.9	-18.3	25.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	2.9	3.5	6.6	10.3	13.5	17.2	19.4	18.6	15.5	11.6	6.7	3.7
	DBStd	6.83	4.14	3.92	3.47	3.49	3.38	3.41	3.32	3.10	3.04	3.81	3.75	3.94
	HDD10.0	897	222	182	114	37	7	1	0	0	1	28	110	197
	HDD18.3	2882	479	414	363	241	154	61	27	34	96	210	348	454
	CDD10.0	1202	1	1	9	47	116	217	292	266	164	77	12	2
	CDD18.3	146	0	0	0	1	4	27	61	42	10	1	0	0
	CDH23.3	1510	0	0	0	11	57	296	629	413	99	5	0	0
	CDH26.7	476	0	0	0	0	10	87	221	141	17	0	0	0
(14) Wind	WSAvg	4.4	5.0	5.0	5.0	4.2	4.0	3.8	3.8	3.8	3.8	4.3	4.7	5.1
(15) Precipitation	PrecAvg	726	59	55	48	52	63	59	63	65	55	68	64	73
	PrecMax	1007	130	111	129	143	147	148	155	151	124	150	140	171
	PrecMin	543	11	9	4	6	13	14	13	9	11	22	21	8
	PrecStd	106	26	29	29	34	27	28	30	39	31	31	32	36
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	14.8	19.8	24.9	28.0	32.2	34.7	33.9	28.9	24.0	17.0	13.2
		MCWB	11.2	10.5	11.6	16.6	20.1	21.4	21.1	20.9	18.6	17.5	14.4	11.7
	2%	DB	11.2	11.9	17.1	22.2	24.8	29.0	31.1	30.2	26.1	21.0	15.0	11.9
		MCWB	10.1	9.2	11.2	14.8	17.5	20.1	20.1	20.0	18.2	16.6	13.2	10.8
	5%	DB	10.0	10.1	14.2	19.7	22.8	26.8	29.0	27.8	23.9	18.9	13.8	10.5
		MCWB	9.2	8.7	10.0	13.7	16.5	19.4	19.4	18.9	17.5	15.7	12.1	9.4
	10%	DB	8.8	9.0	12.2	17.1	20.3	24.2	27.0	25.1	21.4	17.0	12.1	9.2
		MCWB	8.1	7.9	9.2	12.1	15.2	18.2	18.9	17.9	16.3	14.4	10.8	8.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.0	13.2	17.3	21.2	22.8	22.4	22.0	20.3	18.2	15.1	12.3
		MCDB	12.3	13.6	16.5	23.7	27.0	28.9	31.0	30.8	25.6	21.9	16.3	12.9
	2%	WB	10.6	9.9	11.9	15.5	18.7	21.3	21.2	20.8	19.1	17.1	13.3	10.9
		MCDB	11.3	11.0	15.9	20.8	22.8	27.1	28.7	27.9	24.3	20.0	14.8	11.9
	5%	WB	9.2	8.9	10.8	13.9	17.1	19.9	20.3	19.8	18.0	16.0	12.2	9.7
		MCDB	9.8	10.1	13.4	18.6	21.2	25.3	27.3	25.9	22.6	18.4	13.4	10.3
	10%	WB	7.9	7.8	9.7	12.6	15.9	18.7	19.4	18.7	17.1	14.9	11.0	8.5
		MCDB	8.5	8.8	12.0	16.7	19.7	23.4	25.5	23.8	20.9	16.8	12.1	9.1
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	6.5	8.9	10.3	10.3	10.8	11.3	10.9	10.4	8.2	5.8	5.1
		MCDBR	5.8	8.4	12.9	14.1	13.8	14.3	14.9	15.3	13.8	10.3	6.9	5.9
	5% WB	MCWBR	5.3	6.4	7.9	7.7	7.9	6.9	6.0	6.4	6.8	6.4	5.2	5.1
		MCWBR	5.5	7.6	10.5	12.5	11.9	12.9	13.1	12.6	11.8	9.4	6.4	5.6
(40) Clear-Sky Solar Irradiance	taub	taub	0.316	0.338	0.369	0.398	0.406	0.410	0.407	0.399	0.370	0.359	0.329	0.313
		taud	2.423	2.372	2.291	2.218	2.237	2.259	2.258	2.304	2.365	2.392	2.420	2.391
	Ebn at Noon	Ebn at Noon	745	808	838	848	855	852	848	839	829	771	717	690
		Edh at Noon	66	86	109	130	133	131	129	118	101	83	65	60
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.89	1.66	2.87	4.33	5.12	5.72	5.43	4.69	3.62	2.14	1.05	0.72
	RadStd	RadStd	0.13	0.27	0.38	0.52	0.56	0.53	0.49	0.49	0.33	0.16	0.10	0.13

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page