

TROYES-BARBEREY AP, France

WMO: 071680

Lat: 48.3247N

Lon: 4.0200E

Elev: 388

StdP: 14.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.6	23.9	13.5	11.1	21.2	18.5	14.1	26.1	31.2	49.6	28.1	49.6	5.0	300	0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	89.7	68.8	85.8	67.7	82.2	66.7	71.0	85.2	69.4	82.6	67.7	79.3	8.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	98.8	75.9	64.8	93.2	73.9	63.5	88.8	72.4	35.0	85.4	33.6	82.9	32.2	79.4	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	21.0	18.4	DB	13.8	96.7	4.6	4.5	10.5	100.0	7.8	102.6	5.2	105.1	1.9	108.3	(4)
(5)			WB	13.2	74.5	4.7	1.6	9.8	75.6	7.1	76.6	4.4	77.5	1.0	78.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	38.4	39.8	44.8	50.0	56.8	63.0	67.3	66.4	59.8	53.4	44.6	39.7
	DBStd	12.06	7.80	7.12	6.19	5.94	5.96	6.03	5.75	5.93	5.37	6.69	6.96	7.43
	HDD50	1469	362	288	182	71	11	0	0	0	1	42	186	326
	HDD65	5002	825	706	625	450	262	108	41	52	173	363	611	786
	CDD50	2225	3	3	21	71	221	390	536	508	294	147	25	6
	CDD65	279	0	0	0	0	7	48	112	94	16	2	0	0
	CDH74	3627	0	0	0	26	153	666	1367	1163	233	19	0	0
	CDH80	1268	0	0	0	1	22	209	512	470	54	0	0	0
Wind	WSAvg	8.2	9.3	9.5	9.0	8.1	7.5	7.2	7.7	7.2	7.3	7.8	8.4	9.4
Precipitation	PrecAvg	26.7	1.9	1.9	1.8	2.0	2.4	2.1	2.3	2.4	2.1	2.8	2.4	2.6
	PrecMax	36.9	4.5	3.8	4.6	5.1	5.6	4.1	5.7	4.8	5.3	6.0	5.8	6.4
	PrecMin	20.2	0.4	0.2	0.3	0.0	0.7	0.5	0.3	0.4	0.4	0.9	0.7	0.4
	PrecStd	4.1	0.9	1.0	1.0	1.2	1.1	0.9	1.3	1.3	1.2	1.4	1.2	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	60.8	69.5	77.4	82.7	91.9	95.3	98.2	85.5	76.8	64.8	57.9
		MCWB	52.9	51.1	54.7	61.7	67.3	71.0	70.3	70.2	66.1	64.2	58.0	53.5
	2%	DB	54.1	55.8	64.5	72.4	78.1	85.7	89.4	89.9	80.6	71.6	60.7	55.2
		MCWB	51.1	49.7	53.1	58.7	64.3	68.8	68.3	68.8	65.5	62.2	56.3	52.0
	5%	DB	51.8	52.9	60.0	67.5	74.5	81.3	85.7	85.2	75.6	67.6	57.7	52.8
		MCWB	48.9	48.5	51.5	56.1	62.5	67.4	67.5	67.5	63.3	60.6	54.2	50.2
	10%	DB	49.2	50.4	56.1	62.8	70.5	77.3	82.0	80.6	71.7	63.9	55.2	50.6
		MCWB	46.9	47.1	50.0	53.5	60.2	65.2	66.3	65.7	61.2	58.5	52.3	48.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	53.0	57.3	63.6	69.7	73.2	72.5	72.8	68.9	65.4	59.9	54.8
		MCDB	55.9	58.2	65.3	74.9	80.1	86.0	88.4	88.7	79.9	73.3	63.3	56.9
	2%	WB	51.6	50.9	54.6	59.7	66.1	70.6	70.5	70.6	66.3	63.3	56.7	52.4
		MCDB	53.9	54.5	61.5	70.0	75.6	82.4	85.5	85.9	77.2	70.0	59.9	54.7
	5%	WB	49.2	49.1	52.6	56.9	63.4	68.4	68.8	68.8	64.5	61.1	54.6	50.4
		MCDB	51.4	52.2	58.5	65.3	72.2	79.2	82.5	82.0	73.7	66.3	57.5	52.6
	10%	WB	46.9	47.2	50.7	54.5	61.1	66.2	67.2	66.9	62.7	59.2	52.5	48.3
		MCDB	49.0	50.3	55.6	61.4	68.6	75.6	79.2	77.7	70.1	63.4	55.0	50.3
Mean Daily Temperature Range	5% DB	MDBR	10.6	13.8	17.8	20.7	20.6	22.1	22.6	22.5	20.9	17.4	12.3	10.5
		MCDBR	12.5	18.2	25.8	29.7	28.3	29.9	30.6	31.9	28.5	22.4	15.9	12.7
		MCWBR	10.2	13.1	16.0	17.4	16.4	15.0	12.6	13.3	14.8	14.0	11.7	10.2
	5% WB	MCDBR	12.2	15.8	21.5	26.1	25.1	26.5	26.6	27.2	24.2	20.1	15.0	11.6
		MCWBR	10.4	12.0	14.3	16.0	15.2	14.2	11.5	12.7	13.2	13.0	11.6	9.6
Clear-Sky Solar Irradiance	taub	0.317	0.340	0.369	0.399	0.406	0.414	0.410	0.401	0.372	0.362	0.331	0.314	
	taud	2.431	2.376	2.301	2.221	2.246	2.260	2.263	2.309	2.369	2.394	2.429	2.404	
	Ebn at Noon	238	257	267	269	272	270	269	266	263	245	229	221	
	Edh at Noon	21	27	35	41	42	42	41	37	32	27	21	19	
All-Sky Solar Radiation	RadAvg	294	547	934	1385	1634	1840	1747	1516	1170	701	354	242	
	RadStd	41	85	120	167	176	169	151	151	105	52	34	44	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page