

SAINT-DIZIER AB, France

WMO: 071690

Lat: 48.6314N

Lon: 4.9036E

Elev: 458

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.3	24.2	13.0	10.8	25.2	17.1	13.3	28.2	25.2	48.7	22.6	48.6	4.7	100	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	89.7	68.9	85.9	67.5	82.4	66.5	71.0	84.7	69.3	82.0	67.7	79.0	7.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	99.4	75.5	65.1	94.5	73.6	63.8	90.1	72.0	35.0	85.1	33.6	82.2	32.3	79.1	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max			Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.2	17.8	15.7		14.4	96.0	5.2	4.5	10.6	99.3	7.5	101.9	4.6	104.4	0.8	107.7	
			DB	13.6	74.1	5.2	1.5	9.9	75.2	6.8	76.0	3.9	76.8	0.2	77.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	38.2	40.0	45.3	51.0	57.8	64.1	68.0	67.0	60.0	53.6	44.8	39.7
	DBStd	12.37	7.59	6.90	6.43	6.40	6.34	6.51	6.07	6.16	5.61	6.70	6.99	7.35
	HDD50	1452	370	283	173	63	9	0	0	0	1	41	185	327
	HDD65	4898	832	700	612	422	237	95	36	47	168	357	607	785
	CDD50	2368	3	3	26	92	250	422	558	526	302	151	28	7
	CDD65	338	0	0	0	1	13	66	129	108	19	2	0	0
	CDH74	3784	0	0	0	42	206	768	1370	1176	205	17	0	0
	CDH80	1297	0	0	0	3	33	249	511	459	42	0	0	0
	WSAvg	7.1	8.1	8.0	8.0	7.3	6.9	6.5	6.5	5.8	6.1	6.7	7.1	8.0
	PrecAvg	34.7	3.0	2.8	2.5	2.5	2.8	2.6	2.9	2.9	2.8	3.2	3.2	3.6
Precipitation	PrecMax	46.6	5.9	6.1	5.7	6.7	4.8	6.5	7.4	6.9	6.4	8.6	7.3	8.9
	PrecMin	25.0	0.7	0.5	0.2	0.1	0.6	1.0	0.5	0.5	0.6	1.0	0.7	0.8
	PrecStd	5.1	1.3	1.5	1.5	1.6	1.1	1.2	1.3	1.7	1.7	1.5	1.5	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.2	61.4	70.2	78.7	84.2	92.2	95.2	97.6	85.0	76.5	65.2	58.4
		MCWB	51.3	49.8	53.8	60.3	66.0	69.1	70.4	69.9	66.5	63.7	56.6	51.8
	2%	DB	53.9	56.4	65.2	73.6	79.2	86.5	89.1	89.8	79.9	71.4	60.9	55.2
		MCWB	50.6	48.0	52.4	57.3	62.9	68.6	68.6	69.2	65.1	62.0	55.3	51.1
	5%	DB	51.5	52.7	60.7	68.8	75.6	82.2	85.7	85.1	75.3	67.6	57.6	52.9
		MCWB	48.5	47.6	50.5	55.4	61.2	67.0	67.2	67.3	63.5	60.1	53.3	49.9
	10%	DB	48.9	50.1	56.5	64.1	71.6	78.4	81.9	80.7	71.4	63.9	55.0	50.4
		MCWB	46.2	46.3	49.0	53.2	59.8	64.8	66.2	65.8	61.3	58.3	51.7	47.7
	0.4%	WB	53.4	52.1	56.4	62.3	68.2	72.7	72.9	72.9	69.3	65.3	58.6	54.2
		MCDB	54.8	56.9	64.9	76.1	80.9	86.7	88.0	87.9	79.1	72.7	62.2	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	51.1	50.1	54.0	58.8	65.1	70.2	70.7	70.7	66.7	63.0	55.9	51.9
		MCDB	53.4	53.8	61.5	69.6	75.6	82.6	84.5	85.3	76.8	69.8	59.7	54.2
	5%	WB	48.6	48.4	52.1	56.3	62.8	68.0	69.0	68.9	64.7	60.9	53.9	50.1
		MCDB	51.0	52.0	58.5	66.0	72.1	79.7	81.9	81.5	72.9	66.1	57.0	52.7
	10%	WB	46.5	46.5	50.2	54.2	60.8	66.1	67.3	67.2	62.8	59.0	52.0	47.9
		MCDB	48.7	49.8	55.6	62.2	69.4	75.9	78.6	77.7	69.9	63.0	54.9	50.3
Mean Daily Temperature Range	5% DB	MDBR	9.9	12.9	16.6	19.4	19.5	20.4	20.4	20.9	18.7	15.9	11.3	9.7
		MCDBR	11.3	18.3	25.2	28.2	27.3	27.5	27.5	29.7	25.6	20.5	14.9	12.1
		MCWBR	8.7	12.1	14.5	14.4	13.1	12.3	10.4	11.5	12.4	11.9	10.2	9.1
	5% WB	MCDBR	10.5	14.8	19.9	24.8	23.8	24.9	24.2	25.0	21.9	18.4	12.9	10.4
		MCWBR	8.9	10.8	12.3	13.3	12.7	12.1	10.1	10.6	11.5	11.4	9.7	8.6
Clear-Sky Solar Irradiance	taub	0.315	0.339	0.367	0.397	0.405	0.411	0.407	0.400	0.373	0.361	0.330	0.312	
	taud	2.436	2.380	2.309	2.239	2.255	2.273	2.279	2.319	2.373	2.400	2.431	2.409	
	Ebn at Noon	238	257	267	270	272	270	269	266	262	245	228	221	
	Edh at Noon	21	27	34	40	42	41	40	37	32	26	21	19	
All-Sky Solar Radiation	RadAvg	283	528	915	1373	1621	1819	1730	1489	1152	683	334	228	
	RadStd	45	88	124	171	188	170	161	158	107	49	32	44	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page