

NANCY-OCHEY AB, France

WMO: 071810

Lat: 48.5811N

Lon: 5.9597E

Elev: 1106

StdP: 14.12

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.9	21.7	11.1	10.1	22.2	15.6	12.6	26.1	29.8	46.9	26.9	45.4	5.9	60	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	87.9	67.5	83.7	66.3	80.3	64.8	69.5	83.0	67.8	79.9	66.3	77.6	8.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.2	97.1	73.6	63.7	92.0	71.8	62.3	87.5	70.4	34.1	82.8	32.8	80.1	31.5	77.8	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.4	20.5	18.0	11.9	93.5	4.6	4.9	8.5	97.1	5.8	100.0	3.2	102.8	-0.2	106.4
			11.2	72.6	4.8	1.3	7.7	73.5	4.9	74.3	2.1	75.1	-1.4	76.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	35.8	37.4	43.6	49.7	56.3	62.6	66.0	65.7	58.7	51.7	42.6	37.4
	DBStd	12.78	7.88	7.76	6.99	6.81	6.56	6.58	6.30	6.40	5.75	6.95	7.12	7.43
	HDD50	1817	440	356	217	89	17	0	0	0	3	64	237	394
	HDD65	5482	904	774	664	460	280	123	63	69	204	413	672	856
	CDD50	2070	1	2	18	79	212	377	496	486	263	117	16	3
	CDD65	259	0	0	0	0	10	50	94	90	14	1	0	0
	CDH74	2724	0	0	0	14	108	539	1007	921	133	2	0	0
	CDH80	859	0	0	0	0	15	158	337	331	18	0	0	0
Wind	WSAvg	8.0	9.3	9.1	8.8	7.9	7.3	7.0	7.1	6.5	6.9	8.0	8.4	9.6
Precipitation	PrecAvg	34.2	3.1	2.8	2.4	2.1	2.9	2.5	2.8	2.9	2.7	3.2	3.2	3.6
	PrecMax	44.2	7.4	6.3	6.5	5.0	5.3	6.4	6.1	6.8	5.6	8.1	8.0	10.3
	PrecMin	24.6	0.7	0.6	0.4	0.3	0.3	0.8	0.8	0.8	0.7	0.7	0.7	0.4
	PrecStd	4.9	1.5	1.5	1.6	1.3	1.1	1.3	1.2	1.5	1.4	1.6	1.7	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	59.0	67.6	76.1	81.8	90.8	93.4	95.2	82.5	73.6	62.4	55.7
		MCWB	50.1	47.8	52.3	58.6	65.1	68.1	68.1	68.0	64.9	61.3	55.5	50.4
	2%	DB	51.6	53.9	63.1	71.3	76.9	84.6	87.5	88.0	78.0	69.0	58.0	52.7
		MCWB	48.8	46.8	50.3	56.2	62.1	67.1	67.1	67.9	63.8	60.0	53.4	49.4
	5%	DB	49.0	50.6	58.5	66.6	73.3	80.1	83.3	82.9	73.8	65.1	55.4	50.3
		MCWB	46.4	45.6	48.8	53.9	59.9	65.3	65.8	66.0	62.4	58.3	52.1	47.7
	10%	DB	46.4	47.7	54.6	62.6	69.5	76.1	79.7	79.0	69.8	61.8	52.6	47.9
		MCWB	44.2	44.3	47.6	51.9	58.8	63.5	64.5	64.7	60.3	56.8	50.0	46.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	50.0	54.0	60.4	66.7	71.5	71.0	71.5	67.6	63.0	56.9	52.3
		MCDB	52.9	55.2	62.6	72.6	78.2	85.7	86.1	85.9	76.6	70.3	60.1	53.7
	2%	WB	49.3	48.2	52.0	57.3	64.0	68.4	69.0	69.4	65.5	61.0	54.2	49.8
		MCDB	51.1	52.5	59.1	68.8	74.0	80.3	83.4	82.8	74.8	66.9	57.1	52.3
	5%	WB	46.5	46.4	50.2	55.1	61.7	66.6	67.4	67.6	63.7	59.1	52.3	47.9
		MCDB	48.6	49.8	56.3	64.5	70.3	77.9	80.2	79.3	71.7	63.8	55.1	50.1
	10%	WB	44.3	44.5	48.5	53.0	59.7	64.8	65.6	65.9	61.8	57.2	50.1	45.9
		MCDB	46.2	47.5	53.9	60.9	67.4	74.7	77.1	76.5	68.2	61.3	52.5	47.9
Mean Daily Temperature Range	5% DB	MDBR	8.6	11.0	14.9	17.4	18.1	19.9	19.7	19.6	17.3	13.6	9.6	8.1
		MCDBR	10.0	16.1	22.4	25.0	24.3	25.6	26.2	27.3	23.8	17.9	13.0	10.6
		MCWBR	7.9	10.5	12.7	12.8	12.0	11.6	10.3	11.0	11.4	10.4	9.0	8.2
	5% WB	MCDBR	9.6	13.6	17.7	22.1	21.6	23.2	23.8	23.8	20.0	16.0	11.9	9.5
		MCWBR	8.1	9.6	11.0	11.8	11.6	11.3	10.3	10.9	10.8	10.0	9.0	7.9
Clear-Sky Solar Irradiance	taub	0.307	0.331	0.357	0.387	0.396	0.402	0.397	0.393	0.368	0.353	0.324	0.304	
	taud	2.445	2.391	2.330	2.263	2.274	2.291	2.297	2.331	2.378	2.411	2.442	2.427	
	Ebn at Noon	242	260	271	273	274	273	272	268	264	248	232	226	
	Edh at Noon	20	27	33	39	41	40	39	36	32	26	20	18	
All-Sky Solar Radiation	RadAvg	287	529	917	1368	1617	1834	1727	1493	1148	682	336	231	
	RadStd	45	90	132	178	184	163	165	156	112	51	33	42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (49 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page