

NANCY-OCHEY AB, France

WMO: 071810

Lat: 48.5811N

Lon: 5.9597E

Elev: 337

StdP: 97.34

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.8	-5.7	-11.6	1.4	-5.4	-9.1	1.8	-3.3	13.3	8.3	12.0	7.5	2.6	60	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	31.1	19.7	28.7	19.0	26.8	18.2	20.8	28.4	19.9	26.6	19.1	25.4	3.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.9	23.1	17.6	13.1	22.1	16.8	12.5	21.4	61.5	28.2	58.3	26.7	55.4	25.5	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.1	8.0	DB	-11.2	34.2	2.6	2.7	-13.0	36.2	-14.6	37.8	-16.0	39.3	-17.9	41.3	(4)
(5)			WB	-11.6	22.6	2.7	0.7	-13.5	23.1	-15.1	23.5	-16.6	23.9	-18.5	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	2.1	3.0	6.4	9.8	13.5	17.0	18.9	18.7	14.8	11.0	5.9	3.0	(6)	
	DBStd	7.10	4.38	4.31	3.88	3.78	3.65	3.66	3.50	3.55	3.19	3.86	3.95	4.13	(7)	
	HDD10.0	1009	244	198	121	49	9	0	0	0	2	36	132	219	(8)	
	HDD18.3	3046	502	430	369	256	156	68	35	38	113	229	373	476	(9)	
	CDD10.0	1150	1	1	10	44	118	209	276	270	146	65	9	2	(10)	
	CDD18.3	144	0	0	0	0	6	28	52	50	8	1	0	0	(11)	
	CDH23.3	1513	0	0	0	8	60	299	559	512	74	1	0	0	(12)	
	CDH26.7	477	0	0	0	0	8	88	187	184	10	0	0	0	(13)	
(14) Wind	WSAvg	3.6	4.2	4.1	4.0	3.5	3.3	3.1	3.2	2.9	3.1	3.6	3.7	4.3	(14)	
(15) Precipitation	PrecAvg	869	78	71	62	53	73	64	71	74	68	81	82	91	(15)	
	PrecMax	1122	188	161	166	127	135	162	155	172	141	206	204	262	(16)	
	PrecMin	626	18	15	9	7	8	21	20	20	19	18	17	10	(17)	
	PrecStd	125	37	39	41	32	28	33	30	37	35	41	42	54	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	15.0	19.8	24.5	27.7	32.7	34.1	35.1	28.1	23.1	16.9	13.2	(19)	
		MCWB	10.1	8.8	11.3	14.8	18.4	20.0	20.1	20.0	18.3	16.3	13.1	10.2	(20)	
	2%	DB	10.9	12.2	17.3	21.8	24.9	29.2	30.9	31.1	25.5	20.5	14.4	11.5	(21)	
		MCWB	9.3	8.2	10.2	13.4	16.7	19.5	19.5	20.0	17.7	15.6	11.9	9.7	(22)	
	5%	DB	9.4	10.3	14.7	19.2	22.9	26.7	28.5	28.3	23.2	18.4	13.0	10.2	(23)	
		MCWB	8.0	7.5	9.3	12.1	15.5	18.5	18.8	18.9	16.9	14.6	11.2	8.7	(24)	
	10%	DB	8.0	8.7	12.6	17.0	20.8	24.5	26.5	26.1	21.0	16.6	11.5	8.8	(25)	
		MCWB	6.8	6.8	8.7	11.1	14.9	17.5	18.0	18.1	15.7	13.8	10.0	7.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	10.0	12.2	15.8	19.3	21.9	21.7	21.9	19.8	17.2	13.8	11.3	(27)	
		MCDB	11.6	12.9	17.0	22.6	25.6	29.8	30.1	30.0	24.8	21.3	15.6	12.1	(28)	
	2%	WB	9.6	9.0	11.1	14.0	17.8	20.2	20.6	20.8	18.6	16.1	12.3	9.9	(29)	
		MCDB	10.6	11.4	15.0	20.4	23.3	26.8	28.5	28.2	23.8	19.4	14.0	11.3	(30)	
	5%	WB	8.1	8.0	10.1	12.8	16.5	19.2	19.7	19.8	17.6	15.0	11.3	8.8	(31)	
		MCDB	9.2	9.9	13.5	18.0	21.3	25.5	26.8	26.3	22.0	17.6	12.8	10.0	(32)	
	10%	WB	6.8	7.0	9.2	11.7	15.4	18.2	18.7	18.8	16.5	14.0	10.1	7.7	(33)	
		MCDB	7.9	8.6	12.2	16.1	19.6	23.7	25.0	24.7	20.1	16.3	11.4	8.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	6.1	8.3	9.7	10.1	11.0	10.9	10.9	9.6	7.5	5.4	4.5	(35)	
		MCDBR	5.6	8.9	12.5	13.9	13.5	14.2	14.6	15.2	13.2	9.9	7.2	5.9	(36)	
	5% WB	MCWBR	4.4	5.8	7.0	7.1	6.7	6.4	5.7	6.1	6.4	5.8	5.0	4.6	(37)	
		MCWBR	5.3	7.6	9.8	12.3	12.0	12.9	13.2	13.2	11.1	8.9	6.6	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.307	0.331	0.357	0.387	0.396	0.402	0.397	0.393	0.368	0.353	0.324	0.304	(40)	
		taud	2.445	2.391	2.330	2.263	2.274	2.291	2.297	2.331	2.378	2.411	2.442	2.427	(41)	
	Ebn at Noon		762	820	853	860	865	861	859	845	832	781	730	711	(42)	
		Edh at Noon	64	85	105	124	128	127	124	115	100	82	64	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.91	1.67	2.89	4.31	5.10	5.78	5.45	4.71	3.62	2.15	1.06	0.73	(44)	
	RadStd		0.14	0.28	0.42	0.56	0.58	0.51	0.52	0.49	0.35	0.16	0.10	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page